

# DAMMON ENGINEERING, INC.

dammonengineering.com

*ARCHITECTS*

*ENGINEERS*

*CONSULTING*

*DESIGN*

*STUDIES*

*EXPERT WITNESS*

1095 Florida Ave.  
Slidell, LA 70458

P.O. Box 2830  
Slidell, LA 70459

985-649-5832  
FAX 985-641-5950

April 22, 2010

## **ADDENDUM No. 1**

Project: Pearl River High School  
Industrial Arts Building  
Roof Re-coating  
St. Tammany Parish School Board Project No. 0909

From Dammon Engineering, Inc.  
1095 Florida Ave.  
Slidell, LA 70458

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents. Acknowledge receipt of the Addendum in the space provided in the Bid Form. Failure to do so may subject Bidder to disqualification.

This Addendum consists of 1 page.

1. The value of the Industrial Arts Building, for insurance purposes, is \$800,000.00.
2. The preference of the Owner is that existing skylight panels are to be replaced with new skylight panels. The Bidder will have to provide details in accordance with their system and required warranties.
3. All specified or approved Roof Re-Coating systems to provide One Year Installer's warranty and Ten Year NDL Labor and Materials warranty from the system manufacturer.
4. Roof Re-Coating Systems, considered "Approved As Equal" are as follows:

GAF "Topcoat".

United Coatings "Roof Mate".

Adek "Polaroof/Roofab/Polarprime" System.

Uniflex Industrial Roof Coatings System.

Neogard's Elasta-Gard M Roofing System.

American Weatherstar.

5. Specification Manual, Section 076200 – Sheet Metal Flashing and Trim, Page 6, Item B. Downspouts: Hangers to be .040 thick Aluminum in lieu of that shown.

END OF DOCUMENT