

1/2" PLYWOOD

AND JOINT CAULKED WITH INTUMESCENT FIRE RATED CAULKING.

USE TREATED 1/2" PLYWOOD WITH STUCCO WRAP, UNDER ALL STUCCO SURFACES INSTALL AS CLADDING SUPPORT TO WITHSTAND 31.0 PSF & - 36.9 PSF AND LATERAL SUPPORT (SEE A4 FOR NAIL PATTERN)

USE #SP-1 TO SECURE STUDS TO BOTTOM PLATE, SP-2 TO TOP PLATE, AND #PHD2-SDS3 AT ALL MAIN BUILDING CORNERS

WALL VOIDS TO BE FILLED WITH CONCRETE WITH FIBER REINFORCING

REBAR PLACED HORIZONTALLY GRADE BEAM IN THE TOP OF THE CONCRETE BLOCK WALL.

REBAR PLACED VERTICALLY AT REGULAR INTERVALS

2 LAYERS OF 5/8" X TYPE GYPSUM SHEETING ALL JOINTS TO BE SEAMED, AND ALL PENETRATIONS TO BE FIRE CAULKED (SEE FM WP 360) FOR DETAILS

2 LAYERS OF 5/8" X TYPE GYPSUM SHEETING ALL JOINTS TO BE SEAMED, AND ALL PENETRATIONS TO BE FIRE CAULKED (SEE FM WP 360) FOR DETAILS

3/4" T & G PLYWOOD GLUE & NAILED PER A4

1/2" PLYWOOD WITH STUCCO WRAP, UNDER ALL STUCCO SURFACES INSTALL AS CLADDING SUPPORT TO WITHSTAND 31.0 PSF & - 36.9 PSF AND LATERAL SUPPORT (SEE A4 FOR NAIL PATTERN)

2 LAYERS OF 5/8" X TYPE GYPSUM SHEETING (SEE UL 301A) FOR DETAILS

2 LAYERS OF 5/8" X TYPE GYPSUM SHEETING (SEE UL 301A) FOR DETAILS

USE #SP-1 TO SECURE STUDS TO BOTTOM PLATE, SP-2 TO TOP PLATE, AND #PHD2-SDS3 AT ALL MAIN BUILDING CORNERS

2X4 STUDS 16" O.C. WALLS WITH 1" SEPERATION

WALL VOIDS TO BE FILLED WITH CONCRETE WITH FIBER REINFORCING

5/8" "J" BOLTS 10" LONG ON 28" CENTERS WITH WITH MIN. 7" EMBEDDED IN CONCRETE. ALL LOAD BEARING WALLS SHALL BE BOLTED TO FOUNDATION.

2X4 TREATED


PAINTED MDF BASE

REBAR PLACED HORIZONTALLY GRADE BEAM IN THE TOP OF THE CONCRETE BLOCK WALL.

REBAR PLACED VERTICALLY AT REGULAR INTERVALS

SEE FOUNDATION PLAN FOR FOOTING DETAILS

TYPICAL SEPARATION WALL SECTION



1. NAILHEADS - E

2. JOINTS - EXPOSED FINISHER. AS AN EXPOSED VENEER PLASTER CLASSIFIED VENEER


3. NAILS - 6D CEMENT SHANK DIAM, 1/4" NAILS 2-3/8 IN LENGTH

4. GYPSUM BOARD SURFACED, WITH EITHER HORIZONTAL OR VERTICAL JOINTS COVERED WITH GYPSUM VENEER ON THE EXPOSED SURFACE OF CLADDING



DESIGN

BEARING



1. NAILHEADS - E

2. JOINTS - EXPOSED FINISHER. AS AN EXPOSED VENEER PLASTER CLASSIFIED VENEER

3. GYPSUM BOARD SURFACED, WITH EITHER HORIZONTAL OR VERTICAL JOINTS COVERED WITH GYPSUM VENEER ON THE EXPOSED SURFACE OF CLADDING

