



DAMMON

ENGINEERING INC.
Architects & Engineers

554 Old Spanish Trail
Slidell, LA 70458
Phone: 985-649-5832
Fax: 985-641-5950
dammonengineering.com
dammoneng@bellsouth.net

August 28, 2013

William Efferson
Architect
Office of State Fire Marshal
8181 Independence Blvd.
Baton Rouge, LA 70806

Re: **PO437655**

Dear Mr. Efferson,

In regards to your review letter dated August 27, 2013 for the above referenced project. In item 5 you reference 101:36.3.6 and IBC 1018.1 requiring that corridors be separated with a minimum one-hour rated construction. However, as this building will be provided with an automatic sprinkler system the protected corridors are not required due to the following exceptions:

1. NFPA 101:36.3.6.1(3) Within buildings protected throughout by an approved, supervised automatic sprinkler system in accordance with 9.7.1.1(1).
2. IBC Table 1018.1 – Occupancy M - REQUIRED FIRE-RESISTANCE RATING (with sprinkler system) = 0 hours.

Please find attached a copy of your review letter dated August 27, 2013. If you have any additional questions please do not hesitate to contact me.

Sincerely,

Kevin J. Kinchen
Chief Architect

Enclosures

Cc: Dave Kaufmann
Farhad Aduli

LA. B.F.M. PLAN REVIEW
 437655
 READING FILE DATE MO. 12
 REVIEWER YR. 13
 W. EFFERSON
 OWNER
 SENDER
 CC'S
 COPY WHAT PGS.
 N.O.
 HO FILE ALEX LAF.
 HR FILE NON-REQ. SYST.

437655
 REVIEWED FOR
 STATE FIRE MARSHAL
 AS PER REVIEW LETTER
 BY: WILLIAM A. EFFERSON ARCHITECT

OK
 THANKS

437655

437655