

STATE OF LOUISIANA
Department of Public Safety and Corrections
Office of State Fire Marshal Code Enforcement and Building Safety
8181 Independence Boulevard
Baton Rouge, Louisiana 70806
225-925-4920

H "BUTCH" BROWNING
FIRE MARSHAL

**INFORMATION REQUEST
NOT - FOR - PERMITTING**

KEVIN KINCHEN
DAMMON ENGINEERING, INC.
554 OLD SPANISH TRAIL
SLIDELL, LA 70458-0000

RE: P0447035
FIRE STATION 14
297 STEELE RD
SLIDELL, LA 70469

NFPA 101, 2012
IBC, 2012 (CHAPTERS 9 & 10)

STORAGE

Dear Applicant:

Additional information is required to perform a proper review. The project referenced above is being held pending submission of the following information:

1. **Due to a lack of information in your submittal package regarding construction and installation of the required Kitchen exhaust hood, review of this project has been placed ON HOLD.**

The submittal appears to include a new kitchen hood(s). This office has attempted to verify compliance with the information outlined in the attached "Required Operational Features" list, the "Kitchen Exhaust Hood/Duct/Suppression System Requirements" list, and the accompanying typical construction detail/sections, but has been unsuccessful due to the lack of information submitted for review.

Please provide the information requested in the accompanying documents and return it, along with all other pertinent supplemental information addressing the items in these lists. Return the package, including a copy of this letter, to the attention of the writer. Do not send an additional application or fee. Please note that drawings and specifications from your Hood Supplier may be required to adequately address the information requested.

THE REVIEW PROCESS WILL CONTINUE UPON A TIMELY RECEIPT OF THE INFORMATION REQUESTED.

2. **NOTE: HOOD CONSTRUCTION IS NOT AUTHORIZED until a satisfactory review by this office is performed for determining compliance with minimum code requirements. Compliance with NFPA 96, regarding cooking hood construction/installation, cannot be determined with the documents**

Mar 19, 2014
P0447035 - PAGE 1

received. (A copy of the "Kitchen Exhaust Hood/Duct/Suppression System Requirements" is enclosed for your use). The following specific information was not apparently provided:

- a. Hood and duct sizes, metal type and gauge (thickness).
- b. The type of construction at the walls, attic and roof adjacent to the hood and duct.
- c. The clearance between the hood and surrounding walls and ceiling.
- d. The clearance between the exhaust duct and surrounding structure at the ceiling, the attic, and the roof.
- e. The clearances at the exhaust fan assembly.

Due to the lack of information, the referenced project has NOT been reviewed. Please direct the requested information to my attention. Processing will continue upon receipt of the information requested above. Enclose a copy of this letter with future submittals and/or other correspondence pertaining to this project.

This project will be returned as "NOT IN COMPLIANCE" if the requested information is not received by this office within 21 days of the date of this letter, thereby requiring a RESUBMITTAL of the entire project along with a new completed application and appropriate review fee.

CONSTRUCTION IS NOT AUTHORIZED until a satisfactory review has been performed and a formal review letter has been issued by this office.

REVIEWED BY:
RON MATHIS
PLAN REVIEW DEPUTY

NOTE: Please call the REVIEWER identified above if you have any questions regarding this review.
Do not call the Inspection Office until you are ready for inspection.

CC:
St Tammany Fire Protection District No. 1
Fire Station 14
Fire & Safety Commodities
Property Insurance Association*
St Tammany Fire Protection District No 1*
City Of Slidell*
City Of Slidell*