



# AIA<sup>®</sup> Document G709<sup>™</sup> – 2001

## Work Changes Proposal Request

**PROJECT** *(Name and address):*  
Slidell Jr. High School  
Reroofing of Old 6th Grade Wing  
333 Pennsylvania Ave.  
Slidell, LA 70458

**PROPOSAL REQUEST NUMBER:** 002

**OWNER:**

**DATE OF ISSUANCE:** 07/15/2014

**ARCHITECT:**

**CONSULTANT:**

**CONTRACTOR:**

**OWNER** *(Name and address):*  
St. Tammany Parish School Board  
321 N. Theard St.  
Covington, LA 70433

**CONTRACT FOR:** General Construction

**FIELD:**

**CONTRACT DATE:** 04/11/2014

**OTHER:**

**FROM ARCHITECT** *(Name and address):*  
Dammon Engineering, Inc.  
554 Old Spanish Trail  
Slidell, LA 70458

**ARCHITECT'S PROJECT NUMBER:** 2191

**TO CONTRACTOR** *(Name and address):*  
Fischer's Inc.  
11668 Chef Menteur Hwy.  
New Orleans, LA 70129

Please submit an itemized proposal for changes in the Contract Sum and Contract Time for proposed modifications to the Contract Documents described herein. Within Five (5) days, the Contractor must submit this proposal or notify the Architect, in writing, of the date on which proposal submission is anticipated.

**THIS IS NOT A CHANGE ORDER, A CONSTRUCTION CHANGE DIRECTIVE OR A DIRECTION TO PROCEED WITH THE WORK DESCRIBED IN THE PROPOSED MODIFICATIONS.**

**DESCRIPTION** *(Insert a written description of the Work):*

Omit new Paracoat Roof Coating at existing covered walkway adjacent to Fourth Street. In lieu of Paracoat, instead remove existing roof, metal gutters, downspouts, and fascia. Replace with new modified bitumen roof membrane and provide new metal gutters, downspouts, and fascia. New metal gutters and downspouts profile and dimensions to match that provided elsewhere in this project.

**ATTACHMENTS** *(List attached documents that support description):*

**REQUESTED BY THE ARCHITECT:**

  
*(Signature)*

Kevin J. Kinchen, Chief Architect  
*(Printed name and title)*