

NATCO

133 Commercial Square
Slidell, La 70461
Phone: 985-690-4189
Fax: 985-690-4969

REQUEST FOR INFORMATION

To: Chuck Dammon PROJECT: St Tammany Parish DATE: 12/11/2007
Administration Complex
Slidell, LA RFI #: VOLD 12

Subject Description	Spec. Sec. Ref.	Paragraph Ref.	Drawing Ref.	Detail	
RFP #4					
Cost Impact (if known)	Amount	Schedule Impact (if known)	Days	Drawing Impact	Completed

Information Requested: Received RFP #4, talked to Chuck Dammon and wanted to know if the Parish wanted to do the whole western property line or just the part with the house on Codifer. Please Clarify.

VOLD per Chuck

Christopher J. Lindley

(Print Name)

Signature: Christopher J. Lindley

Title: Superintendent

Suggestions:

Reply:

Reply by: _____
(Print Name)

Signature: _____

Date: _____

Title: _____

NATCO

Commercial Square
Slidell, La 70461
Phone: 985-690-4189
Fax: 985-690-4969

REQUEST FOR INFORMATION

To: PETE ~~Chris~~ Dammon PROJECT: St Tammany Parish DATE: 12/13/2007
Administration Complex
Slidell, LA RFI #: 12 Q

Subject Description	Spec. Sec. Ref.	Paragraph Ref.	Drawing Ref.	Detail	
Brick Lintel					
Cost Impact (if known)	Amount	Schedule Impact (if known)	Days	Drawing Impact	Completed
unk	unk				

Information Requested: The north entrance lobby has a 10'-10 1/2" corridor going around to the elevator. As per conversation earlier when this happens we have to demo the brick/block wall. In doing this there will not be any support of the brick/block wall above. As per our conversation we discussed that the alternative was to put a 1/2" groove in the mortar joint at 11'-0" +/- and install a 3"x3"x3/8" angle approximately 12" beyond the opening. Please Advise.

Christopher J. Lindley (Print Name) Signature: Christopher J. Lindley
Title: Superintendent

Suggestions:

Reply: THE DEMO & INSTALLATION OF THE ANGLE SHOULD BE MADE AS DESCRIBED ABOVE. IF THERE IS A PROPOSED ADDITIONAL FEE FOR THE ANGLE INSTALLATION, THAT SHOULD BE PART OF THE VAV SYSTEM PROPOSAL, AS THE VAV REQUIRES THE ADDITIONAL HEIGHT OF THE OPENING ABOVE THE DOOR, FOR DUCT WORK.

(NOTE: THIS IS THE BLOCK & BRICK WALL THAT IS THE SOUTHERN MOST WALL OF THE LEAN-TO SECTION OF THE EXISTING BUILDING. IT HAS A DOORWAY THAT HAS TO BE WIDENED FOR OUR NEW HALL & THE AREA ABOVE THE DOOR DEMOLISHED FOR ADDITIONAL ROOM TO ALLOW VAV DUCT WORK.

Reply by: PETE DAMMON (Print Name) Signature: Pete Dammon
Date: 12-14-07 Title: _____

NATCO

133 Commercial Square
Slidell, La 70461
Phone: 985-690-4189
Fax: 985-690-4969

REQUEST FOR INFORMATION

To: Chuck Dammon
PROJECT: St Tammany Parish
Administration Complex
Slidell, LA
DATE: 1/14/2008
RFI #: 12b

Subject Description	Spec. Sec. Ref.	Paragraph Ref.	Drawing Ref.	Detail	
Parking Lot Sub-base	Division 2				
Cost Impact (if known)	Amount	Schedule Impact (if known)	Days	Drawing Impact	Completed

Information Requested: We never received the Division 2 Specifications, therefore we don't have any information on what the sub-base needs to be. Please Advise.

Christopher J. Lindley
(Print Name)

Signature: *Christopher J. Lindley*

Title: Superintendent

Suggestions:

- Reply:
- Excavation for new parking lot. Excavate minimum of one foot., excavate any areas found to pump, & fill with sand clay mix. Compact to 95%, fill as required. Both parking lots shall receive 5", 4000# concrete.
 - The sprinkler system should be designed to automatically sprinkle the landscaping package as shown on the landscaping package. Provide freeze proof hose bib at each side of the Porte Cochere and one at each end of the building at front.
 - Pile Driving. A copy of the soils report is available at our office. No pile test is required. Provide a blow driving record for each pile. Any substitution of pile type or size shall be approved by this office and Gore Engineering, who provided the boring analysis. Composite piles are acceptable, attachments shall be submitted for approval.
 - Disinfection of water lines shall be to requirements of the city inspector.

Reply by: _____ (Print Name) Signature: _____

Date: _____ Title: _____