

SMH - Women's Imaging

Minimum Ventilation rate for VAV terminals Per IMC 2009, Tbl. 403.3

AHU #1

Vav #	Min. Ventilation	%Min CFM	
1,2,3	41.25	0.17	17 %
4	90	0.17	17 %
5	130	0.14	14 %
6	40	0.05	5 %

AHU #2

Vav #	Min. Ventilation	%Min CFM	
1,7	45	0.18	18 %
2	60	0.21	21 %
3	11	0.05	5 %
4	95	0.1	10 %
5	2	0.01	1 %
6	2	0.01	1 %

AHU #3

Vav #	Min. Ventilation	%Min CFM	
1	115	0.12	12 %
2	140	0.14	14 %
3	85	0.19	19 %