

Table 7.5
Station Outlets for Oxygen, Vacuum (Suction), and Medical Air Systems in Hospitals¹

Section	Location	Oxygen	Vacuum	Medical Air
7.2.A	Patient rooms (medical and surgical)	1/bed	1/bed	--
7.2.B10	Examination/treatment (medical, surgical, and postpartum care)	1/room	1/room	--
7.2.C/7.2.D	Isolation—infectious and protective (medical and surgical)	1/bed	1/bed	--
7.2.E	Security room (medical, surgical, and postpartum)	1/bed	1/bed	--
<u>7.3</u>	<u>Intermediate care</u>	<u>2/bed</u>	<u>2/bed</u>	<u>1/bed</u>
<u>7.34.A</u>	Critical care (general)	3/bed	3/bed	1/bed
<u>7.34.A14</u>	Isolation (critical)	3/bed	3/bed	1/bed
<u>7.34.B</u>	Coronary critical care	3/bed	2/bed	1/bed
<u>7.34.D</u>	Pediatric critical care	3/bed	3/bed	1/bed
<u>7.34.E</u>	Newborn intensive care	3/bassinet	3/bassinet	3/bassinet
<u>7.45.B</u>	Newborn nursery (full-term)	1 per 4 bassinets ²	1 per 4 bassinets ²	1 per 4 bassinets ²
<u>7.56.A</u>	Pediatric and adolescent	1/bed	1/bed	1/bed
<u>7.56.B</u>	Pediatric nursery	1/bassinet	1/bassinet	1/bassinet
<u>7.67.A</u>	Psychiatric patient rooms	--	--	--
<u>7.67.DC</u>	Seclusion treatment room	--	--	--
<u>7.79.AB1</u>	General operating room	2/room	3/room	--
<u>7.79.AB2</u>	Cardio, ortho, neurological	2/room	3/room	--
<u>7.79.AB3</u>	Orthopedic surgery	2/room	3/room	--
<u>7.79.AB4</u>	Surgical cysto and endo	1/room	3/room	--
<u>7.79.BC2</u>	Post-anesthesia care unit	1/bed	3/bed	1/bed
<u>7.79.CD9</u>	Anesthesia workroom	1 per workstation	--	1 per workstation
<u>7.79.CD14</u>	Phase II recovery ³	1/bed	3/bed	--

7.810.BA2.a	Postpartum bedroom	1/bed	1/bed	--
7.810.A3	Cesarean/delivery room	2/room	3/room	1/room
7.810.A3.c	Infant resuscitation station ⁴	1/bassinet	1/bassinet	1/bassinet
7.810.A3.d	Labor room	1/room	1/room	1/room
7.810.A3.e	OB recovery room	1/bed	3/bed	1/room
7.810.A4	Labor/delivery/recovery (LDR) ⁵	2 1/bed	2 1/bed	--
7.810.A4	Labor/delivery/recovery/ postpartum (LDRP) ⁵	2 1/bed	1 2/bed	--
7.911.C23	Initial emergency management	1/bed	1/bed	--
7.911.D3	Triage area (definitive emergency care)	1/station	1/station	--
7.911.D7	Definitive emergency care exam/treatment rooms	1/bed	1/bed	1/bed
7.911.D7	Definitive emergency care holding area	1/bed	1/bed	--
7.911.D8	Trauma/cardiac room(s)	2/bed	3/bed	1/bed
7.911.D9	Orthopedic and cast room	1/room	1/room	--
7.12E	MRI	1/room	1/room	1/room
7.129.H	Cardiac catheterization lab	2/bed	2/bed	2/bed
7.196.A2	Autopsy room	--	1 per workstation	--1 per workstation

¹For any area or room not described above, the facility clinical staff shall determine outlet requirements after consultation with the authority having jurisdiction.

²Four bassinets may share one outlet that is accessible to each bassinet.

³If Phase II recovery area is a separate area from the PACU, only one vacuum per bed or station shall be required.

⁴When infant resuscitation takes place in a room such as cesarean section/delivery or LDRP, then the infant resuscitation services must be provided in that room in addition to the minimum service required for the mother.

⁵~~Two outlets for mother and two for one bassinet.~~