

**GENERAL NOTES**


- PROVIDE POWER TO FIXTURES SHOWN FROM THE 141ST READINESS CENTER. ROUTE THROUGH LIGHTING CONTROLS.
- S3 AND S6 FIXTURES (AS SHOWN) ARE PART OF ALTERNATE 2A. REDUCE LIGHTS ACCORDINGLY.

**USED POLE ASSEMBLIES**

A2 = (4) EH19-Q-250 MH @ 33'  
 A4 = (2) EH19-Q-350 PSMH 180" APART @ 33'  
 A5 = (1) EH19-PA-350 PSMH  
 A11 = (1) EH19-S-350 PSMH

NOTE: ALL ASSEMBLIES USE TYPE S1 FIXTURES. SEE FIXTURE SCHEDULE.

1 ELECTRICAL SITE PLAN - LIGHTING AREA C PARKING  
 1" = 30'



© 2006 IMC 1474  
 CONSULTING ENGINEERS  
 INC.  
 3120 206 STREET  
 METAIRIE, LOUISIANA 70002

**BROADMOOR**  
 DESIGN GROUP  
 ARCHITECTS  
 2740 NORTH ARNOLD ROAD  
 METAIRIE, LOUISIANA 70002  
 (504) 885-5000

**BltchKnevel**  
 ARCHITECTS  
 757 ST. CHARLES AVENUE  
 NEW ORLEANS, LOUISIANA 70130  
 (504) 524-4834

LOUISIANA ARMY NATIONAL GUARD  
 141st FIELD ARTILLERY BATTALION  
 READINESS CENTER  
 JACKSON BARRACKS NEW ORLEANS, LOUISIANA



▲	2/22/06	PROG. REVIEW #1
▲	3/1/06	PROG. REVIEW #2
▲	3/27/06	PROG. REVIEW #3
▲	4/10/06	PROG. REVIEW #4
▲	5/3/06	PRELIM. DESIGN

MARK	DATE	DESCRIPTION
DRAWING ISSUED: 05/03/2006		

NOB PROJECT NO.: 220027

PRELIMINARY DESIGN

DRAWING TITLE:  
 ELECTRICAL SITE  
 LIGHTING AREA C  
 PARKING

DRAWING NUMBER:

E101  
 SHEET 76 OF 106

These drawings are conceptual in nature and are not suitable for construction. It is the intent of these documents to clearly delineate the baseline minimum scale, scope and quality of the project. It is the responsibility of the design-builder that his proposal provides for a complete and functional facility responding to relative Army National Guard criteria, recognized industry standards and applicable building codes regardless of the content of these conceptual drawings. Further, it will be the responsibility of the successful design-builder and his architect of record to prepare complete construction documents responding to the fullest intent of the conceptual drawings and specifications.