

Table C3-1 Minimum Design Dead Loads^a

Component	Load (psf)
CEILINGS	
Acoustical fiber board	1
Gypsum board (per 1/8-in. thickness)	0.55
Mechanical duct allowance	4
Plaster on tile or concrete	5
Plaster on wood lath	8
Suspended steel channel system	2
Suspended metal lath and cement plaster	15
Suspended metal lath and gypsum plaster	10
Wood furring suspension system	2.5
COVERINGS, ROOF, AND WALL	
Asbestos-cement shingles	4
Asphalt shingles	2
Cement tile	16
Clay tile (for mortar add 10 psf)	
Book tile, 2-in.	12
Book tile, 3-in.	20
Ludowici	10
Roman	12
Spanish	19
Composition:	
Three-ply ready roofing	1
Four-ply felt and gravel	5.5
Five-ply felt and gravel	6
Copper or tin	1
Corrugated asbestos-cement roofing	4
Deck, metal, 20 gage	2.5
Deck, metal, 18 gage	3
Decking, 2-in. wood (Douglas fir)	5
Decking, 3-in. wood (Douglas fir)	8
Fiberboard, 1/2-in.	0.75
Gypsum sheathing, 1/2-in.	2
Insulation, roof boards (per inch thickness)	
Cellular glass	0.7
Fibrous glass	1.1
Fiberboard	1.5
Perlite	0.8
Polystyrene foam	0.2
Urethane foam with skin	0.5
Plywood (per 1/8-in. thickness)	0.4
Rigid insulation, 1/2-in.	0.75
Skylight, metal frame, 3/8-in. wire glass	8
Slate, 3/16-in.	7
Slate, 1/4-in.	10
Waterproofing membranes:	
Bituminous, gravel-covered	5.5
Bituminous, smooth surface	1.5
Liquid applied	1
Single-ply, sheet	0.7
Wood sheathing (per inch thickness)	3
Wood shingles	3
FLOOR FILL	
Cinder concrete, per inch	9

Continued