



Designation: F 2073 – 001

## Standard Test Method for Non-Destructive Short Circuit Testing of a Membrane Switch<sup>1</sup>

This standard is issued under the fixed designation F 2073; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ε) indicates an editorial change since the last revision or reapproval.

### 1. Scope

1.1 This standard establishes a test method for detecting unwanted electrical shorts in a membrane switch.

1.2 Since this is a non-destructive test, it can be performed on a membrane switch that is going to be mounted and used in its intended environment.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

---

<sup>1</sup> This guide is under the jurisdiction of ASTM Committee F01 on Electronics and is the direct responsibility of Subcommittee F01.18 on Membrane Switches. Current edition approved ~~Dec.~~ June 10, 2000<sup>1</sup>. Published ~~February~~ August 2001. Originally published as F 2073–00. Last previous edition F 2073–00.

## 2. Referenced Documents

### 2.1 *ASTM Standards:*<sup>2</sup>

F 1680 Test Method for Determining the Circuit Resistance of a Membrane Switch

## 3. Terminology

### 3.1 *Definitions:*

3.1.1 *short*—unwanted electrical connection between two test points having a resistance lower ~~than, or equal to,~~ than the specified open circuit resistance.

3.1.2 *membrane switch*—a momentary switching device in which at least one contact is on, or made of, a flexible substrate.

3.1.3 *open circuit resistance*—minimum allowable resistance as measured between two test points that, if lower than, will indicate an electrical short.

3.1.4 *test point*—an electrical input or outpoint connection on the membrane switch.

## 4. Significance and Use

4.1 Destructive and non-destructive tests characteristics must be evaluated to ensure the membrane switch will operate and survive the application it was designed for. It is not feasible for all tests to be performed on each membrane of a production lot. However, there are some non-destructive tests that must be performed on each switch assembly to ensure 100 % functionality and checking each i/o point for unwanted electrical continuity to any other i/o point is one of these characteristics.

~~4.2 Since this is a non-destructive test the applied voltage should not exceed operating voltage.~~

## 5. Apparatus

5.1 *Electrical Tester*, capable of measuring the electrical resistance between two test points.

5.1.1 Electrical Tester must be capable of detecting a short when a resistance is measured between any of the test points that ~~fall below~~ is less than an open circuit resistance.

~~5.1.2 Since this is a non-destructive test the applied voltage should not exceed operating voltage selected appropriately.~~

## 6. Procedure

### 6.1 *Pretest Setup:*

6.1.1 Connect ~~all~~ test points of the switch assembly to the Electrical Tester.

6.1.2 Adjust test voltage source as necessary.

6.1.3 Adjust threshold resistance to the open circuit resistance.

### 6.2 *In-Process Test:*

~~6.2.1 Adjust voltage source to specified voltage.~~

~~6.2.2 Adjust threshold resistance to the open circuit resistance.~~

### 6.2.3 *Test*

6.2.1 Test first test point for shorts between all other test points and record results.

6.2.4<sub>2</sub> Test second test point for shorts between all other test points and record results.

6.2.5<sub>3</sub> Repeat until all test points are checked between all other test points.

## 7. Report

7.1 Report the following information:

7.1.1 Specified Voltage,

7.1.2 Specified shorts resistance,

7.1.3 Shorts found,

7.1.4 Test points associated with each short, and

7.1.5 Resistance value of each short.

## 8. Keywords

8.1 electrical short; insulation resistance; membrane switch; open circuit; resistance; short circuit; switch short

<sup>2</sup> For referenced ASTM standards, visit the ASTM website, [www.astm.org](http://www.astm.org), or contact ASTM Customer Service at [service@astm.org](mailto:service@astm.org). For *Annual Book of ASTM Standards*, Vol 10.05, volume information, refer to the standard's Document Summary page on the ASTM website.

*ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.*

*This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.*

*This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or [service@astm.org](mailto:service@astm.org) (e-mail); or through the ASTM website ([www.astm.org](http://www.astm.org)).*