



SECTION VIEW

WIDTH (W)	DEPTH (D)	BACKER MATERIAL (DIAMETER)	MINIMUM DEPTH TO REMOVE INCOMPRESSIBLES
3/8" - 1"	1/2"	W + 25%	T/2
1" - 2"	W/2	W + 25%	T

NOTES:

- Hot poured sealant shall conform to section 602.05 of the Standard Specifications.
- Backer material shall consist of heat resistant, closed-cell, cross-linked polyethylene or polyolefin foam.
- All work on this detail to be paid for under item labeled:
Cleaning and resealing existing longitudinal pavement joints.
- Detail not to scale.

ROAD DESIGN		CLEANING AND RESEALING EXISTING LONGITUDINAL JOINTS		DESIGNED CHECKED	BCT MAC	PARISH		SHEET NO.
		CPR-02		DETAILED CHECKED	BCT MAC	CONTROL SECTION		
		NO.	DATE	REVISION DESCRIPTION	BY	DATE SHEET	03-03-11 1 OF 1	