

separate booster heater.) However, it is emphasized that this does not imply that all water used would be at this temperature. Water temperatures required for acceptable laundry results will vary according to type of cycle, time of operation, and formula of soap and bleach as well as type and degree of soil. Lower temperatures may be adequate for most procedures in many facilities but higher temperatures should be available when needed for special conditions. Minimum laundry temperatures are for central laundries only.

**Table 2.5-2****Minimum Maintained Average Illuminance**

	Ambient Light in		Task Light in	
	Lux	Foot-candles	Lux	Foot-candles
Exterior entrance (night)	100	10		
Interior entry (day)	1000	100		
Interior entry (night)	100	10		
Exit stairways and landings	300	30		
Elevator interiors	300	30		
Exterior walkways	50	5		
Administration (active hours)	300	30	500	50
Active areas (day only)	300	30	500	50
Visitor waiting (day)	300	30		
Visitor waiting (night)	100	10		
Resident room/dwelling unit				
Entrance	300	30		
Living room	300	30	750	75
Bedroom	300	30	750	75
Wardrobe/closet	300	30		
Bathroom	300	30		
Makeup/shaving area	300	30	600	60
Shower/bathing rooms	300	30		
Kitchen area	300	30	500	50
Hair salon (day)	500	50		
Chapel or quiet area (active hours)	300	30		
Hallways (active hours)	300	30		
Hallways (sleeping hours)	100	10		
Dining (active hours)	500	50		
Medicine preparation	300	30	1000	100
Nurse station (day)	300	30	500	50
Nurse station (night)	100	10	500	50
Physical therapy area (active hours)	300	30	500	50
Occupational therapy area (active hours)	300	30	500	50
Examination room (dedicated)	300	30	1000	100
Janitor's closet (environmental services room)	300	30		

*(Continued)*