

**MWFRS Wind Load Calculations**  
**ASCE 7-10 Chapter 29 Wind Loads on Other Structures and Building**  
**Appurtenances - MWFRS**

Design Wind Loads -- Solid Freestanding Walls and Solid Signs

Project: SLVHCS REPLACEMENT MEDICAL 629-HS2-401

Sign Height z = 10 feet  
 Sign Width B = 10 feet  
 Sign Height S = 10 feet

1. Risk Category Table 1.5-1	Cat I
2. Basic Wind Speed, by website at council.org	133 mph
3. Wind load parameters	
a. Surface Roughness, Section 26.7.2:	Roughness B
b. Wind directionality Factor, Sec 26.6	$K_d = 0.85$
c. Exposure Category, Section 26.7.3:	Exposure B
d. Topographic Factor, Section 26.8.2:	$K_{zt} = 1$
e. Gust Effect, Section 26.9	Rigid G = 0.85
f. Terrain Exposure Constants, Tbl 26.9-1	$\alpha = 7.0$ $z_g$ (ft) = 1200
g. Enclosure classification, Sec 26.10	Enclosed
h. Velocity Pressure Coefficient, Tbl 29.3-1	$K_h = 0.90$ $K_z = 2.01(z/z_g)^{(2/\alpha)}$
	$K_z = 0.51$
f. Velocity Pressure, Section 29.3.2	$q_z = 0.00256 K_z K_{zt} K_d V^2$ ( $lb/ft^2$ )
	$q_z = 19.7$
h. Net Force Coefficient, Fig 29.4-1 (See Elevation View Top Left Corner)	$s/z = 1$ $B/s = 1$ $C_f = 1.45$
4. Design Wind Force, Section 29.4.1	$F = q_h G C_f A_s$ (lb)
	$F = 2428 \text{ lbs or } 24.3 \text{ } lb/ft^2$

Prepared by: David Dammon

Date: 1/4/2015

Supplied data  
 Calculated