

Table 9.2
Station Outlets for Oxygen, Vacuum, and Medical Air in Outpatient Facilities

Section	Location	Oxygen	Vacuum	Medical Air
9.2.B1 & B2	Examination	0	0	--
9.2.B3	Treatment	0	0	--
9.2.B11	Isolation	0*	0*	--
9.5.F1	Pre-procedure examination	0*	0*	--
	Operating room			
9.5.F2.b	Class A—minor surgical procedure room	1	1	--
9.5.F2.c	Class B—intermediate surgical procedure room	2	2	--
9.5.F2.d	Class C—major surgical procedure room	2	3	--
9.5.F3	Post-anesthesia recovery	1	1	--
9.5.F4	Step down recovery area	0*	0*	--
--	Cysto procedure	1	3	--
	Emergency			
9.6.E1	Trauma/cardiac room	1	1	1
--	Cast room	0*	0*	--
--	Catheterization room	1	2	2
9.7.C1	Birthing room	2	2	--
	Endoscopy			
9.9.A3	Procedure room	<u>2</u>	3	--
9.9.B2f	Decontamination room	--	--	--
9.9.B3	Holding/prep/recovery area	0*	0*	--

*Portable or hard-piped source should be available for the space.