



Standard Practice for Calculating the Superimposed Load on Wood-frame Walls for Standard Fire-Endurance Tests¹

This standard is issued under the fixed designation D 6513; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice covers procedures for calculating the superimposed axial load required to be applied to load-bearing wood-frame walls throughout standard fire-endurance and fire and hose-stream tests.

1.2 The calculations determine the maximum load allowed by design for wood-frame wall assemblies under nationally recognized structural design criteria.

1.3 This practice is only applicable to those wood-frame assemblies for which the nationally recognized structural design criteria is the *National Design Specification for Wood Construction (NDS)*.²

1.4 The system of units to be used is that of the nationally recognized structural design criteria. For the NDS, the units are inch-pound.

1.5 The text of this standard references notes and footnotes which provide explanatory material. These notes and footnotes (excluding those in tables and figures) shall not be considered as requirements of the standard.

1.6 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:

D 9 Terminology Relating to Wood³

E 119 Test Methods for Fire Tests of Building Construction and Materials⁴

E 176 Terminology Relating to Fire Standards⁴

E 1529 Test Methods for Determining Effects of Large Hydrocarbon Pool Fires on Structural Members and Assemblies⁴

2.2 Other Standards:

NDS—National Design Specification for Wood Construction²

NDS Supplement—Design Values for Wood Construction²

3. Terminology

3.1 *Definitions*—Definitions used in this practice are in accordance with Terminology D 9 and Terminology E 176, unless otherwise indicated.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *gross area, n*—section area calculated from overall actual dimensions of member.

3.2.2 *net section area, n*—section area calculated by deducting from the gross section area the projected area of all materials removed by boring, grooving, dapping, notching, or other means.

3.2.3 *superimposed load, n*—The additional external load needed to be applied to the assembly to result in the calculated stresses within the assembly when any dead load of the assembly itself is accounted for in the calculations.

4. Significance and Use

4.1 Test Methods E 119 and E 1529, and other standard fire endurance test methods specify that throughout exposures to fire and the hose stream, a constant superimposed axial load be applied to a load-bearing test specimen to simulate a maximum load condition. They specify that this superimposed load shall be as nearly as practicable the maximum load allowed by design under nationally recognized structural design criteria. For this practice, the nationally recognized structural design criteria is the *National Design Specification for Wood Construction (NDS)*.

4.1.1 Alternatively, the standard fire endurance test methods shall be conducted by applying an axial load that is less than the maximum allowable axial load as addressed by the NDS and this practice, but these tests shall be identified in the test report as being conducted under restricted load conditions. The superimposed axial load, as well as the superimposed axial load as a percentage of the maximum allowable axial design load as addressed by the NDS and this practice shall be included in the test report.

¹ This practice is under the jurisdiction of ASTM Committee D-7 on Wood and is the direct responsibility of Subcommittee D07.07 on Fire Performance of Wood Products.

Current edition approved Feb. 10, 2000. Published April 2000.

² Available from American Forest & Paper Association, American Wood Council, 1111 19th Street, NW, Suite 800, Washington, DC 20036

³ *Annual Book of ASTM Standards*, Vol 04.10.

⁴ *Annual Book of ASTM Standards*, Vol 04.07.

4.2 This practice describes procedures for calculating the superimposed axial load to be applied in standard fire endurance tests of wood-frame wall assemblies.

4.3 Statements in either the fire endurance test method standard or the nationally recognized structural design standard supercede any procedures described by this practice.

4.4 The NDS shall be consulted to ensure calculations are in compliance with all applicable provisions of that document.

5. Test Assumptions

5.1 Wood-frame walls consist of vertical compression members and horizontal plates.

5.1.1 Compression members support a vertical axial load.

5.1.2 Bearing ends of the compression members are supported by the horizontal plates.

5.2 *Load:*

5.2.1 The test load is determined from the vertical axial capacity of the wall.

5.2.2 The test load calculations are based on standard design conditions including normal load duration, that is, ten years load duration.

5.3 *Dimensions:*

5.3.1 Gross cross-sectional areas are the section areas based on the standard dressed size of the member as given in the NDS for the nominal size member.

5.3.1.1 Net section area, A , is the gross area minus the projected area of all materials removed by boring, grooving, dapping, notching, or other means.

5.3.1.2 For nailed connections, the net section area equals the gross section area.

5.3.2 Height of vertical columns is the actual length of the vertical member.

6. Design Load Calculations

6.1 For structural sawn lumber, tabulated design values for the grade and species of lumber are multiplied by all applicable adjustment factors to determine the allowable design values.

6.1.1 Tabulated design values $F_{C\perp}$, F_C , and E are given in the separate Supplement to the NDS.

6.1.2 Compression perpendicular to grain, $F_{C\perp}$, is multiplied by C_M , C_t , C_i and C_b .

6.1.3 Compression parallel to the grain, F_C , is multiplied by C_D , C_M , C_p , C_F , C_i , and C_P .

6.1.4 Modulus of elasticity, E , is multiplied by C_M , C_t , C_i , and C_T .

6.2 *Adjustment Factors for Design Values:*

6.2.1 If values less than those listed in this section (6.2) are used for the adjustment factors, the appropriate load restriction shall be reported in the test report.

6.2.2 Load duration factor, C_D , is 1.0.

6.2.3 Wet service factor, C_M , is 1.0.

6.2.4 Temperature factor, C_t , is 1.0.

6.2.5 Size factor, C_P , is taken from tables in the NDS.

6.2.5.1 Size factor for F_C and the appropriate table within NDS depends on the width, species, and grade of the lumber.

6.2.6 Incising factor, C_i , is 1.0.

6.2.7 Column stability factor, C_P .

6.2.7.1 Buckling of compression member in plane of wall is prevented by the sheathing which normally provides support throughout its length and C_P equals 1.

6.2.7.2 For buckling of compression member perpendicular to plane of wall, C_P depends on the slenderness ratio of the columns. The equation for C_P is given in the NDS. The effective column length shall be the actual length of the vertical member for calculating the slenderness ratio and C_P .

6.2.8 Buckling stiffness factor, C_T , is 1.0.

6.2.9 Bearing area factor, C_b , is 1.0.

NOTE 1—The NDS provides for a bearing area factor of 1.25 for a bearing length of 1.5 in. when the bearings are not nearer than 3 in. to the end of a member. Due to the random layout of platform framing, the location of butt joints in top and bottom plates cannot be specified. For this reason, the bearing area increase is not generally taken in the design of wood frame walls. Historically, a bearing area factor of one has been used in the calculations of the load for fire endurance tests of wood-frame walls.

6.2.10 For lumber and structural-glued laminated timber pressure-treated with fire-retardant chemicals, the allowable design values, including connection design values, shall be obtained from the company providing the treatment and redrying service.

6.2.11 For load duration factor, C_D , equal to 1.0, there is no additional reduction for wood products pressure treated by an approved process and preservative.

6.3 For vertical compression members of simple solid wood columns, the load per vertical compression member is the maximum superimposed load that satisfies the following:

6.3.1 Actual compression stress parallel to grain based on minimum net section area does not exceed the tabulated compression design value parallel to grain multiplied by all applicable adjustment factors except the column stability factor, C_P .

6.3.2 Actual compression stress parallel to grain based on gross section area at critical part of column length that is most subject to potential buckling of compression member perpendicular to plane of wall does not exceed the allowable compression design value parallel to grain (that is, tabulated design value multiplied by all applicable adjustment factors).

6.3.3 Actual compression stress perpendicular to grain in horizontal plates does not exceed the allowable compression design value perpendicular to grain which includes the adjustment factor for bearing area, C_b , and the other applicable adjustment factors.

6.4 Actual stress in a member in 6.3 includes both that due to the superimposed load applied to the assembly and that due to the dead load or weight of the components being supported by the member.

6.5 Total superimposed load to be applied to the test assembly during the fire test is the sum of the maximum superimposed load of each of the vertical compression members in the assembly.

7. Keywords

7.1 fire endurance; fire resistance; superimposed load; wall assembly; wood studs

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org).