



Standard Practice for Integrity Testing of Water Filtration Membrane Systems¹

This standard is issued under the fixed designation D 6908; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last approval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This standard covers the determination of the integrity of water filtration membrane elements and systems using air based tests (pressure decay and vacuum hold), soluble dye, and TOC monitoring tests for the purpose of rejecting particles and microbes. The tests are applicable to systems with membranes that have a nominal pore size less than about 1 μm . The TOC and Dye tests are generally applicable to NF and RO class membranes only.

1.2 This standard does not purport to cover all available methods of integrity testing.

1.3 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety and health practices and determine the applicability of regulatory limitations prior to use.*

2. Referenced Documents

2.1 ASTM Standards:

- D 1129 Terminology Relating to Water²
- D 2777 Determination of Precision and Bias of Applicable Tests Methods of Committee D19 on Water²
- D 3370 Practices for Sampling Water from Closed Conduits²
- D 3923 Practice for the Determination of Leaks Within a Reverse Osmosis Device³
- D 4839 Total Carbon and Organic Carbon in Water by Ultraviolet, or Persulfate Oxidation, or Both, and Infrared Detection³
- D 5173 On-Line Monitoring of Carbon Compounds in Water by Chemical Oxidation, by UV Light Oxidation, by Both, or by High Temperature Combustion Followed by Gas Phase NDIR or by Electrolytic Conductivity²
- D 5904 Total Carbon, Inorganic Carbon and Organic Carbon in Water by Ultraviolet, Persulfate Oxidation and Membrane Conductivity Detection³
- D 5997 On-Line Monitoring of Total Carbon, Inorganic Carbon in Water by Ultraviolet, Persulfate Oxidation, and

Membrane Conductivity Detection²

D 6161 Terminology Used for Crossflow Microfiltration, Ultrafiltration, Nanofiltration and Reverse Osmosis Membrane Processes³

E 128 Maximum Pore Diameter and Permeability of Rigid Porous Filters for Laboratory Use⁴

3. Terminology

3.1 *Definitions*—For definitions of terms used in this practice, refer to Terminologies D 6161 and D 1129.

3.1.1 For description of terms relating to cross flow membrane systems, refer to Terminology D 6161.

3.1.2 For definition of terms relating to dissolved carbon and carbon analyzers, refer to D 5173, D 5904 and D 5997.

3.1.3 *bubble point*—when the pores of a membrane are filled with liquid and air pressure is applied to one side of the membrane, surface tension prevents the liquid in the pores from being blown out by air pressure below a minimum pressure known as the bubble point.

3.1.4 *equivalent diameter*—the diameter of a pore or defect calculated from its bubble point using Eq 1 (see 9.3). This is not necessarily the same as the physical dimensions of the defect(s).

3.1.5 *integrity*—measure of the degree to which a membrane system rejects particles of interest. Usually expressed as a log reduction value (LRV).

3.1.6 *log reduction value (LRV)*—a measure of the particle removal efficiency of the membrane system expressed as the log of the ratio of the particle concentration in the untreated and treated fluid. For example, a 10-fold reduction in particle concentration is an LRV of 1.

3.1.7 *membrane system*—refers to the membrane hardware installation including the membrane, membrane housings, interconnecting plumbing, seals and valves. The membrane can be any membrane with a pore size less than about 1 μm .

4. Significance and Use

4.1 The integrity test methods described are used to determine the integrity of membrane systems, and are applicable to systems containing membrane module configurations of both hollow fiber and flat sheet; such as, spiral-wound configuration. In all cases the practices apply to membranes in the RO, NF,

¹ This practice is under the jurisdiction of ASTM Committee D19 on Water and is the direct responsibility of Subcommittee D19.08 on Membranes and Ion Exchange Materials.

Current edition approved April 10, 2003. Published June 2003.

² *Annual Book of ASTM Standards*, Vol 11.01.

³ *Annual Book of ASTM Standards*, Vol 11.02.

⁴ *Annual Book of ASTM Standards*, Vol 14.02.

and UF membrane classes. However, the TOC and Dye Test practices do not apply to membranes in the MF range or the upper end of the UF pore size range (0.01 μm and larger pore sizes) due to insignificant or inconsistent removal of TOC material by these membranes.

4.2 These methods may be used to identify relative changes in the integrity of a system, or used in conjunction with the equations described in 9.4, to provide a means of estimating the integrity in terms of log reduction value. For critical applications, estimated log reductions using these equations should be confirmed by experiment for the particular membrane and system configuration used.

4.3 The ability of the methods to detect any given defect is affected by the size of the system or portion of the system tested. Selecting smaller portions of the system to test will increase the sensitivity of the test to defects. When determining the size that can be tested as a discrete unit, use the guidelines supplied by the system manufacturer or the general guidelines provided in this standard.

4.4 The applicability of the tests is largely independent of system size when measured in terms of the impact of defects on the treated water quality (that is, the system LRV). This is

because the bypass flow from any given defect is diluted in proportion to the systems total flowrate. For example, a 10-module system with a single defect will produce the same water quality as a 100-module system with ten of the same size defects.

5. Reagents and Materials

5.1 *Reagents*—As specified for the TOC analyzer in question. D 5173 lists requirements for a variety of instruments.

5.2 *Soluble Dye Solution*—Use FD&C or reagent grade dyes such as FD&C Red #40, dissolved in RO permeate, or in ASTM Reagent Grade Type IV water.

6. Precision and Bias

6.1 Neither precision nor bias data can be obtained for these test methods because they are composed of continuous determinations specific to the equipment being tested. No suitable means has been found of performing a collaborative study to meet the requirements of Practice D 2777. The inability to obtain precision and bias data for methods involving continuous sampling or measurement of specific properties is recognized and stated in the scope of Practice D 2777.

PRACTICE A—PRESSURE DECAY AND VACUUM DECAY TESTS

7. Scope

7.1 This practice covers the determination of integrity for membrane systems using the pressure decay test (PDT) and vacuum decay test (VDT).

7.2 The tests may be used on membranes in all classes, RO through MF, and are suitable for hollow fibers, tubular and flat sheet (such as spiral wound) configurations. However, the PDT is most commonly employed for in-situ testing of UF and MF systems and the VDT for testing NF and RO elements and systems. See Practice D 3923.

8. Summary of Practice

8.1 *Principles*—The tests work on the principle that if air pressure is applied to one side of an integral, fully wet membrane at a pressure below the membrane bubble point, there will be no airflow through the membrane other than by diffusion through liquid in the membrane wall. If a defect or leak is present then air will flow freely at this point, providing that the size of the defect is such that it has a bubble point pressure below the applied test pressure.

8.1.1 Air based tests are means of applying air, at a pressure below the membrane bubble point, to one side of a wet membrane and measuring the air flow from one side to the other. Air flow can be measured directly, but more commonly, it is derived from pressure or vacuum decay. In the PDT air flow is measured as the rate of pressure decay when one side of a membrane system (either the feed or filtrate side) is isolated and pressurized with air. In the VDT an air pressure differential is generated by isolating one side of a wet membrane and applying a partial vacuum with atmospheric pressure on the other side. Air flow is measured as the rate of vacuum

decay on the isolated side of the membrane. The results of both the PDT and VDT are a direct measure of the membrane system integrity.

8.2 *Limitations and Applications*—The tests are limited to monitoring and control of defects greater than about 1 to 2 μm (see 9.3, Selection of Test Pressure).

8.2.1 The tests can be applied in various forms provided a differential pressure below the bubble point is established across a wet membrane with air on the relative high pressure side of the membrane. Some examples are included in Fig. 1.

8.2.2 Both the PDT and VDT are described here in their most common forms. In the case of the PDT this is with one side of the membrane pressurized with air and the other filled with liquid vented to atmosphere. In the case of the VDT, air is typically present on both sides and vacuum is applied to the permeate side.


9. Procedure

9.1 *Pressure Decay Test (PDT)*—The pressure decay test can be carried out by pressurizing either side of the membrane (see Fig. 1). For complete wet-out of all the membrane in the system, the system should be operated at its normal pressure before the test is performed. The steps involved in the PDT are:

9.1.1 Drain the liquid from the side of the membrane to be pressurized (referred to here as the upstream side).

9.1.2 Open the downstream side of the membrane system to atmosphere. This ensures air that leaks or diffuses is free to escape without creating backpressure, and establishes the downstream pressure as atmospheric pressure.

9.1.3 Isolate and pressurize the upstream side with air to the test pressure. Then isolate the air supply. Do not exceed the test pressure as this could lead to blowing out smaller pores than



—————→ Normal water permeation direction
 - - - - - → Air leaking direction

NOTE—The last example also represents the vacuum decay test when a partial vacuum is applied to one side of the membrane.
FIG. 1 Various Configurations for the Pressure Decay Test

intended resulting in a higher PDT. Record this pressure as $P_{test,max}$, the maximum test pressure.

9.1.4 After allowing time for the decay rate to stabilize record the initial pressure, P_i , and commence timer.⁵

9.1.5 After at least 2 min, record the final pressure, P_f , and the time taken for the pressure to decay from P_i to P_f (t). The time period can be extended in order obtain a more accurate result if the pressure decay rate is slow.⁶

9.1.6 Calculate the Pressure Decay Rate (PDR) as follows and record the result along with the test conditions (temperature, average test pressure $P_{test,avg}$ and maximum pressure $P_{test,max}$):

$$PDR_{measured} = \frac{P_i - P_f}{t}$$

where:

$PDR_{measured}$ = measured pressure decay rate, kPa/min at the average test pressure, $P_{test,ave} = P_i + P_f / 2$,

P_i = initial pressure, kPa gauge,

P_f = final pressure, kPa gauge,

t = time taken for pressure to decay from P_i to P_f , mins, and

$P_{test,max}$ = maximum test pressure given as the pressure at the start of the test, kPa.

9.1.7 The PDR will result from diffusion through the membrane wall, as well as leaks through defects, damaged membranes, or seals. The diffusive component of the airflow is not related to the integrity, so a more accurate estimate of the nondiffusive pressure decay can be obtained by subtracting the

diffusive flow from the measured flow. The diffusive component can be estimated either by calculation or experimental determination of the diffusive flow, such as laboratory measurements or by measuring the PDR on a system confirmed suitably integral by other means. In such cases, the measured PDR result is corrected as follows:

$$PDR_{corrected} = PDR_{measured} - PDR_{diffusion}$$

where:

$PDR_{diffusion}$ = $PDR_{measured}$ for the integral system, at the same P_{Test} and temperature.

9.1.8 For most practical applications of the test sufficient accuracy can be obtained by taking the conservative approach and assuming that all the pressure decay is related entirely to leaks ($PDR_{diffusion} = 0$).

9.2 *Vacuum Decay Test*—The VDT is conducted with air on both sides of the membrane. For complete wet-out of all the membrane in the system, the system should be operated at its normal pressure before the test is performed. The steps involved in the VDT are:

9.2.1 Drain the liquid from the feed side of the membrane (referred to here as the upstream side), and let it remain open to the atmosphere. For membrane devices placed horizontally, the feed and exit ports must be located on the bottom of the device housings in order for this to work.

9.2.2 Use the equipment connected in this order (see Fig. 2): a vacuum pressure gauge, an isolation valve, a water trap that will not buckle at vacuum, and a vacuum pump, to the permeate manifold that serves one or more membrane devices. Addition of another isolation valve (B) at the permeate header allows easy connection of the equipment without disrupting operation of the membrane system.

9.2.3 Open isolation valves A and B and run the vacuum pump to evacuate the permeate side until the pressure gauge shows a stable vacuum. The water removed during this operation is collected in the water trap. Close isolation valve A.

⁵ The pressure decay rate at the start of the test is usually quite high due to displacement of some of the liquid in the membrane wall. The time taken for the decay rate to stabilize will be different for different systems, but may take up to 3 min.

⁶ Due to the nonlinear decay in pressure with time and the desire to simplify the equations by using the first order approximation for decay rate, the maximum time should be such that P_f is no more than 10 % lower than P_i .




FIG. 2 Connection Arrangement for the VDT

Start the stopwatch and record the initial vacuum (P_i). The test vacuum can be selected using the guidelines in 9.3.

9.2.4 After the determined time (60 s is a typical time, 120, 180 or 300 s will yield a more sensitive test) record the final pressure (P_f) and the time (t) for reaching this value.⁶

9.2.5 Calculate the Vacuum Decay Rate (VDR) as follows:

$$VDR_{measured} = \frac{P_f - P_i}{t}$$

where:

$VDR_{measured}$ = measured vacuum decay rate, kPa/min at the average test pressure, $P_{test,ave} = P_i + P_f / 2$,

P_i = initial vacuum, kPa gauge,

P_f = final vacuum, kPa gauge,

t = time taken for vacuum to decay from P_i to P_f mins, and

$P_{test,max}$ = maximum test vacuum given as the pressure at the start of the test, kPa.

9.2.6 The VDR will result from diffusion through the membrane wall, as well as leaks through defects, damaged membranes, or seals. The diffusive component of the airflow is not related to the integrity, so a more accurate estimate of the nondiffusive vacuum decay can be obtained by subtracting the diffusive flow from the measured flow. The diffusive component can be estimated either by calculation or experimental determination of the diffusive flow, such as laboratory measurements or by measuring the VDR on a system confirmed suitably integral by other means. In such cases, the measured VDR result is corrected as follows:

$$VDR_{corrected} = VDR_{measured} - VDR_{diffusion}$$

where:

$VDR_{diffusion}$ = $VDR_{measured}$ for the integral system, at the same P_{test} and temperature.

If $VDR_{diffusion}$ is unknown, the conservative approach is to set $VDR_{diffusion} = 0$.

9.3 Selection of Test Pressure—The test pressure selected determines the minimum equivalent diameter of a defect that

can contribute to the pressure or vacuum decay rate. The relationship between the test pressure and the equivalent defect diameter is given by Eq 1. Defects smaller than this will be too small for the bubble point to be overcome and thus will not contribute to airflow. Larger defects will allow airflow as the bubble point will be exceeded by the applied test pressure. Details on the derivation of this equation and its use in determining maximum pore size for membranes can be found in Method E 128.⁷

$$d = \frac{4\gamma \cos\theta}{\Delta P_{test,max}} \quad (1)$$

where:

$\Delta P_{test,max}$ = the maximum differential test pressure applied across the membrane. This is the $P_{test,max}$ recorded during the test corrected for any static head contribution,

γ = surface tension at the air-liquid interface,

θ = liquid-membrane contact angle, and


d = equivalent diameter of the smallest defect included in the test.

9.3.1 For the theoretical case of a perfectly hydrophilic membrane, the contact angle is zero, and assuming water at 25°C (surface tension 72 dynes/cm), Eq 1 simplifies to Eq 2, with d in micrometres and $P_{test,max}$ in kilopascal:

$$d = \frac{288}{\Delta P_{test,max}} \quad (2)$$

9.3.2 Fig. 3 shows the relationship between test pressure and equivalent defect diameter expressed by Eq 1 and assuming a surface tension of 72 dynes/cm. The solid line represents Eq 2; that is, the conservative situation of $\cos\theta = 1$. In practice most membranes used in water treatment have a contact angle

⁷ Eq 1 is often modified to include a correction factor referred to as the pore shape factor or the Bechold Constant. This is a value < 1 and takes into account the irregular shape of membrane pores. For the purpose of this practice the shape factor is assumed to be 1 as this is the most conservative position, and the shape of any particular defect detected by these tests is not known.



NOTE—The solid line represents Eq 2.

FIG. 3 The Relationship Between Test Pressure and Equivalent Defect Diameter (Eq 1, Water at 25°C)

greater than zero, which is represented by the shaded region under the solid line in Fig. 3. If the contact angle is known or can be determined, Eq 1 may be used. However, if the contact angle is not known, a conservative estimate of the test pressure required can be made by applying Eq 2.

9.3.3 The test pressure is usually selected to ensure that the minimum defect diameter picked up by the test is smaller than contaminates or particles of interest. For example, Eq 2 indicates that a test pressure of 100 kPa would include all defects larger than or equal to 3 μm. A lower pressure could be used for less hydrophilic membranes. For example, if the contact angle is 60 degrees (typical for polypropylene, polysulfone, or PVdF) Eq 1 indicates that defects of 3 μm would be included at a test pressure of 50 kPa. An even lower test pressure may be used for larger defects, such as for example detection of broken fibers in a hollow fiber system.

9.3.4 In practice the applied test pressure is rarely more than 300 kPa, which is usually sufficient to include defects smaller than most pathogens of interest. At this pressure limit the test is not suitable for direct validation of virus rejection as these particles are very small (typically less than 0.01 μm) with a corresponding test pressure of several thousand kilopascals.

9.4 Interpreting PDR and VDR Results as Log Reduction Values—Both the PDR and the VDR are measurements of the airflow from one side of the membrane to the other under a known set of test conditions (temperature and pressure). This information can be used to estimate the flow of liquid through the same defects during filtration conditions. This provides an estimate of the membrane bypass flow and thereby an estimate of the log removal of particles for the system. One approach is based on the Hagen-Poiseuille law, which assumes laminar flow through cylindrical defects. Whilst this method provides a useful estimate, its applicability is limited to small fibers (< 400 μm ID) where the criteria for laminar flow are more closely approximated. The method is described in 9.4.1 and a detailed

derivation, along with the assumptions required, is contained in Appendix X1. An alternative method is to experimentally measure the relationship between liquid and air flows for the worst case failure mode. This is typically a broken fiber at the pot for most hollow fiber MF or UF systems. This approach, described in 9.4.3, assumes that all the measured gas flow is due to “worst case” failures and so provides a conservative estimate of bypass flow and LRV for the system. While these approaches have been applied in practice, data covering a range of different membrane configurations, test conditions, and fiber diameters are not yet available. Regardless of the chosen method the relationship between integrity test results and LRV should be verified by experiment in the field on the particular membrane and configuration used.

9.4.1 The Laminar Flow Approach Using the Hagen-Poiseuille (H-P) Law—This approach assumes laminar flow through cylindrical defects and is most suitable for small diameter fibers (200 to 400 μm lumen diameter). A detailed derivation along with key assumptions is contained in Appendix X1. The equations required to convert the PDR and VDR results obtained using the method described here to a log reduction value, are given below as Eq 3 and 4 respectively:

For PDR:

$$LRV_e = \log_{10} \left(\frac{Q_{filt} P_{atm}}{CF \cdot PDT \cdot V_{system}} f_1 f_2 \right) \quad (3)$$

and for VDR:

$$LRV_e = \log_{10} \left(\frac{Q_{filt} P_{atm}}{CF \cdot VDT \cdot V_{system}} f_1 f_2 \right) \quad (4)$$

where:

- f_1 = viscosity correction factor = μ_{water} / μ_{air}
- f_2 = pressure correction factor = $P_{u,test}^2 - P_{d,test}^2 / 2P_{atm} TMP$,
- Q_{filt} = filtrate flowrate (m³/s),

$P_{u,test}$	= upstream pressure during the PDT or VDT = $P_{test,avg}$ for PDT and P_{atm} for VDT, (kPa absolute),
$P_{d,test}$	= downstream pressure during the PDT or VDT = P_{atm} for PDT and $P_{test,avg}$ for VDT, (kPa absolute),
P_{atm}	= atmospheric pressure (kPa absolute),
CF	= concentration factor. This represents the increase in the contaminant concentration that could occur on the upstream side of the membrane relative to the feed water concentration due to the operating mode. This would typically be equal to 1 for dead-end systems, but could be higher for cross flow or feed and bleed modes,
PDR	= pressure decay rate (kPa/s),
VDR	= vacuum decay rate (kPa/s),
TMP	= transmembrane pressure during filtration (kPa),
V_{system}	= volume pressurised (or under vacuum) during test (m^3),
μ_{water}	= the viscosity of the liquid during filtration (Pa·s),
μ_{air}	= the viscosity of the air during the test (Pa·s), and
LRV_e	= estimated log reduction value.

9.4.2 Example Calculation of the Log Reduction of Particles from the PDT Using the H-P Approach—Estimate the LRV for a membrane system operating at a filtrate flowrate of 50 L/s and a transmembrane pressure of 70 kPa. The water temperature is 20°C, and the PDR for the system is 2.5 kPa/min at 100 kPa test pressure and 27°C. The system is operating in dead-end mode so $CF = 1$. The viscosity of water at 20°C is 1.00×10^{-3} Pa·s and air at 27°C is 1.84×10^{-5} Pa·s. The pressurized system volume during the PDT is 400 L.

First calculate f_1 and f_2 :

$$f_1 = \frac{\mu_{water}}{\mu_{air}} = \frac{1.00 \times 10^{-3}}{1.84 \times 10^{-5}} = 54.35$$

$$f_2 = \frac{P_{u,test}^2 - P_{d,test}^2}{2P_{atm} TMP} = \frac{(201.3 \text{ kPa})^2 - (101.3 \text{ kPa})^2}{2 \cdot 101.3 \text{ kPa} \cdot 70 \text{ kPa}} = 2.13$$

Estimate the LRV from Eq 3 as follows:

$$LRV_e = \log_{10} \left(\frac{Q_{filt} P_{atm}}{CF \cdot PDT \cdot V_{system}} f_1 f_2 \right)$$

$$= \log_{10} \left(\frac{50 \times 10^{-3} \text{ m}^3/\text{s} \cdot 101.3 \text{ kPa}}{1 \cdot 2.5/60 \text{ kPa/s} \cdot 400 \times 10^{-3} \text{ m}^3} \cdot 54.35 \cdot 2.13 \right)$$

$$= 4.5$$

Note that from Eq 2 the test pressure of 100 kPa equates to a minimum defect size of 2.9 μm (conservatively). So the LRV of 4.5 calculated above is the minimum LRV for particles greater than 2.9 μm diameter.

9.4.3 Experimental Approach to Correlating Test Results and System LRV Using Equivalent Number of Broken Fibers—This approach relies on measuring the relationship between gas flow and bypass flow for “worst case” defects for hollow fiber systems, and assuming that all bypass will be through such defects. This approach provides a conservative estimate of LRV that can be applied to most membrane diameters and configurations. For hollow fiber membrane systems the worst case failure will usually be a fiber that is cut cleanly at the

fiber-pot interface. This provides the shortest bypass path and the largest possible diameter. The steps involved are:

(1) Experimentally determine the gas flow through a single fiber, cut at the pot, at the selected test pressure (call this $Q_{G,atm,fiber}$). Preferably this is carried out in field tests using one or more modules of the full-scale design, or alternatively in a laboratory using the same membrane fiber and potting materials.

(2) For the same configuration determine the water flow through the lumen ($Q_{L,fiber}$) at a range of pressures to establish the bypass flow vs TMP curve for a single fiber. This can be done experimentally using short fiber lengths in the laboratory, or by theoretical calculation combined with experimental determination of friction factor (for turbulent flow).

(3) Evaluate the system LRV using the following:

(a) Measure the PDR (or VDR) for the system. Calculate the gas flow using Eq 5 (for PDT) or Eq 6 (for VDT). Note that these are the equations derived as Eq X1.4 and X1.5 in Appendix X1.

$$Q_{G,atm} = PDR \frac{V_{system}}{P_{atm}} \quad (5)$$

$$Q_{G,atm} = VR \frac{V_{system}}{P_{atm}} \quad (6)$$

(b) Calculate the equivalent number of broken fibers for the system as:

$$N_{equivalent} = \frac{Q_{G,atm}}{Q_{G,atm,fiber}} \quad (7)$$

(c) Calculate the liquid bypass flow, Q_{bypass} by multiplying the equivalent number of broken fibers by the flow per fiber at the operating TMP (from the data generated in step 2):

$$Q_{bypass} = N_{equivalent} \times Q_{L,fiber} \quad (8)$$

Eq 5 can be written for an individual fibre as $Q_{G,atm,fiber} = PDR_{fiber} V_{system} / P_{atm}$ where PDR_{fiber} is the pressure decay rate corresponding to $Q_{G,atm,fiber}$. Combining with Eq 7 and 8 gives:

$$Q_{bypass} = \frac{PDR_{corrected}}{PDR_{fiber}} \cdot Q_{L,fiber} \quad (9)$$

(d) Calculate the estimated LRV using Eq 10 (also Eq X1.2):

$$LRV_e = \log_{10} \left(\frac{Q_{filt}}{Q_{bypass}} \right) \quad (10)$$

Substituting Eq 9 into Eq 10:

$$LRV_e = \log_{10} \left(\frac{PDR_{fiber} \cdot Q_{filt}}{PDR_{corrected} \cdot Q_{L,fiber}} \right) \quad (11)$$

A similar derivation for VDT gives:

$$LRV_e = \log_{10} \left(\frac{VDR_{fiber} \cdot Q_{filt}}{VDR_{corrected} \cdot Q_{L,fiber}} \right) \quad (12)$$

The values for $Q_{G,atm,fiber}$ and $Q_{L,fiber}$ can be calculated using known hydraulic formulae (such the Darcy-Weisbach equations) including consideration of entrance and exit losses, however for nonlaminar flow situations solving these requires an iterative approach as well as establishing values for surface roughness which must be experimentally determined. When using theoretical calculation of $Q_{L,fiber}$, consideration should also be given to flow through the free end of the cut fiber as




FIG. 4 PDR Values

well as the pot, although in most cases this will be small compared to the flow through the pot.

9.4.4 Example of the Experimental Method Using the Equivalent Number of Broken Fibers—The following example is taken from data presented in Kothari and St. Peter.⁸ The filtration unit is a hollow fiber microfilter using membranes with an internal diameter of 250 μm. Results from a study looking at the impact on PDR of cutting fibers are presented. Fibers were cut near the pot, giving a cut fiber length of approximately 125 mm, with the long end of the fiber approximately 1035 mm. Temperature is assumed to be 5°C (viscosity 1.62 × 10⁻³ Pa·s), with a filtrate flow of 120 000 L/h. Data up to 400 cut fibers is presented, although only the data up to 40 cut fibers is used here as the test pressure was reasonably constant between tests at an average of 100 kPa.

Number of Cut Fibers	PDR (kPa/min)	PDR Starting Pressure (kPa)
0	0.69	101.8
1	0.76	101.7
2	0.90	101.6
6	1.10	100.9
12	1.58	100.3
24	2.41	98.4
40	3.51	95.8

Step 1. Determine the Relationship Between Gas Flow and Fibers Cut at the Pot—In order to do this the above PDR values are plotted producing the graph shown in Fig. 4. The slope of the line of best fit represents the change in pressure decay for each cut fiber, and the intercept represents the gas flow due to diffusion only (at 100 kPa test pressure). This could be converted to a gas flow using Eq 5, however for this example it is more useful to leave it as a PDR per cut fiber.

Step 2. Determine the Liquid Flowrate Through a Single Broken Fiber at the Pot—In this case we will calculate the flowrate from theory, although it could also be determined by laboratory measurement. Using Eq X1.7 for laminar flow in hollow cylinders at a filtration TMP of 50 kPa, including allowance for both ends of the cut fiber, gives:

$$Q_{L, fiber} = \frac{\pi d^4 TMP}{128 L \mu}$$

$$= \frac{\pi (250 \times 10^{-6} \text{ m})^4 \cdot 50 \times 10^3 \text{ Pa}}{128 \cdot 1.62 \times 10^{-3} \text{ Pa}\cdot\text{s}} \cdot \frac{1000 \text{ L}}{\text{m}^3} \cdot \frac{3600 \text{ s}}{\text{h}}$$

$$\cdot \left(\frac{1}{0.125 \text{ m}} + \frac{1}{1.035 \text{ m}} \right) = 0.095 \text{ L/h}$$

Checking Reynolds number confirms this is laminar flow and hence the equation is valid. An allowance for entrance and exit losses could be made, however, given the low Reynolds number this correction will be minor and the value as calculated above is conservative.

Step 3. Calculate the Relationship Between PDR and Bypass Flowrate—Using Eq 11 gives:

$$LRV_e = \log_{10} \left(\frac{PDR_{fiber} \cdot Q_{filt}}{PDR_{corrected} \cdot Q_{L, fiber}} \right)$$

$$= \log_{10} \left(\frac{0.0702 \times 120\,000 \text{ L/h}}{PDR_{corrected} \times 0.095 \text{ L/h}} \right)$$

$$= \log_{10} \left(\frac{88\,674}{PDR_{corrected}} \right)$$

$$= 4.95 - \log_{10} (PDR_{corrected})$$

$$= 4.95 - \log_{10} (PDR_{measured} - 0.72)$$

The estimated LRV's using the above equation are tabulated below for varying numbers of cut fibers. The LRV's calculated according to the H-P method (as described in 9.4.1) are also included for comparison. The difference between the two methods of estimating the LRV is small in this case (0.05 to 0.1

⁸ Kothari, H., St. Peter, E., "Utility Perspective on Regulatory Approval for Microfiltration Treatment Facilities in Wisconsin," Proceedings of AWWA Annual Conference, June 11-15 2000, Denver, CO.

log). As the fiber diameter increases the limitations of the assumptions involved in the H-P method will become greater, and the experimental approach might be more suitable. Particle count data are also included to indicate the difficulty of using conventional water quality methods to verify integrity at these levels.

0	0.69			1.40
1	0.76	6.37	6.47	1.07
2	0.90	5.70	5.80	7.50
6	1.10	5.37	5.46	2.60
12	1.58	5.01	5.10	3.00
24	2.41	4.72	4.79	1.30
40	3.51	4.50	4.55	2.30

No. of Cut Fibers	PDT (kPa/min)	LRV _e Equivalent Broken Fibers Method (see 9.4.3)	LRV _e H-P Method (see 9.4.1)	Total Particle Count (counts/mL)
----------------------	------------------	---	---	---

PRACTICE B—USE OF TOTAL ORGANIC CARBON ANALYZERS FOR MONITORING INTEGRITY OF REVERSE OSMOSIS OR NANOFILTRATION MEMBRANE SYSTEMS

10. Scope

10.1 This practice is applicable where the membrane system and water source will allow the monitoring of TOC both upstream and downstream of the system, and at least order of magnitude difference from the feed can be measured in the permeate (product) water. See D 4839.

11. Summary of Practice

11.1 *Carbon Analysis Summary*—There are two processes involved in TOC analysis—first dissolved carbon is oxidized to CO₂ and then the concentration of CO₂ is detected and the result is interpreted using a customized calibration curve. To eliminate interference from inorganic carbon (carbonate, bicarbonate, and dissolved CO₂) the sample is split into two streams. Both streams are acidified to convert inorganic carbon (IC) to CO₂, and one stream is treated further to oxidize the organic carbon to CO₂. The samples are sent to separate CO₂ detectors—one for IC and one for Total Carbon (TC). TOC is the difference between the TC and IC results. D 5173 and D 5997 give detailed descriptions of the various techniques used to perform on-line monitoring of carbon compounds in water. Instruments using these methods require approximately six minutes to analyze one sample.

11.2 *Sampling from the Permeate Stream*—Practices D 3370 describes standard practices for sampling water from closed conduits. A side stream from the permeate line is diverted to the TOC analyzer. The length of this line should be as short as possible. Most analyzers have a flushing cycle between samples and by-pass during analysis, which is diverted to drain. The volume of sample is very small compared to the by-pass flow (as little as 0.35 mL/min versus 30 to 220 mL/min for flush).

11.3 *Establishing Baseline Data*—When the system has stabilized after start-up, the feed, permeate and concentrate streams are analyzed for TOC concentration. If the instrument used can handle the range in concentrations, with different calibration curves, then it is best to use the same instrument as will be used for integrity monitoring. The instrument can be used off line in grab sample mode for these tests. It is important to perform enough repeat sample analyses to ensure the sample lines are completely filled with the test solution. Testing the permeate sample first will make this task easier. Sample size

should be large enough to reflect normal variations due to temperature and time of day.

11.4 *Concentrate Sampling*—The concentrate stream is tested to determine the system's mass-balance. It may be that organic carbon is adsorbing to the membrane. If so, there may be break-through later on when all adsorption sites are taken up and a new permeate baseline will be necessary.

11.5 *TOC Monitoring*—Follow instructions for the particular TOC analyzer in service. Be sure to keep the power on, chemicals fresh, pre-filters clean and UV or IR sources in good working order. Become familiar with the data output for your analyzer. It should provide the time, alarms, cause of the alarm, alerts when analysis conditions have been changed and a description of the new conditions. View permeate TOC concentration on a graph with the feed and permeate baseline concentrations marked.

11.5.1 *Decision Point*—A decision point must be established for your particular process depending on the degree of risk associated with a breach of integrity.

11.5.2 *Variability*—Process fluctuations, temperature, changes in chemical cartridges, fouling of the TOC analyzer inlet pre-filter, changes in flow to the analyzer can all affect the TOC analysis. The degree of variability depends on the process and operation of the analyzer. The decision point should not be reached due to normal process variability.

12. Significance and Use


12.1 TOC Monitoring can be used effectively when the difference between average feed and product TOC concentration is at least one order of magnitude. TOC monitoring, as a tool for monitoring integrity, is used to identify relative changes in the integrity of a system. The sensitivity of the method is dependent on:

12.1.1 The capabilities of TOC instrument,

12.1.2 The size of the system as measured by permeate flow, and

12.1.3 The change in permeate TOC concentration that corresponds to a significant leak.

12.2 TOC analyzers are affected by conditions outlined below. For interference specific to a particular analyzer, contact the manufacturer. A baseline permeate TOC level must be established within the limits of the instrument that is still



NOTE—Error bars indicate 3 standard deviations from the average (Chapman and Linton).⁹

FIG. 5 Change in TOC Concentration with Different Types of Damage

significantly different from the challenge or average feed concentration by one order of magnitude.

12.3 The size of the system monitored by one sample point should be determined using a risk/cost analysis. The risk is the potential for harm or legal action if there is a leak in the system. The cost is the price of additional sample points or additional analyzers.

12.4 The change in permeate TOC concentration corresponding to a significant leak (as defined by the risk/cost analysis) will depend on the volume of permeate produced by intact membrane in the monitored unit.

12.5 When determining the size that can be tested as a discrete unit, consider the change in TOC concentration expected from a leak that should initiate action. The change should be greater than 3 standard deviations of the average product concentration measured for that system. Fig. 5 shows change in permeate TOC concentration in an RO system with different types of damage. The feed and concentrate concentrations were approximately 5 and 10 mg/L, respectively.

13. Interferences

13.1 *Changes in Inorganic Carbon Concentration*—Instability in the pretreatment acidification process can cause fluctuations in the inorganic carbon concentration of the permeate stream. If adjustment is not made in the acidification process to drive off excess IC, then the TOC results will be high.

13.2 *Changes in Background Conductivity*—Changes in sample background conductivity will corrupt the comparison

of CO₂ conductivity with the calibration curve. Since TOC analyzers can be much more sensitive than conductivity sensors, breaches in integrity should be detected due to increase in TOC concentration before there is a significant change in permeate conductivity.⁹

13.3 *Particulates*—Particles suspended in the water stream may cause blockage in the monitor over time.

14. Apparatus

14.1 D 5173 shows block diagrams of several designs of on-line TOC analyzers that have been introduced successfully.

15. Interpretation of Results

15.1 Permeate and feed (or average of feed and concentrate) TOC concentrations should be plotted over time. Using the feed concentration will provide the more conservative benchmark and simplify the procedure.

15.2 When the system has stabilized after start-up, calculate the standard deviation of the permeate and feed TOC concentrations. If permeate concentration exceeds three standard deviations from the average, check the system to determine the cause.

⁹ Chapman, M. W., Linton, K., "Evaluation of Integrity Monitoring Methods for Reverse Osmosis Membrane Systems," 4/2000, USBR- DWPR Report #55. Available from S. Martella, USBR M.S. D-8230, P.O. Box 25007, Denver, CO 80225-0007.

PRACTICE C—SOLUBLE DYE TEST
16. Scope

16.1 This guide is applicable to RO and NF membrane systems, including those with spiral, tubular or flat sheet configuration elements. The guide describes the application of two soluble dyes, Red Dye # 40 and Rhodamine WT. Both dyes have a molecular weight of approximately 500. See Practice D 3923.

17. Summary of Practice

17.1 This test works on the principle that a dissolved dye that is nearly completely rejected by an intact membrane element will pass through a membrane or seal defect into the permeate at an increased rate that indicates a leak that is capable of passing significant amounts of microbial material.

17.2 A solution of controlled concentration of a dye, known to be rejected at a rate of 99.0 % or greater (≥ 2 log) by the membrane, is circulated through the system under standard operating conditions as recommended by the manufacturer. The concentration of the dye in the permeate and in the feed is measured with a spectrophotometer for dyes that adsorb light maximally at a specific wavelength or with a fluorometer for fluorescing dyes that adsorb at one wavelength and emit at a second wavelength. A leak, or loss of integrity, will be indicated by increased dye passage, as measured by a critical percent increase in the permeate concentration. The membrane or system supplier may have a specific dye passage specification that indicates loss of integrity—consult the supplier. For RO systems tested with FD&C Red Dye # 40, a passage greater than 0.2 % of the feed concentration is known to indicate a loss of integrity.¹⁰ Alternatively, calculate the LRV from the feed and permeate dye values (as described in Section 21), to assure the required removal is achieved.

17.3 Plumbing connections and operational considerations should allow the system to be run 30 min in recirculation mode, or alternately with continuous liquid dye injection for up 30 min and when introduction of a soluble dye will not interfere with operation of the system for its application. The dye chosen must be rejected (retained) by the intact membrane in the system.

18. Apparatus

18.1 *Feed Tank*—For batch (recirculation) tests, a feed tank of sufficient volume relative to the system size to allow operation in recirculation mode, such as the system's clean-in-place (CIP) tank connected to the feed and outlet piping system. Alternately, for flow-through tests, a system with a chemical feed pump calibrated to allow a controlled amount of dye plumbed in prior to the high pressure pump can be used.

18.2 *Spectrophotometer*—The spectrophotometer must be capable of measuring at a wavelength best for the absorption spectra for the dye of interest.

18.3 *Fluorometer*—The fluorometer shall be capable of measuring Rhodamine WT with a minimum detection limit of 10 nanograms per litre (ng/L) in clean water, using excitation wavelength of 550 nm and emission wavelength of about 570 to 700 nm. One fluorometer suitable for this purpose is the Turner Designs model TD-700.

19. Reagents
19.1 Non-fluorescent Dyes:

19.1.1 *Dye Feed Solution*—For all RO systems and those NF systems where the membrane is known to have a pore size that retains molecules larger than 400 Daltons, FD&C Red Dye #40 is suggested. If another dye is chosen, it must be miscible in water, stable in the mid pH range, not adsorbed by the membrane and nontoxic. Its molecular weight must also be appropriate for the membrane being tested. Check with the membrane supplier for suitable dye choices.

19.1.2 *Recirculation Mode*—Calculate the tank plus system hold-up volume, and mix a solution of dye to achieve the desired total system volume concentration (from 50 to 100 mg/L is recommended).

19.1.3 *On-stream Mode*—To achieve a feed dye concentration of 50 mg/L, inject a 1 % solution of dye at a rate of 3 gallons per hour for every 100 gallons per minute of system feed flow. This injection rate will need to be lowered if there is internal recycle of the concentrate stream back to the feed (the test should be run with no internal recycle if possible). If run with recycle, the dye concentration in the concentrate stream should be calculated assuming 100 % dye rejection and used to recalculate the required dye concentration in the raw feed.

19.1.4 *Calibration Curve*—Prior to integrity testing, a calibration curve of the test dye concentration to absorbance should be developed over the range of 1 μ g/L to 1 mg/L. The proper wavelength must be determined for the chosen dye's spectrophotometric measurement.

19.2 Fluorescent Dye:

19.2.1 *Dye Feed Solution*—For all RO systems and those NF systems where the membrane is known to have a pore size that retains molecules larger than 400 Daltons, Rhodamine WT fluorescent dye may be used unless incompatible with the membrane (check for compatibility with the membrane manufacturer). Rhodamine WT has low adsorbability on most solid surfaces, is widely used in the water treatment industry as a tracer compound, and has been approved for use in drinking water by the U.S. EPA provided that the concentration not exceed 0.1 μ g/L (100 ng/L) and exposure be brief and infrequent. At this time, no other fluorescent dyes are approved for use with drinking water. Based on studies conducted by the American Water Works Association Research Foundation (AwwaRF), the minimum practical quantitation limit for Rhodamine WT in membrane permeates is 20 ng/L. Based on this level, a maximum permissible concentration of 100 ng/L in the membrane feedwater, a desired LRV challenge level of 3.5 logs and an assumed LRV of 3 by NF and RO membranes, a feed solution concentration of 100 μ g/L is required.

¹⁰ Chapman and Linton found that a response greater than 0.53 μ g/L was significant and could be differentiated from the baseline. Therefore, a feed concentration of 5 mg/L and a permeate concentration of 5 μ g/L would correspond to a 3 log reduction (LRV) of dye.

19.2.2 *Dosing Solution Preparation*—Commercially-available Rhodamine WT solutions have a specific gravity of 1.2 and are typically 21.3 % active, meaning 21.3 parts of active Rhodamine WT in 100 parts of water. To obtain a given concentration of active Rhodamine WT in a membrane feed solution, both the active concentration and specific gravity of the Rhodamine WT must be accounted for. A 100 µg/L concentration of active Rhodamine WT is equivalent to 0.32 mL of 21.3 % active Rhodamine solution in 1 gal of water.

19.2.3 *Recirculation Mode*—Calculate the tank plus system hold-up volume, and mix a solution of active dye to achieve a total system volume concentration of 100 µg/L.

19.2.4 *On-stream Mode*—To achieve a feed dye concentration of 100 µg/L, inject a 0.01 % (100 mg/L) solution of dye at a rate of 3.2 gal per hour for every 100 gallons per minute of system feed flow. This injection rate will change if there is internal recycle of the concentrate stream back to the feed (the test should be run with no internal recycle if possible). If run with recycle, the dye concentration in the concentrate stream should be calculated assuming 100 % rejection and used to recalculate the required dye concentration in the raw feed.

19.2.5 *Calibration Curve*—Prior to integrity testing, two calibration curves of dye concentration to fluorescence must be developed: low (permeate) level curve (range of 10 ng/L 300 ng/L) and high (feed) level (10 µg/L to 1 mg/L).

20. Procedure

20.1 The system should be running under manufacturer recommended operating conditions or at conditions that best simulate the normal production mode of the membrane plant for a period long enough that the performance of the membrane system (as measured by flow and salt rejection) is at equilibrium. For batch tests, add the appropriate volume of dye to the feed tank ensuring good mixing in the tank and recirculate the feed solution to obtain a steady state dye concentration in the system. For on-stream tests, inject the dye using a metering pump to obtain the target concentration of dye in the membrane feedwater as indicated in Section 19. Inject the dye upstream of the membrane feed (high pressure) pump at a location that will ensure adequate mixing of the dye with the feedwater.

20.2 Determine the appropriate sample points, especially the sections of the system where permeate will be sampled. The amount of membrane contributing to each permeate sample determines the sensitivity of the test, since any given leak is diluted by the permeate volume from the nonleaking membrane. It is recommended that the permeate from each housing (in a membrane train) be sampled to provide the maximum sensitivity.

20.3 *Non-Fluorescent Dyes*—Allow the system to equilibrate for 15 min, or the time recommended by the manufacturer, while maintaining constant flow, pressure, and temperature conditions. At the end of this period, collect 100-mL samples of the feed, concentrate, and permeate stream in clean test tubes or cuvettes from the composite system and from each individual housing for which integrity is to be monitored. Measure and record the absorbance of the feed, concentrate, and permeate samples using a spectrophotometer at the correct wavelength for the dye used (502 nm for FD&C Red Dye #40)

and correlate absorbance to a dye concentration value using the calibration curve. Calculate the percent dye passage using Eq 13.

20.4 00-mL samples of the feed, concentrate, and permeate stream in clean test tubes or cuvettes from the composite system and from each individual housing for which integrity is to be monitored. Measure and record the absorbance of the feed, concentrate, and permeate samples using a spectrophotometer at the correct wavelength for the dye used (502 nm for FD&S Red #40) and correlate absorbance to a dye concentration value using the calibration curve. Calculate the percent dye passage using the equation in Section 21.

20.5 *Fluorescent Dye*—Allow the system to operate for 15 min, or the time recommended by the manufacturer, while maintaining constant flow, pressure, and temperature conditions. At the end of this period, collect 100-mL samples of the feed, concentrate, and permeate stream in clean test tubes or cuvettes from the composite system and from each individual housing for which integrity is to be monitored. Measure and record the fluorescence of the feed, concentrate, and permeate samples using a fluorometer and excitation and emission wavelengths as described in Section 19 and calculate dye concentration using the appropriate calibration curve. Calculate the percent dye passage using the equation in Section 21.

21. Calculations

21.1 To calculate dye passage, use the equation:

$$\text{Dye Passage (\%)} = \frac{C_p}{C_f} \cdot 100 \quad (13)$$

where:

C_p = dye concentration of the permeate, and
 C_f = dye concentration of the feed.

Passage of 1 % and 0.1 % would correspond to LRV values of 2 and 3, respectively.

21.2 Because the concentrate stream from one stage is the feed to an additional stage in series, the dye concentration of the feed to the downstream stage will be higher. To calculate the dye concentration of the feed to the downstream stage, assume the feed concentration to each stage in a given array is equivalent. Recalculate the dye concentration for the feed to each separate stage by reducing the feed volume by the approximate volume of the permeate removed in the preceding stage while holding the mass of dye in that feed solution constant. This higher concentration of dye will enter the downstream stage. Alternately, one can assume the feed to each stage in series is equivalent to the feed to the entire system. This will increase the safety factor of the test but may give a false indication of a leak.

21.3 If a leak is detected measure the composite permeate from each stage to determine the stage with the breach of integrity. Then measure permeate flow from individual housings within the suspect stage to isolate the leaking element(s).¹¹

¹¹ The elements in the housing may be individually tested with a similar procedure from Practice A to determine which have lost integrity.

22. Keywords

22.1 integrity; membrane; pressure decay; soluble dye test; TOC test; vacuum decay

APPENDIX

(Nonmandatory Information)

X1. DERIVATION

X1.1 The mass flow of particles in the filtrate leaving the system is made up of particles passing through the membrane ($C_{membrane} \cdot Q_{membrane}$) and particles bypassing the membrane through defects or leaks ($C_{bypass} \cdot Q_{bypass}$). The mass flow of particles challenging the membrane is $C_{feed} \cdot Q_{filtr}$. The log reduction of particles across the membrane is defined by mass balance as shown in Eq X1.1.

$$LRV = \log_{10} \left(\frac{C_{raw} \cdot Q_{filtr}}{(C_{bypass} \cdot Q_{bypass} + C_{membrane} \cdot Q_{membrane})} \right) \quad (X1.1)$$

where:

C_{raw}	= concentration of particles entering the system,
C_{filtr}	= concentration of particles in the filtrate leaving the system,
C_{bypass}	= concentration of particles in the flow bypassing the membrane through defects or leaks,
$C_{membrane}$	= concentration of particles passing through the membrane,
Q_{feed}	= flowrate of feed to the membrane (= Q_{filtr}),
Q_{filtr}	= flowrate of filtrate leaving the membrane (= $Q_{bypass} + Q_{membrane}$),
Q_{bypass}	= flowrate bypassing the membrane through defects or leaks,
$Q_{membrane}$	= flowrate passing through the integral portion of the membrane, and
LRV	= log reduction value of particles across the membrane system.

X1.2 For particles with a diameter greater than the minimum defect size (as set by the test pressure chosen, see 9.3) an intact membrane will give complete rejection. Thus for these particles $C_{membrane}$ will be zero, and C_{bypass} can be assumed to be the same as the concentration of particles in suspension and challenging the membrane, which we will call C_{feed} . In direct flow (dead-end) filtration systems C_{feed} can be assumed to be the same as the concentration of particles in the raw feed to the membrane system, C_{raw} . However, in the case of recirculation systems or configurations that increase the concentration of suspended solids on the feed side of the membrane (such as feed and bleed modes) C_{feed} can be many times greater than C_{raw} . In such cases C_{feed} is calculated as follows:

$$C_{feed} = CF \cdot C_{raw}$$

Where CF is a concentration factor that typically ranges from 1 to more than 20. Substituting into Eq X1.1 gives:

$$LRV = \log_{10} \left(\frac{Q_{filtr}}{Q_{bypass} \cdot CF} \right) \quad (X1.2)$$

X1.3 As the integrity test is conducted under known conditions of temperature and pressure, it is possible to mathematically estimate the equivalent flow of liquid that would pass through these same defects under filtration conditions (the bypass flow Q_{bypass}). Using Eq X1.2, an estimate of the LRV for the system can then be determined.

X1.4 The following derivations are made with reference to Fig. X1.1, assuming laminar flow for both the air and liquid through cylindrical defects. The PDR or VDR is first expressed as $Q_{G,atm}$, the volumetric air flow rate through defects at atmospheric pressure. If we define V_{system} as the volume of the air cavity pressurized during the PDT, or under vacuum during the VDT, then at the beginning of the test:

$$P_i V_{system} = P_{atm} V_i$$

At the end of the air test:

$$P_f V_{system} = P_{atm} V_f$$

Where V_i and V_f represent the equivalent volumes of air at atmospheric pressure (P_{atm}) at the beginning and end of the test respectively. P_i and P_f are the initial and final pressures during the test.

By subtraction:

$$(P_i - P_f) V_{system} = (V_i - V_f) P_{atm}$$

$$V_i - V_f = (P_i - P_f) \frac{V_{system}}{P_{atm}}$$

Dividing both sides by t , the duration of the test:

$$\frac{V_i - V_f}{t} = \frac{(P_i - P_f)}{t} \frac{V_{system}}{P_{atm}} \quad (X1.3)$$

By definition for PDT:

$$\frac{V_i - V_f}{t} = Q_{G,atm} \quad \text{and} \quad \frac{P_i - P_f}{t} = PDR$$

Substituting into Eq X1.3 gives the following for PDT:

$$Q_{G,atm} = PDR \frac{V_{system}}{P_{atm}} \quad (X1.4)$$

and for VDT by definition:

$$\frac{V_f - V_i}{t} = Q_{G,atm} \quad \text{and} \quad \frac{P_f - P_i}{t} = VDR$$

Substituting into Eq X1.3 gives the following for VDT:

$$Q_{G,atm} = VDR \frac{V_{system}}{P_{atm}} \quad (X1.5)$$

$Q_{G,atm}$ is converted to $Q_{G,test}$ by correcting for the difference in pressures using the average pressure through the defect:




FIG. X1.1 Membrane System Under Test and Filtration Conditions

$$\frac{Q_{G,test}}{Q_{G,atm}} = \frac{P_{atm}}{\left(\frac{P_{u,test} + P_{d,test}}{2}\right)} \quad (X1.6)$$

$$Q_{G,test} = Q_{G,atm} \frac{2P_{atm}}{(P_{u,test} + P_{d,test})}$$

X1.5 The next step is to convert the air flow through the defect under test conditions, $Q_{G,test}$, to an equivalent liquid flow under filtration conditions, Q_{bypass} . To do this it is assumed that both the air and liquid flows follow the Hagen-Poiseuille law for laminar flow in circular pipes, which is:

$$Q = \frac{\pi d^4 \Delta P}{128 L \mu} \quad (X1.7)$$

Where Q is the flowrate, ΔP is the pressure drop, and μ is the fluid viscosity. The parameters d and L refer to the diameter and length of the pipe. In our application we have no information about the nature or number of defects that would allow the appropriate choice of values for d and L . If we assume that the defect geometry remains the same in both test and filtration conditions we can introduce a proportionality constant, k , to represent the geometry term $\pi d^4 / (128L)$ in Eq X1.7.

Applying this to the test conditions for air:

$$Q_{G,test} = k \cdot \frac{(P_{u,test} - P_{d,test})}{\mu_{air}} \quad (X1.8)$$

And for filtration conditions:

$$Q_{bypass} = k \cdot \frac{TMP}{\mu_{water}} \quad (X1.9)$$

Divide Eq X1.9 by Eq X1.8 and rearranging:

$$Q_{bypass} = Q_{G,test} \left(\frac{\mu_{air}}{\mu_{water}}\right) \frac{TMP}{P_{u,test} - P_{d,test}} \quad (X1.10)$$

Substitute Eq X1.6 into Eq X1.10:

$$Q_{bypass} = Q_{G,atm} \frac{2P_{atm}}{(P_{u,test} + P_{d,test})} \frac{TMP}{(P_{u,test} - P_{d,test})} \frac{\mu_{air}}{\mu_{water}} \quad (X1.11)$$

$$Q_{bypass} = Q_{G,atm} \frac{\mu_{air}}{\mu_{water}} \frac{2P_{atm} TMP}{(P_{u,test}^2 - P_{d,test}^2)}$$

Define:

$$f_1 = \frac{\mu_{water}}{\mu_{air}} \text{ and } f_2 = \frac{P_{u,test}^2 - P_{d,test}^2}{2P_{atm} TMP}$$

Substituting into Eq X1.11 gives:

$$Q_{bypass} = \frac{Q_{G,atm}}{f_1 f_2} \quad (X1.12)$$

Where f_1 and f_2 can be considered to represent viscosity and pressure corrections respectively.

Substituting Eq X1.12 into Eq X1.2 gives:

$$LRV_e = \log_{10} \left(\frac{Q_{filtr}}{CF \cdot Q_{G,atm}} f_1 f_2 \right) \quad (X1.13)$$

Substituting Eq X1.4 and Eq X1.5 into Eq X1.13 gives:

For PDT:

$$LRV_e \log_{10} \left(\frac{Q_{filtr} P_{atm}}{CF \cdot PDT \cdot V_{system}} f_1 f_2 \right) \quad (X1.14)$$

For VDT:

$$LRV_e \log_{10} \left(\frac{Q_{filtr} P_{atm}}{CF \cdot VDT \cdot V_{system}} f_1 f_2 \right) \quad (X1.15)$$

X1.6 The assumption of laminar flow for both air and liquid is not valid for all configurations, particularly large diameter membranes (> 300 to $400 \mu\text{m}$ lumen diameter) which can lead to error in the calculated LRV. As with all methods to correlate integrity test results to LRV the relationship should be verified by field tests for the particular membrane and configuration used.

ASTM International takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM International Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, at the address shown below.

This standard is copyrighted by ASTM International, 100 Barr Harbor Drive, PO Box C700, West Conshohocken, PA 19428-2959, United States. Individual reprints (single or multiple copies) of this standard may be obtained by contacting ASTM at the above address or at 610-832-9585 (phone), 610-832-9555 (fax), or service@astm.org (e-mail); or through the ASTM website (www.astm.org).