

401.2 Ventilation required.

Every occupied space shall be ventilated by natural means in accordance with Section 402 or by mechanical means in accordance with Section 403. *Dwelling units* complying with the air leakage requirements of the *International Energy Conservation Code* or ASHRAE 90.1 shall be ventilated by mechanical means in accordance with Section 403. Ambulatory care facilities, Group I-2 *occupancies* shall be ventilated by mechanical means in accordance with Section 407.

anical means in
ergy Conservation
care facilities and