

MODEL NO.

01EB060A25B

SERIAL (S)N0G5557273



CENTRAL COOLING AIR CONDITIONER

FOR OUTDOOR INSTALLATION ONLY

USE COPPER SUPPLY WIRE 208/230-3-60

FACTORY CHARGED: R22, 5 LBS., 15 OZ.

MIN. TEST PRESS.: HIGH SIDE 300 PSIG, LOW SIDE 150 PSIG

QTY	LOAD	HP	VOLT-PH-HZ		
1	COMP.		208/230-3-60	16.0	RLA 125 LRA
1	I.D.BLOW.	1.0	208/230-1-60	7.0	FLA
1	O.D.FAN	1/4	208/230-1-60	1.3	FLA

** HEATER	MIN	HEATER	MIN CKT	MAX FUSE/
MODEL	SPD	KW @	AMPACITY	HACR BRKR
** 2NH045-	TAP	208/240	208/240	208/240
() NONE	L	0.0	28.3	40.0
() 01025A	L	7.5/10.0	34.8/38.8	40/40
() 01525A	L	11.3/15.0	47.8/53.9	50/60
() 02025A	M	15.0/20.0	60.9/68.9	70/70
() 02525A	M	18.8/25.0	73.9/83.9	80/90

** MARK OPTION INSTALLED BY "X" IN BOX

MAXIMUM EXTERNAL STATIC PRESS: .70 I.W.C.

MIN. UNIT CLEARANCE FROM COMBUSTIBLE SURFACE: 0.0 IN.

MIN. SUPPLY DUCT/PLENUM CLEARANCE: 1.0 IN. AROUND ALL

SIDES FOR FIRST 3 FEET FROM UNIT; 0.0 IN. THEREAFTER.

SEE INSTALLATION INSTRUCTIONS FOR FURTHER DETAILS.

MAXIMUM OUTLET AIR TEMPERATURE: 200 DEG. F.