



**St. Tammany Fire Protection District**

522 Robert Boulevard  
Slidell La. 70458



Phone: (985) 649-3665 Fax: 985-646-4865

This inspection is intended for your safety and the safety of the citizens of Louisiana. Your cooperation is greatly appreciated.

**Occupancy:** Slidell tire service.

**Address:** 153 EAST HALL

**Date of Inspection:** 12/9/2024 10:00:22 AM

**Type of Inspection:** Reinspection-Deficiency follow up

Severity	Location	Code	Reason
1 Deficient		ADA	Bathroom needs to be brought back to ADA. Sink must be brought up 2 inches minimum and moved away from the rear grab bar to not interfere. Braille sign must be installed and 36 inch door must be installed and outward swinging door to allow for proper clearance. Wood must be removed in entire bathroom in addition to adding a mirror in restroom. Mirror must be hung with a max height of 40 in from the floor at the reflective surface.
2 Deficient		Electrical System	All electric needs to be compliant with all electrical wires in boxes. Outlets gfi. Electrical panel with correct blanks. Awaiting electrical permit granted by the City.
3 Deficient		Means of Egress	Separate means of egress is required with occupancy as roll up doors do not need code as a sufficient means of egress. Discussed with management that structural permit must be filed with City in order to perform work necessary to create additional exits.

**Inspection Result:** Deficiencies noted

**Re-Inspection Date:** 12/10/2024 7:32:17 AM

**Completed By:**

Cambre, Mark

**Report Received By:**

Oscar sanchez

R.S. 40:1621 Whoever fails to comply with any order issued by the Fire Marshal or his authorized representative under any provision of Part III, Chapter 7, of Title 40 of the Louisiana Revised Statutes of 1950, R.S. 50:1569 expected, shall be fined not more than five hundred dollars or imprisoned, for not more than six months or both. Each day's violation of an order constitutes a separate offense and may be punished at the discretion of the court.