

Covington Elem Stage AC

From: Mannino, Sammy V. <sammy.mannino@stpsb.org>

To: David Dammon <david@dammonengineering.com>

David

Re: Sheet 23 74 16-1, Par. 2.01 A.: (Rooftop Air Units) – Delete notes that state “provide evidence that unit will work with existing duct **prior to bid**”

Okay to add notes requiring the unit to work with existing ductwork. Contractor responsible for any/all modifications required.

Thanks

Sammy Mannino

STPSB Supervisor of Construction

985-898-3241

985-966-3085 (cell)

STPPS adheres to the equal opportunity provisions of federal and civil rights laws and does not discriminate on the basis of race, color, national origin, religion, age, sex, sexual orientation, marital status, or disability.

Confidentiality Notice: This e-mail message, including any attachments, is for the sole use of the intended recipient and may contain confidential and privileged information. Any unauthorized review, use, disclosure or distribution is prohibited. If you are not the intended recipient, please contact the sender by reply e-mail and destroy all copies of the original message.
