


ELECTRICAL NOTES #	
1	REFER TO TYPICAL EXAM ROOM ON THIS SHEET FOR DEVICE LAYOUT.
2	COORDINATE MOUNTING OF DEVICES AND ROUTING OF CONDUIT WITH MILLWORK PROVIDER PRIOR TO INSTALLATION.
3	
4	1" CONDUITS WITH CABLE INDICATED TO NEAREST WALL WITH ACCESSIBLE CEILING. STUB UP A MINIMUM OF 6" ABOVE CEILING.
5	DISTRESS BUTTON. VERIFY LOCATION WITH OWNER/ARCHITECT PRIOR TO INSTALLATION.
6	3/4" CONDUIT WITH CABLING TO COMMUNICATION BACKBOARD.
7	REFER TO TYPICAL OFFICE ON THIS SHEET FOR DEVICE LAYOUT.
8	CONNECT DOOR HARDWARE TO FIRE ALARM SYSTEM. DOOR TO BE RELEASED UPON ACTIVATION OF FIRE ALARM SYSTEM.



1 LEVEL 4 - SPECIAL SYSTEMS PLAN
 SCALE: 1/8" = 1'-0" (REFER TO ARCHITECTURAL DRAWINGS FOR ALL DIMENSIONS)



washer hill
 lipscomb cabanis
 architecture, llc
 copyright 2023
 1744 oakdale dr baton rouge, la
 t. 225.767.1530 f. 225.767.0018
 www.whlcarchitecture.com

Construction Documents
 11.8.2023
 WHLC 21-068
 05-23-2024 - ASI #016

Fourth Floor Special
 Systems Plan