



February 25, 2026

Mel Faciane, Project Manager

Hopkins Construction
19197 Commission Rd.
Long Beach, MS 39560
C: 985-960-0221

Re:
Pride Fire Station
Indian Mound Station
Central, La. 70739

Dear Mr. Faciane,

J bolt sizes for the Pre Engineered metal building designed by Pinnacle Structures Inc.

Jamb: 24" Long J Bolts x 5/8" diameter with a 3" leg
Endwall: 24" Long J Bolts x 3/4" diameter with a 3" leg
Frame: 24" Long J Bolts x 3/4" diameter with a 3" leg

This report does not cover any other aspects of the building such as framing, plumbing, electrical, gas, mechanical egress, general arrangement, site drainage, etc., and assumes that ground conditions are substantially the same.

Sincerely,

Brian Mistich

Brian A Mistich, P.E.
La. License No. 0030187

