

Main Wind Force Res. Sys. / Comp and Clad. – Method 2		All Heights
Figure 6-5	Internal Pressure Coefficient, GC_{pi}	Walls & Roofs
Enclosed, Partially Enclosed, and Open Buildings		

Enclosure Classification	GC_{pi}
Open Buildings	0.00
Partially Enclosed Buildings	+0.55 -0.55
Enclosed Buildings	+0.18 -0.18

Notes:

1. Plus and minus signs signify pressures acting toward and away from the internal surfaces, respectively.
2. Values of GC_{pi} shall be used with q_z or q_h as specified in 6.5.12.
3. Two cases shall be considered to determine the critical load requirements for the appropriate condition:
 - (i) a positive value of GC_{pi} applied to all internal surfaces
 - (ii) a negative value of GC_{pi} applied to all internal surfaces