



Project: _____

SUBMITTAL COVER SHEET

Arch. Project No: _____

MNC Project No: _____

To: _____

From: _____

Attn. _____

Sent Via _____

General Contractor's Review:

M Natal Contractor, Inc.

CONTRACTOR'S REVIEW:

SUBMITTAL NO: _____

NO EXCEPTIONS TAKEN

SPEC. SEC. NO: _____

FURNISH AS CORRECTED

VENDOR/SUB: _____

REJECTED; RESUBMIT

DESCRIPTION: _____

PARTIAL APPROVAL; SUBMIT ADD'L ITEM(S)

Reviewing is for conformance with the design concept of the project and compliance with the information given in the Contract Documents. The Vendor/Subcontractor is responsible for dimensions to be confirmed and correlated at the site for information that pertains solely to the fabrication process or to the means, method, technician, sequences, and procedures of construction; and for coordination of the work with all trades.

BY Chen Rusich

DATE: _____

Architect/Engineer Review:

FIRE EXTINGUISHERS - COSMIC MULTI PURPOSE DRY CHEMICAL - C - Portable Handheld

ABC dry chemical is a multipurpose extinguishing agent that is suitable for use in offices, classrooms, churches, parking garages and retail. Not recommended for use on sensitive electronic equipment.



CLASS A FIRES

Common
Combustibles



CLASS B FIRES

Flammable
Liquids
and Gases



CLASS C FIRES

Energized
Electrical
Equipment

SPECIFICATIONS:

These units contain specially fluidized and siliconized mono ammonium phosphate powder, which smothers and breaks the chain reaction on Class B fires, fuses and insulates Class A fires and is a non-conductor of electricity. Non-toxic.

Conforms to Test Standards: CAN/ULC-S504 — ANSI/UL299 & CAN/ULC S508 — ANSI/UL711

Operation: Squeeze the lever, which opens the valve, allowing the chemical to be forced out. Upright squeeze grip operation.


Temperature Range: -65° F (-53° C) to 120° F (49° C)

Construction: Heavy-duty steel cylinder with siphon tube, replaceable molded valve stem seal, visual pressure gauge, pull pin and upright squeeze grip. Corrosion and impact-resistant powder coat finish.

Valve Material: Aluminum

All units meet the current requirements established by the National Fire Protection Association (NFPA) for NFPA10 "Standard for Portable Fire Extinguishers", and any other applicable NFPA standards. Tested and listed by UL to meet construction and performance standards for this type of extinguisher, and can be used where required by local codes such as OSHA.

Tagging included

Qty.	Model	Type	Valve	Nominal Capacity	Shipping Weight	Cylinder Dia.	Overall Height	Overall Width	Shipping Vol.	UL Rating 	Optional Mounting Bracket	USCG Approved
	Cosmic 2-1/2E* (FE02C)	ABC Dry Chemical	Aluminum	2-1/2 lbs.	5-1/2 lbs.	3-3/8"	15-1/2"	5-3/4"	.2 cu.ft.	1A-10B:C	MB817C*	YES
	Cosmic 5E (FE05C)			5 lbs.	10 lbs.	4-1/4"	16-3/8"	7-1/4"	.35 cu.ft.	3A-40B:C	MB818C	YES
	Cosmic 5B* (FE05BC)			5 lbs.	10 lbs.	4-1/4"	16-3/8"	7-1/4"	.35 cu.ft.	3A-40B:C	MB818C*	YES
	Cosmic 10E (FE10C)			10 lbs.	18-1/4" lbs.	5-1/8"	21"	7-3/4"	.65 cu.ft.	4A-80B:C	MB846C	YES
	Cosmic 20E (FE20C)		20 lbs.	33-1/2 lbs.	7-1/2"	21-1/4"	8-3/4"	1.0 cu.ft.	10A-120B:C	MB811C	YES	
	Cosmic 5E (FE05CBV)		Brass	5 lbs.	10 lbs.	4-1/4"	16-3/8"	7-1/4"	.35 cu.ft.	3A-40B:C	MB818C	YES
	Cosmic 10E (FE10CBV)			10 lbs.	18-1/4" lbs.	5-1/8"	21"	7-3/4"	.65 cu.ft.	4A-80B:C	MB846C	YES
	Cosmic 20E (FE20CBV)			20 lbs.	33-1/2 lbs.	7-1/2"	21-1/4"	8-3/4"	1.0 cu.ft.	10A-120B:C	MB811C	YES

*Indicates mounting bracket standard. J hook wall bracket standard with all other extinguisher - mounting bracket available for those models at extra charge.

Note: NFPA regulations also require extinguishers to be inspected when initially placed in service and all local fire code and tagging requirements must be adhered to. All fire extinguisher sizes are nominal. Contact Customer Service for more information about ordering tagged extinguishers in your area.



800-554-6077
sales@activarcpg.com
www.activarcpg.com

9702 Newton Ave S. Bloomington, MN 55431 | Many Locations Across North America

Distributor:

Project:

Contractor:

Approved By:

Date:

Architect:

Scale: N/A

Pages: 1 of 1

Item #: