

DAMMON ENGINEERING, INC.

dammonengineering.com

ARCHITECTS

ENGINEERS

CONSULTING

DESIGN

STUDIES

EXPERT WITNESS

554 Old Spanish Trail
Slidell, LA 70458

985-649-5832
FAX 985-641-5950

6 December 2011

RE: Slidell Memorial Hospital
Fitness Park
1353 11th Street
Slidell, Louisiana 70458

Dear Plan Holder:

This letter acknowledges receipt of Addendum No. 1 and all attachments (5 total pages).

Please Print Name & Company:

Signature:

Date:

Please fax your acknowledgement to Dammon Engineering, Inc. at 985-641-5950.

Sincerely,

Dammon Engineering, Inc.

Robert Wiltse
Chief Architect

554 Old Spanish Trail
Slidell, LA 70458

985-649-5832
FAX 985-641-5950

ADDENDUM NO. 1
6 December 2011

Slidell Memorial Hospital
Fitness Park
1353 11th Street
Slidell, Louisiana 70458

ADDENDA NO. 1

1. Sheet L-1, L-2: Wood for trash receptacles to be "Mahogany".
2. Sheet L-1, L-2: Wood for 6' benches to be "Mahogany".
3. Sheet L-1, L-2: Metal finish for all site furnishings to be "VS Bronze".
4. See attached Pre-Bid Meeting Minutes.
5. See attached Pre-Bid Meeting Attendance Sheets.

Slidell Memorial Hospital
Fitness Park
Tuesday November 29, 2010 at 12:30pm
Pre-Bid Meeting in Conference Room A @ SMH

MINUTES:

- Meeting started promptly at 12:30 pm.
- Barry Winters started meeting and made introductions of himself, Eric McQuiston, Robert Wiltse, and Chuck Dammon
- Barry stated Bid Opening will be December 14, 2011 @ 2:00 pm in this same room
- Barry stated that the Board of Commissioners will meet on December 19, 2011 to review the bid recommendation.
- Robert briefly reviewed Specification Manual Documents including Request for Bids, Bid Form, Bonds, and Contracts. There were no questions.
- Robert emphasized Sealed bids must have the bid number, **Bid # 11-12-02C**, boldly displayed on the outside of the envelope.
- Chuck and Eric reviewed Plans and Technical Specifications.
- Chuck reviewed fence layout including double fence on West side.
- Chuck advised Contractors to coordinate directly with utility companies and with SMH & Dammon Engineering.
- Bidder asked about gas meter and Cleco pole on site, this to be reviewed during site tour.
- Chuck verified sidewalks to have micro fiber reinforcing, parking paving to have micro fiber and steel reinforcing, as shown on plans. Slope for sidewalks verified to be as shown in Section B-B on Sheet C-2.
- Chuck verified Contractor to relocate existing site lights from adjacent parking lot and install on new concrete bases, as per plans. Three from 12th Street side – coordinate with SMH & Dammon Engineering.
- Chuck verified top of existing catch basins can be used as benchmark if J.V. Burkes did not establish a benchmark.
- Eric reviewed trees to be removed or remain. Keep as many trees as possible. Remove tallow trees. Preserve oaks and magnolias. Protect trees to remain. Minimize machine work.
- Eric noted benches are to be six feet in length.
- Eric advised to bring grade up from existing as required, but to minimize fill required in general. Do not dump or store fill on areas not to be filled.
- Barry advised Bidders of SMH policy of not publishing project budgets.

SITE TOUR:










- Gas line observed on site, contractor to coordinate with utility company and remove.
- Sewage clean out observed on site. Contractor to coordinate with City of Slidell for any action required and with Dammon Engineering.

- J. V. Burkes benchmark observed in power pole, marked JVB019.
- Contract Eric McQuiston, Landscape architect, prior to three/shrub removal to coordinate on site meeting and tree flagging.
- Contractor staging areas to be on site.
- Site tour concluded at 1:30 pm.

Pre-Bid Attendance Sign In Sheet

Name (Please Print)	Signature	Company	Phone Number	E-mail Address
Randy Whiters		SMH Air Mgmt	985-649-8520	Whitersb@SMHFla.com
Eric McQuisler		Ene McQuisler LLC	985-789-9468	ermcquist@qee.com
Ashley Canulette		SMH - MM	985-649-8608	canulettea@smt.com
Wile Garza		D.L. DAIGLE Const.	504-628-9094	wle.roconst@gmc.com
LONNIE REYNOLDS		Dura Heavy Const.	985-875-2164	lreynolds@durahc.com
JEFF PITTMAN		Const 2 Const	985-960-2380	jeffpittman@mac.com
JANE SCHRÖDER		FHP TECTORUS Corp.	(504) 592-9298	DIVISION@FHT.com PH 504
John Finch		John G. Finch Const.	985-960-5018	finchconst@bellcast.com
DAVID KAUFMAN JR		KB. KAUFMAN	985-649-7381	davejr@kkaufman.com
LOUIS REBELLIUS		CONCRETE AND SOIL	504-814-2900	L.REBELLIUS@CONCRETEANDSOIL.com
Brent Ragusa		Brent Const.	781-478-3500	Brentml@bellsouth.net
CHRIS COMBS		CM COMBS CONST	985-264-7125	CCOMBS@CMCOMBSCONSTRUCTION.com
ROD KOROLO		RKCI	643-2427x106	Rod.korolob@bellsouth.net
Andrew Kent		RKCI	643-2427x120	Andrew.kent@bellsouth.net
Tiffany Powell		KLMK Group	205-259-1944	tpowell@klmkgroup.com

Pre-Bid Attendance Sign In Sheet

Name (Please Print)	Signature	Company	Phone Number	E-mail Address
Jeff Brewer		KLME	905.261.9200	JBrewer@klme.com
Mike NATAL		MNATAL contractor	985-649-2713	patricia@mnatal.com
Ben Galloway		SMH	985-639-8911	
Toni Blue		SMH	985-639-8956	
Kenneth Decker		Excibur International, LLC	985-646-1211	kidecker@excint.com
CHUCK DANNON		DANNON BRY	649-5832	DANNON@BETS.com
Stephen Campbell		SMH	985-639-8613	
Roberts, Rick		DANNON		
Billica, Ben		SMH	621-1949	