

Attn: Mr. Mohammad



# ST. TAMMANY PARISH SEWERAGE INSPECTION PERMIT RESULTS

DEPARTMENT OF ENVIRONMENTAL SERVICES

P. O. Box 528  
COVINGTON, LA 70434  
PHONE: (985) 898-2535  
FAX: (985) 898-2523  
e-mail: es@stpgov.org

Kevin Davis  
Parish President

1161  
Site Location: ~~2075~~ Colbert St

**Inspection revealed:**

At the time of our limited inspection, the system appears not cause an apparent public health or environmental problem, and a Sewerage Inspection Permit will be issued by the St. Tammany Parish Department of Environmental Services.

System appears to cause an apparent public health or environmental problem for the following reason(s):

- Wet or Saturated Areas
- Effluent Discharge to Ground Surface
- Lush or Unusual Vegetation
- Evidence of Structural Damage
- Un-permitted Septic Tank
- Unauthorized modification to system
- Evidence of Possible System Bypass
- Effluent Discharge to Surface Water
- Septic/Foul Odors
- Aerator not operational
- Proof of system pumping required
- Other: \_\_\_\_\_

Comments: System has solids in the clarifier and contact chamber. Effluent is cloudy with solids.  
When was system pumped, last?

A new sewerage treatment system is required. The owner of the property should contact LA Department of Health and Hospitals, Office of Public Health (LA DHH) at 893-6297 or 646-6448 for a permit to install an On-Site Wastewater Treatment System. A Sewerage Inspection Permit will be issued upon receipt of verification from LA DHH that a new system has been installed (permitted.) It is your responsibility to provide this office with a copy of the permit once the new system is installed.

Please provide this office with proof that your system has been pumped within the last two years. If the system has not been pumped in the last two years, please contact a licensed hauler to have your system pumped. Upon presentation to this office of a receipt from a licensed hauler indicating that the system has been pumped within the last two years, a Sewerage Inspection Permit will be issued.

Maintenance/Repair of the system is required as described above. Please contact this office at 898-2535 when maintenance/repairs are complete for a follow-up inspections.

Inspector Signature: Glenn Daughdell Date: 6/8/10

985 789 8762