

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)

DISCHARGE MONITORING REPORT (DMR)

(2-16) LAGS31453

PERMIT NUMBER

(17-19) 007Y

TOTAL FACILITY DISCHARGE

12345

JAN 28 2022

RECEIVED

(2-16) MONITORING PERIOD


FROM YEAR 21 MO 1 DAY 1

TO YEAR 21 MO 12 DAY 31

F - FINAL
TREATED SANITARY EFFLUENT
AI NO. 36357
 No Discharge

ENFORCEMENT DIVISION

NOTE: Read instructions before completing this form.

PARAMETER (22-27)	MEASUREMENT	QUANTITY OR LOADING (3 Card Only) (46-53)			UNITS	QUALITY OR CONCENTRATION (4 Card Only) (38-45)			UNITS	NO. EX. (62-63)	FREQUENCY OF ANALYSIS (64-66)	SAMPLE TYPE (69-70)
		AVERAGE	MAXIMUM	MINIMUM		AVERAGE	MAXIMUM	MINIMUM				
BOD	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	*****	*****	*****	1	1/365	GR
5-DAY (20 DEG C)	PERMIT	*****	*****	*****	*****	*****	*****	*****	*****	0	999	GR
00310 1 0 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	*****	*****	*****	0	999	GR
EFFLUENT GROSS VALUE	PERMIT	*****	*****	*****	*****	*****	*****	*****	*****	1	1/365	GR
TOTAL SUSPENDED SOLIDS	PERMIT	*****	*****	*****	*****	*****	*****	*****	*****	0	999	GR
00530 1 0 0	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	*****	*****	*****	0	999	GR
EFFLUENT GROSS VALUE	PERMIT	*****	*****	*****	*****	*****	*****	*****	*****	0	999	GR
THRU TREATMENT PLANT	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	*****	*****	*****	0	999	GR
50050 1 0 0	PERMIT	*****	*****	*****	*****	*****	*****	*****	*****	0	999	GR
EFFLUENT GROSS VALUE	PERMIT	*****	*****	*****	*****	*****	*****	*****	*****	0	999	GR
COLIFORM, FECAL GENERAL	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	*****	*****	*****	0	999	GR
74055 1 0 0	PERMIT	*****	*****	*****	*****	*****	*****	*****	*****	0	999	GR
EFFLUENT GROSS VALUE	PERMIT	*****	*****	*****	*****	*****	*****	*****	*****	0	999	GR
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER M. Roch Houlias Owner TYPED OR PRINTED												
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT 												
										TELEPHONE		DATE
										985 893-9922		2021 18

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

FLOW=52365, PH= 3365, BOD & TSS MX EXCEPTION DATES 12/9

EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

During the period beginning with written notification of coverage under this permit and lasting through the expiration date of this permit, the permittee is authorized to discharge treated sanitary wastewater and/or other accepted wastewater totaling less than 2,500 gallons per day maximum expected flow from the specified facility in accordance with the following limitations:

SCHEDULE A¹ – FINAL EFFLUENT LIMITATIONS

EFFLUENT CHARACTERISTICS	DISCHARGE LIMITATIONS		MONITORING REQUIREMENTS	
	MONTHLY AVERAGE	DAILY MAXIMUM	MEASUREMENT FREQUENCY ²	SAMPLE TYPE
FLOW – GPD	N/A	REPORT	1/12 months	Estimate
BOD ₅	N/A	45 mg/l	1/12 months	Grab
TSS ³	N/A	45 mg/l	1/12 months	Grab
FECAL COLIFORM ^{4&5}	N/A	400 cfu/100 ml	1/12 months	Grab
pH – allowable range (standard units) ⁶	6.0 s.u. (min)	9.0 s.u. (max.)	1/12 months	Grab

- ¹ Upon written notification of coverage under this permit, the permittee shall comply with the effluent limitations schedule(s) stated in Appendix A of the permit authorization. Schedule A will apply to facilities that discharge less than 2,500 GPD and have no food service waste, laundromat wastewater, nor are regulated under LAC 33:IX.2511.B.14.
- ² Certain facilities of concern are subject to a monitoring frequency of 1/6 months. Instructions will be given in the cover letter and/or Appendix A of the permit authorization if this condition is applicable to the permittee.
- ³ If the treatment unit is an oxidation pond, the daily maximum limitation may be 135 mg/L. If this limit applies, it will be noted in Appendix A of the permit authorization.
- ⁴ If chlorination is chosen as the disinfection method, see Part II, Section H.
- ⁵ If the discharge is directly to a waterbody which is named in the LAC 33:IX.1123.Table 3, and which has a designated use of oyster propagation, the fecal coliform limitations will be 200 cfu/100 ml daily maximum. Appendix A of the permit authorization states if the more stringent limitations apply.
- ⁶ The pH shall not be less than 6.0 standard units nor greater than 9.0 standard units. The permittee shall report both the minimum and maximum instantaneous pH values measured.

There shall be no discharge of floating or settleable solids or visible foam in other than trace amounts, nor of free oil or other oily material, nor of toxic materials in quantities such as to cause acute toxicity to aquatic organisms. Furthermore, there shall be no visible sheen or stains attributable to this discharge. There shall be no accumulation of solids in the drainage system as a result of this operation that have the potential to have a negative impact on aquatic life or drainage.

Publicly Owned Treatment Works (POTWs) shall not be eligible for coverage under Schedule A.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the following location:

Outfall 001, at the point of discharge from the last treatment unit prior to mixing with other waters and, if applicable, any additional outfalls listed in Appendix A of the permit authorization.