

From: **Hoppy Allred** hoppy@allredarchitecturalgroup.com  
 Subject: RE: Joseph Greene Hall  
 Date: March 12, 2018 at 1:18 PM  
 To: Joe Legge jlegge@corbettlegge.com, Wayne Hilliard whilliard@idnacme.com



Joe / Wayne:

Here is a list of all Door Numbers and their associated Hardware Numbers that are to rec've access controls (43 Total).

Door Number:	Hardware Number:	
108A	29	
115	21	
155A	1	
156A	1	
129	29	1-6
133	15	9-2
150A	15	
150B	15	
146A	1	13-2
139	15	
140A	15	15-14
140B	15	
143A	15	21-6
143B	15	
144A	15	22-4
144B	15	
141A	1	23-2
168	23	
162	23	27-6
159A	1	
157A	1	30-1
216	21	
238	15	
239	29	
214	21	
243	15	
245	15	
247A	13	
247B	13	
268	21	
269A	29	
269B	29	
324	21	
330	30	
343	22	
334	29	
335	15	
336	22	
346A	22	
348A	22	
349A	9	
349B	9	
362	21	

21

31

47

Room 336  
 Cards been  
 12 & 13

✓	108A	Set 29.0
✓	115	Set 21.0
✓	129	<del>Set 47.0</del> 29.0
✓	133	34.0
✓	139	Set 48.0
?	✓ 140A	Set 20.0
?	✓ 140B	Set 20.0
✓	141A	Set 1.0
✓	143A	Set 15.0
✓	143B	Set 15.0
✓	144A	Set 15.0
✓	144B	Set 15.0
✓	146A	Set 1.0
✓	150A	Set 15.0
✓	150B	Set 15.0
✓	155A	Set 1.0
✓	156A	Set 1.0
✓	157A	Set 1.0
✓	159A	Set 1.0
✓	162	Set 23.0
✓	168	Set 23.0
?	A100A	Reader Set 3.0
?	A110	Set 6.0

- ✓ 214 Set 21.0
- ✓ 216 Set 21.0
- ? 229
- ✓ 238
- ✓ 239
- ✓ 243 Set 34.0
- ✓ 245
- ✓ 247A Set 13.0
- ✓ 247B Set 13.0
- ✓ 268A
- 268B Set 34.0
- ✓ 269B
- ✓ 269A

✓ 324	Set 21.0
✓ 330	Set 30.0
✓ 334	Set 35.0
✓ 335	
<del>339</del>	
✓ 343	Set 22.0
✓ 346A	Set 22.0
✓ 348A	Set 22.0
✓ 349A	Set 9.0
✓ 349B	Set 9.0
349C	Set 14.0
350	Set <del>25</del> 21.0
✓ 362	
✓ 336A	

Pair of Doors

Pair  
Door Set 1: 155A, 156A, 146A, 141A, 157A, 159A  
Exit Device with Electric Lock Retractor  
Door Position Switch  
Card Reader

EPT Power Transfer Device

Pair  
Set 9: Pair of Doors 349A, 349B  
Exit Device with Electric Lock Retractor  
Door Position Switch  
Card Reader

EPT Power Transfer Device

Set  
Set 13: 247A, 247B  
Exit Device w/ Electric Lock Retractor  
Door Position Switch  
Card Reader

EPT Power Transfer Device

Set  
Set 15: 133, 150A, 150B, 139, 140A, 140B, 143A, 143B  
144A, 144B, 238, 243, 245, 335

Electric Lock

Card Reader

EPT Power Transfer Device

Door Position Switch

Motion Sensor

Set  
Set 21: 115, ~~216~~ 216, 214, 268, 324, 362  
Exit Device w/ Electric Lock Retractor  
Card Reader

EPT Power Transfer Device

Door Position Switch

Jan

Set 22: 343, 336, ~~346A~~, ~~348A~~  
K4A Device

Set 23: 162, 168

Set 29: 108A, 129, 239, 269A, 269B, 334

Set 30: 330

# Joseph Greene Hall

## Hardware Set 1      Doors: 141A, 146A, 155A, 156A, 157A, 159A

### Pair of Doors

- 2 each Rim Exit Devices w/ Electric Latch Retractors
- 1 each Removable Mullion (should show this but doesn't have anything electrical)
- 2 each Door Transfer Hinges
- 1 each Card Reader
- 1 each Power Supplies (supplied by Hardware Supplier)
- 2 each Door Position Switches
- 2 each Auto Door Operators (being supplied by Hardware Supplier but needs to be wired to the Access Control System)

## Hardware Set 9      Doors: 349A, 349B

### Pair of Doors

- 1 each Mortise Exit Devices w/ Electric Latch Retractors
- 1 each Door Transfer Hinges
- 1 each Card Reader
- 1 each Power Supplies (supplied by Hardware Supplier)
- 1 each Door Position Switches
- 1 each Push Button Emergency by podium (Provided by Hardware Supplier)

## Hardware Set 13      Doors: 247A, 247B

### Single Doors

- 1 each Rim Exit Devices w/ Electric Latch Retractors
- 1 each Door Transfer Hinges
- 1 each Card Reader
- 1 each Power Supplies (supplied by Hardware Supplier)
- 1 each Door Position Switches

1 each Push Button Emergency by podium (Provided by Hardware Supplier)

**Hardware Set 15 Doors: 133, 139, 140A, 140B, 143A, 143B, 144A, 144B, 150A, 150B, 238, 243, 245, 335**

Single Doors

1 each Electrified Mortise Lock  
1 each Door Transfer Hinges  
1 each Card Reader  
2 each Power Supplies (supplied by Hardware Supplier)  
(for somereason this Hardware Set is calling for 2 each power supplies, supplied by Hardware Supplier.  
Might want to verify it's use?)  
1 each Door Position Switches  
1 each Push Button Emergency by podium (Provided by Hardware Supplier)

**Hardware Set 21 Doors: 115, 214, 216, 268, 324, 362**

Single Doors

1 each Rim Exit Devices w/ Electric Latch Retractors  
1 each Door Transfer Hinges  
1 each Card Reader  
1 each Power Supplies (supplied by Hardware Supplier)  
1 each Door Position Switches

**Hardware Set 22 Doors: 336, 343, 346A, 348A**

Pair of Doors

1 each Electrified Mortise Lock  
1 each Door Transfer Hinges  
1 each Card Reader  
1 each Power Supplies (supplied by Hardware Supplier)  
1 each Door Position Switches  
1 each Push Button Emergency by podium (Provided by Hardware Supplier)

**Hardware Set 23      Doors: 162, 168**

Pair of Doors

- 2 each Rim Exit Devices w/ Electric Latch Retractors
- 1 each Removable Mullion (should show this but doesn't have anything electrical)
- 2 each Door Transfer Hinges
- 1 each Card Reader
- 1 each Power Supplies (supplied by Hardware Supplier)
- 2 each Door Position Switches
- 1 each Push Button Emergency by podium (Provided by Hardware Supplier)

**Hardware Set 29      Doors: 108A, 126, 239, 269A, 269B, 334**

Single Door

- 1 each Electrified Mortise Lock
- 1 each Door Transfer Hinges
- 1 each Card Reader
- 1 each Power Supplies (supplied by Hardware Supplier)
- 1 each Door Position Switches
- 1 each Motion Sensor

**Hardware Set 30      Doors: 330**

Single Door

- 1 each Electrified Mortise Lock
- 1 each Door Transfer Hinges
- 1 each Card Reader
- 1 each Power Supplies (supplied by Hardware Supplier)
- 1 each Door Position Switches
- 1 each Push Button Emergency by podium (Provided by Hardware Supplier)
- 1 each Motion Sensor