

PANEL SCHEDULE

CUT THIN MIRE NO SIZE	LOAD DESCRIPTION LOCATION	BREAKER AMP POLE	LOAD (VA)	NO. OF CIRCUITS			BREAKER AMP POLE	LOAD DESCRIPTION LOCATION	THIN MIRE NO SIZE	
				A	B	C				
1	RECEPTACLES AT THE RECEPTION AREA	20	340	1	1	0	20	RECEPTACLES, VENTILATION AND LIGHTING	#2 2	
3	RECEPTACLES AT THE RECEPTION AREA	20	340	1	1	0	20	DEDICATED RECEPTACLE	#2 4	
5	RECEPTACLES RECEPTION ROOM	20	120	1	1	0	20	RECEPTACLES RECEPTION ROOM	#2 6	
7	RECEPTACLES RECEPTION ROOM	20	1000	1	1	0	20	RECEPTACLES LEFT SIDE OF RECEPTION ROOM THROUGH	#2 8	
9	RECEPTACLES JANET LAUNDRY	20	120	1	1	0	20	RECEPTACLES AT JANET LAUNDRY	#2 10	
11	RECEPTACLES JANET LAUNDRY	20	120	1	1	0	20	RECEPTACLE DRY CENTER IN JANET LAUNDRY	#2 12	
13	RECEPTACLES JANET LAUNDRY	20	120	1	1	0	20	DEDICATED RECEPTACLE JANET LAUNDRY	#2 14	
15	RECEPTACLES JANET LAUNDRY	20	120	1	1	0	20	DEDICATED RECEPTACLE JANET LAUNDRY	#2 16	
17	RECEPTACLES JANET LAUNDRY	20	120	1	1	0	20	DRINKING FOUNTAIN IN JANET LAUNDRY	#2 18	
19	GAS WATER HEATER (GHW) FOR WATER HEATER ROOM AND A/C	20	500	1	1	0	20	ELEVATOR CONTROL POWER	#2 20	
21	RECEPTACLES JANET LAUNDRY	20	500	1	1	0	20	DEDICATED RECEPTACLE IN ELEVATOR PIT	#2 22	
23	RECEPTACLES JANET LAUNDRY	20	484	1	1	0	20	RECEPTACLE IN ELEVATOR PIT	#2 24	
25	RECEPTACLES JANET LAUNDRY	20	641	1	1	0	20	2000	#2 26	
27	RECEPTACLES JANET LAUNDRY	20	641	1	1	0	20	2000	#2 28	
29	RECEPTACLES JANET LAUNDRY	20	641	1	1	0	20	2000	#2 30	
31	RECEPTACLES JANET LAUNDRY	20	641	1	1	0	20	2000	#2 32	
33	RECEPTACLES JANET LAUNDRY	20	641	1	1	0	20	2000	#2 34	
35	RECEPTACLES JANET LAUNDRY	20	641	1	1	0	20	2000	#2 36	
37	RECEPTACLES JANET LAUNDRY	20	641	1	1	0	20	2000	#2 38	
39	RECEPTACLES JANET LAUNDRY	20	641	1	1	0	20	2000	#2 40	
41	RECEPTACLES JANET LAUNDRY	20	641	1	1	0	20	2000	#2 42	
			TOTAL CONNECTED LOAD (VA) 44,468						GROUND BUS	
			AD - 16,344						BD - 13,698	
									CD - 14,426	

PANEL SCHEDULE

CUT THIN MIRE NO SIZE	LOAD DESCRIPTION LOCATION	BREAKER AMP POLE	LOAD (VA)	NO. OF CIRCUITS			BREAKER AMP POLE	LOAD DESCRIPTION LOCATION	THIN MIRE NO SIZE	
				A	B	C				
1	COOK TOP TWO BURNER, SUITE 101	30	2400	1	1	0	20	SPACE	#2 2	
3	COOK TOP TWO BURNER, SUITE 102	30	2400	1	1	0	20	SPACE	#2 4	
5	COOK TOP TWO BURNER, SUITE 103	30	2400	1	1	0	20	REFRIGERATOR AND COUNTER RECEPTACLES, SUITE 103	#2 6	
7	COOK TOP TWO BURNER, SUITE 104	30	2400	1	1	0	20	SPACE	#2 8	
9	COOK TOP TWO BURNER, SUITE 105	30	2400	1	1	0	20	SPACE	#2 10	
11	COOK TOP TWO BURNER, SUITE 106	30	2400	1	1	0	20	SPACE	#2 12	
13	COOK TOP TWO BURNER, SUITE 107	30	2400	1	1	0	20	SPACE	#2 14	
15	COOK TOP TWO BURNER, SUITE 108	30	2400	1	1	0	20	SPACE	#2 16	
17	COOK TOP TWO BURNER, SUITE 109	30	2400	1	1	0	20	SPACE	#2 18	
19	COOK TOP TWO BURNER, SUITE 110	30	2400	1	1	0	20	SPACE	#2 20	
21	COOK TOP TWO BURNER, SUITE 111	30	2400	1	1	0	20	SPACE	#2 22	
23	COOK TOP TWO BURNER, SUITE 112	30	2400	1	1	0	20	SPACE	#2 24	
25	COOK TOP TWO BURNER, SUITE 113	30	2400	1	1	0	20	SPACE	#2 26	
27	COOK TOP TWO BURNER, SUITE 114	30	2400	1	1	0	20	SPACE	#2 28	
29	COOK TOP TWO BURNER, SUITE 115	30	2400	1	1	0	20	SPACE	#2 30	
31	COOK TOP TWO BURNER, SUITE 116	30	2400	1	1	0	20	SPACE	#2 32	
33	COOK TOP TWO BURNER, SUITE 117	30	2400	1	1	0	20	SPACE	#2 34	
35	COOK TOP TWO BURNER, SUITE 118	30	2400	1	1	0	20	SPACE	#2 36	
37	COOK TOP TWO BURNER, SUITE 119	30	2400	1	1	0	20	SPACE	#2 38	
39	COOK TOP TWO BURNER, SUITE 120	30	2400	1	1	0	20	SPACE	#2 40	
41	COOK TOP TWO BURNER, SUITE 121	30	2400	1	1	0	20	SPACE	#2 42	
			TOTAL CONNECTED LOAD (VA) 56,000						GROUND BUS	
			AD - 18,000						BD - 18,000	
									CD - 18,000	

PANEL SCHEDULE

CUT THIN MIRE NO SIZE	LOAD DESCRIPTION LOCATION	BREAKER AMP POLE	LOAD (VA)	NO. OF CIRCUITS			BREAKER AMP POLE	LOAD DESCRIPTION LOCATION	THIN MIRE NO SIZE	
				A	B	C				
1	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 2	
3	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 4	
5	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 6	
7	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 8	
9	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 10	
11	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 12	
13	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 14	
15	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 16	
17	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 18	
19	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 20	
21	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 22	
23	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 24	
25	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 26	
27	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 28	
29	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 30	
31	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 32	
33	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 34	
35	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 36	
37	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 38	
39	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 40	
41	RECEPTACLES AND LIGHTING	20	1800	1	1	0	20	RECEPTACLES AND LIGHTING	#2 42	
			TOTAL CONNECTED LOAD (VA) 22,400						GROUND BUS	
			AD - 1,800						BD - 8,800	
									CD - 11,800	

PANEL SCHEDULE

CUT THIN MIRE NO SIZE	LOAD DESCRIPTION LOCATION	BREAKER AMP POLE	LOAD (VA)	NO. OF CIRCUITS			BREAKER AMP POLE	LOAD DESCRIPTION LOCATION	THIN MIRE NO SIZE	
				A	B	C				
1	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE GAINING ROOM	#2 2	
3	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE GAINING ROOM	#2 4	
5	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE GAINING ROOM	#2 6	
7	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLES LOCKER, OFFICE	#2 8	
9	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK IN LOCKER	#2 10	
11	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK IN LOCKER	#2 12	
13	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLES AT BANK	#2 14	
15	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 16	
17	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 18	
19	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 20	
21	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 22	
23	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 24	
25	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 26	
27	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 28	
29	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 30	
31	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 32	
33	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 34	
35	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 36	
37	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 38	
39	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 40	
41	RECEPTACLES AND LIGHTING	20	1000	1	1	0	20	RECEPTACLE AT BANK	#2 42	
			TOTAL CONNECTED LOAD (VA) 21,048						GROUND BUS	
			AD - 6,810						BD - 9,218	
									CD - 14,920	

PANEL SCHEDULE

CUT THIN MIRE NO SIZE	LOAD DESCRIPTION LOCATION	BREAKER AMP POLE	LOAD (VA)	NO. OF CIRCUITS			BREAKER AMP POLE	LOAD DESCRIPTION LOCATION	THIN MIRE NO SIZE
				A	B	C			
1	COOK TOP TWO BURNER, SUITE 111	30	2400	1	1	0	20	SPACE	#2 2
3	COOK TOP TWO BURNER, SUITE 112	30	2400	1	1	0	20	SPACE	#2 4
5	COOK TOP TWO BURNER, SUITE 113	30	2400	1	1	0	20	REFRIGERATOR AND COUNTER RECEPTACLES, SUITE 113	#2 6
7	COOK TOP TWO BURNER, SUITE 114	30	2400	1	1	0	20	SPACE	#2 8
9	COOK TOP TWO BURNER, SUITE 115	30	2400	1	1	0	20	SPACE	#2 10
11	COOK TOP TWO BURNER, SUITE 116	30	2400	1	1	0	20	SPACE	#2 12
13	COOK TOP TWO BURNER, SUITE 117	30	2400	1	1	0	20	SPACE	#2 14
15	COOK TOP TWO BURNER, SUITE 118	30	2400	1	1	0	20	SPACE	#2 16
17	COOK TOP TWO BURNER, SUITE 119	30	2400	1	1	0	20	SPACE	#2 18
19	COOK TOP TWO BURNER, SUITE 120	30	2400	1	1	0	20	SPACE	#2 20
21	COOK TOP TWO BURNER, SUITE 121	30	2400	1	1	0	20	SPACE	#2 22
23	COOK TOP TWO BURNER, SUITE 122	30	2400	1	1	0	20	SPACE	#2 24
25	COOK TOP TWO BURNER, SUITE 123	30	2400	1	1	0	20	SPACE	#2 26
27	COOK TOP TWO BURNER, SUITE 124	30	2400	1	1	0	20	SPACE	#2 28
29	COOK TOP TWO BURNER, SUITE 125	30	2400	1	1	0	20	SPACE	#2 30
31	COOK TOP TWO BURNER, SUITE 126	30	2400	1	1	0	20	SPACE	#2 32
33	COOK TOP TWO BURNER, SUITE 127	30	2400	1	1	0	20	SPACE	#2 34
35	COOK TOP TWO BURNER, SUITE 128	30	2400	1	1	0	20	SPACE	#2 36
37	COOK TOP TWO BURNER, SUITE 129	30	2400	1	1	0	20	SPACE	#2 38
39	COOK TOP TWO BURNER, SUITE 130	30	2400	1	1	0	20	SPACE	#2 40
41	COOK TOP TWO BURNER, SUITE 131	30	2400	1	1	0	20	SPACE	#2 42