

**403.1 Minimum number of fixtures.**

Plumbing fixtures shall be provided in the minimum number as shown in [Table 403.1](#), based on the actual use of the building or space. Uses not shown in [Table 403.1](#) shall be considered individually by the code official. The number of occupants shall be determined by the [International Building Code](#).

**TABLE 403.1**

**MINIMUM NUMBER OF REQUIRED PLUMBING FIXTURES\*(See [Sections 403.1.1](#) and [403.2](#))**

NO.	CLASSIFICATION	DESCRIPTION	WATER CLOSETS (URINALS: SEE <a href="#">SECTION 424.2</a> )		LAVATORIES		BATHTUBS/ SHOWERS	DRINKING FOUNTAIN (SEE <a href="#">SECTION 410</a> )	OTHER
			MALE	FEMALE	MALE	FEMALE			
1	Assembly	Theaters and other buildings for the performing arts and motion pictures <sup>d</sup>	1 per 125	1 per 65	1 per 200		—	1 per 500	1 service sink
		Nightclubs, bars, taverns, dance halls and buildings for similar purposes <sup>d</sup>	1 per 40	1 per 40	1 per 75		—	1 per 500	1 service sink
		Restaurants, banquet halls and food courts <sup>d</sup>	1 per 75	1 per 75	1 per 200		—	1 per 500	1 service sink
		Casino gaming areas	1 per 100 for the first 400 and 1 per 250 for the remainder exceeding 400	1 per 50 for the first 400 and 1 per 150 for the remainder exceeding 400	1 per 250 for the first 750 and 1 per 500 for the remainder exceeding 750		—	1 per 1,000	1 service sink
		Auditoriums without permanent seating, art galleries, exhibition halls, museums, lecture halls, libraries, arcades and gymnasiums <sup>d</sup>	1 per 125	1 per 65	1 per 200		—	1 per 500	1 service sink