

FOUNDATION PLAN

SCALE: 1/8" = 1'-0"

MARK	SIZE	REINFORCEMENT	REMARKS	ANC BOLT EMBEDMENT
F1	6'-0" SQ x 1'-6" DEEP	(8) # 5's E.W.	DETAIL 1/S3.2	16"
F2	6'-6" SQ x 1'-6" DEEP	(8) # 5's E.W.	DETAIL 2/S3.2	16"
F3	9'-0" SQ x 2'-0" DEEP	(11) # 6's E.W.	DETAIL 4/S3.2	18"
F4	15'-0" x 7'-0" x 1'-6"	# 5's @ 10" O.C. E.W.	DETAIL 5/S3.2	16"
F5	5'-0" SQ x 1'-6" DEEP	(7) # 5's E.W.	DETAIL 3/S3.2	16"
F6	5'-0" SQ x 1'-6" DEEP	(7) # 5's E.W. T&B	SECTION 2/S1.2	12"
F7	7'-0" SQ x 1'-6" DEEP	(9) # 5's E.W. T&B	SECTION 2/S1.2	12"

FOOTING SCHEDULE

CONTRACTOR NOTE:
ALL METAL BUILDING COLUMNS BEAR AT 6" BELOW FINISHED FLOOR.

CONTRACTOR NOTE:

- COLUMN FOOTING SIZES ARE SUBJECT TO CHANGE WHEN FINAL ANCHOR BOLT PLAN WITH COLUMN DESIGN LOADS IS SUBMITTED TO ENGINEER FOR APPROVAL. DO NOT BEGIN FOUNDATION CONSTRUCTION PRIOR TO ANCHOR BOLT SETTING PLAN APPROVAL.
- COLUMN FOOTING ELEVATIONS ARE SUBJECT TO CHANGE WHEN FINAL CIVIL GRADING PLAN IS SUBMITTED TO ENGINEER.
- FOR DIMENSIONS NOT SHOWN SEE ARCHITECTURAL DRAWINGS.

CMU WALL LEGEND


INDICATES 12" CMU WALL w/ #6 VERTICAL REINFORCEMENT @ 32" o.c. FILL CELLS WITH 3,000 PSI CONCRETE

INDICATES 12" CMU WALL w/ #6 VERTICAL REINFORCEMENT @ 48" o.c. FILL CELLS WITH 3,000 PSI CONCRETE

FOR CONTROL JOINTS SEE ARCHITECTURAL DRAWINGS.


P.O. Box 529
22615 Highway 59 North
Robertsdale, Alabama 36567
Office: 251.947.3864
Fax: 251.947.3138

ADAMS STEWART ARCHITECTS, LLC
Architecture, Planning
Interiors, Construction Administration



Tractor Supply Company

2083 Gause Blvd West, Slidell Louisiana 70460



TRACTOR SUPPLY COMPANY

DATE	DESCRIPTION
January 29, 2018	ISSUE FOR SCHEDULE I
March 12, 2018	ISSUE FOR PERMIT
May 11, 2018	ISSUE FOR SCHEDULE II

PROJECT NO: 17-061 / S0318

SHEET NO:
FOUNDATION PLAN
S1.1