

CHANGE PROPOSAL REQUEST

TITLE	Hardware Revisions	PROPOSAL REQUEST NO.	30
PROJECT	North Oaks Rehabilitation and Sports Performance Center	PROJECT NO.	23035
CONTRACTOR	Kent Design Build.	ISSUE DATE / REVISE DATE	03-06-2026
ADDRESS	16675 E Brewster Rd Suite 200, Covington, LA 70433	DISTRIBUTION LIST	<input checked="" type="checkbox"/> OWNER <input checked="" type="checkbox"/> CONTRACTOR <input type="checkbox"/> CONSULTANT <input checked="" type="checkbox"/> FILE

PLEASE SUBMIT AN ITEMIZED PROPOSAL AND ITEMIZED QUOTATIONS FOR SUBCONTRACTED WORK FOR CHANGES IN THE CONTACT SUM AND CONTRACT TIME FOR PROPOSED MODIFICATIONS TO THE CONTRACT DOCUMENTS DESCRIBED HEREIN. ALL WORK SHALL BE SUBJECT TO CURRENT CONTRACT TERMS AND STATUS OF THE WORK. WITHIN FOURTEEN (14) DAYS, THE CONTRACTOR MUST SUBMIT THIS PROPOSAL OR NOTIFY THE ARCHITECT, IN WRITING, OF THE DATE ON WHICH PROPOSAL SUBMISSION IS ANTICIPATED.

THIS IS NOT A CHANGE ORDER, A CONSTRUCTION CHANGE DIRECTIVE OR A DIRECTION TO PROCEED WITH THE WORK DESCRIBED IN THE PROPOSED MODIFICATION.

DESCRIPTION

(INSERT A WRITTEN DESCRIPTION OF THE WORK)

Provide all labor, materials, equipment and incidentals for the following revisions to the door hardware and access control.

1. The following doors have been revised to include auto openers, with card reader access on the lobby side and push button access on the gymside. Provide all necessary hardware;
Doors 101 & 138a
2. Door 201 has been revised to include an auto opener with push button activation on either side of the door. Provide all necessary hardware.
3. Doors 133 & 211 has been revised to include a card reader and the necessary hardware.
4. The following doors have been revised from Passage lock to Privacy lock;
121, 224
5. The following doors have been revised from Classroom lock to Passage lock;
Doors 201 & 217
6. The following doors have been revised from Passage lock to Classroom lock;
228, 229, 231, 232
7. The following doors have been revised from Passage lock to Office lock;
Door 237
8. The following doors have been revised from Storeroom lock to Classroom lock;
Doors 208, 209, 219, 220, 221, 239
9. The following doors have been revised from Storeroom lock to Privacy lock;
Door 226
10. The following doors have been revised from Classroom lock to Office lock;
Door 211

11. The following doors have been revised from Multi-Point lock to Mag lock;
Door 138a

ATTACHMENTS

(LIST ATTACHED DOCUMENTS THAT SUPPORT DESCRIPTION)

REQUESTED BY THE ARCHITECT

Richard Longman

(PRINTED NAME AND TITLE)

Auto-Opener Spec,