FILE NAME: J:\... Commercial\Kathleen Day Care\Current Drawings\103 - PNL SCHEDULE.dwg PLOT DATE & TIME: Tuesday, September 30, 2025 @ 4:10:09 PM

PANEL: PNL A (EXISTING)
LOCATION: ELEC. RM. 113
FEEDER SOURCE: SERVICE PROVIDER

VOLTAGE: 208/120V, 225A 3Ø, 4W
ENCLOSURE: RECESSED W/EQUIPMENT GND BAR
BOLT-ON BRK 22000 AIC, MLO

CKT. NO.	THHN WIRE SIZE	LOAD DESCRIPTION / LOCATION	BREAKER AMP	BREAKER POLE	LOAD (kva)	AØ BØ CØ	LOAD (kva)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION / LOCATION	THHN WIRE SIZE	CKT. NO.
1	#12	LIGHTING, SOUTHWEST	20	1	1.3		-	1	20	SPARE	#12	2
3	#12	OUTLETS, SW	20	1	0.9		1.3	1	20	SW OUTLETS	#12	4
5	#12	SPARE	20	1			1.0	1	20	LIGHTING, SOUTHEAST	#12	6
7	#12	OUTLETS, SW	20	1	0.9		1.0	1	20	LIGHTING CENTER	#12	8
9	#12	WASHING MACHINE	20	1	0.7		-	1	20	SPARE	#12	10
11	#12	LIGHTING, CENTER	20	1	0.7		-	1	20	SPARE	#12	12
13	#12	OUTLETS, SE	20	1	1.3		-	1	20	SPARE	#12	14
15	#12	SPARE	20	1	-		1.1	1	20	SE OUTLETS	#12	16
17	#12	LIGHTING, NORTHWEST	20	1	0.8		-	1	20	SPARE	#12	18
19	#12	REFRIGERATOR OUTLETS	20	1	1.3		-	1	20	SPARE	#12	20
21	#12	OUTLETS, SE	20	1	1.3		-	1	20	SPARE	#12	22
23	#12	OUTLETS, CENTER	20	1	1.3		-	1	20	SPARE	#12	24
25	#12	OUTLETS, NE	20	1	1.1		-	1	20	SPARE	#12	26
27	#12	SPARE	20	1	-		-	1	20	SPARE	#12	28
29	#12	SPARE	20	1	-		1.0	1	20	LIGHTING, NORTHEAST	#12	30
31	#12	SPARE	20	1	-		1.1	1	20	N OUTLETS	#12	32
33	#12	LIGHTING, EXTERIOR	20	1	0.6		1.3	1	20	N OUTLETS	#12	34
35	#12	TIMECLOCK	20	1	0.6		1.3	1	20	NW OUTLETS	#12	36
37	#12	SPARE	20	1	-		1.3	1	20	NW OUTLETS	#12	38
39		SPACE					2.1	2	30	DUCTLESS MINI-SPLIT	#12	40
41		SPACE					2.1					42

SOLID NEUTRAL
NEUTRAL WIRE (W)

TOTAL CONNECTED LOAD (kva)= 27.4
AØ=9.3 | BØ=9.3 | CØ=8.8

GROUND BUS
GROUND WIRE (G)

PANEL: PNL B (EXISTING)
LOCATION: ELEC. RM. 113
FEEDER SOURCE: SERVICE PROVIDER

VOLTAGE: 208/120V, 225A 3Ø, 4W
ENCLOSURE: RECESSED W/EQUIPMENT GND BAR
BOLT-ON BRK 22000 AIC, MLO

CKT. NO.	THHN WIRE SIZE	LOAD DESCRIPTION / LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	AØ BØ CØ	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION / LOCATION	THHN WIRE SIZE	CKT. NO.
1	#10	VVT #1, 5kw Heat	30	2	2.5		4.0	2	50	OVEN	#6	2
3					2.5		4.0					4
5	#10	VVT #2, 5kw Heat	30	2	2.5							6
7					2.5							8
9	#10	VVT #3, 5kw Heat	30	2	2.5		4.0	2	50	OVEN	#6	10
11					2.5		4.0					12
13	#10	VVT #4, 4kw Heat	30	2	2.0		-	-	-	BLANK	-	14
15					2.0		-	-	-	BLANK	-	16
17	#10	WATER HEATER	30	2	2.5		-	-	-	BLANK	-	18
19					2.5		-	-	-	BLANK	-	20
21	#10	VVT #5, 3.5kw Heat	30	2	1.7		-	-	-	BLANK	-	22
23					1.7		-	-	-	BLANK	-	24
25	#10	VVT #6, 5kw Heat	30	2	2.5		-	-	-	BLANK	-	26
27					2.5		-	-	-	BLANK	-	28
29	#10	VVT #7, 5kw Heat	30	2	2.5		-	-	-	BLANK	-	30
31					2.5		-	-	-	BLANK	-	32
33	-	BLANK	-	-	-		-	-	-	BLANK	-	34
35	-	BLANK	-	-	-		-	-	-	BLANK	-	36
37	#12	SPARE	20	1	-		-	-	-	BLANK	-	38
39	#10	Clothes Dryer	30	2	2.5		-	1	20	SPARE	#12	40
41					2.5		-	1	20	SPARE	#12	42

SOLID NEUTRAL
NEUTRAL WIRE (W)

TOTAL CONNECTED LOAD (kva)= 56.2
AØ=18.5 | BØ=21.7 | CØ=16.2

GROUND BUS
GROUND WIRE (G)



ELEC. RISER DIAGRAM

N.T.S.

ELECTRICAL ONE LINE DIAGRAM NOTES: (#)

1. EXISTING 200A FUSED DISCONNECT TO REMAIN.
2. EXISTING 200A DISCONNECT FUSED AT 150A TO REMAIN.
3. EXISTING 225A 120/208V 3Ø PANEL TO REMAIN. LOCATED IN ROOM #113
4. DEMO 120/208 1Ø 150A LOAD CENTER WITH MAIN BREAKER.
5. NOT USED.
6. EXISTING GRND ROD, GRND WIRE, AND PVC CONDUIT TO REMAIN.
7. ALL EXISTING ELECTRICAL SERVICE EQUIPMENT TO REMAIN.

DAMMON ENGINEERING, INC.
LOUISIANA & MISSISSIPPI
www.dammonengineering.com
info@dammonengineering.com
PH: 985.649.5832
Chief Engineer: Brian Mistich, PE
554 Old Spanish Trail
Slidell, LA 70458

REVISIONS

#	DESCRIPTION	DATE

SEAL:

STATE OF LOUISIANA
BRIAN A. MISTICH
License No. 30187
PROFESSIONAL ENGINEER

NEW DAYCARE
THREE PEAS IN A POD EARLY LEARNING CENTER
2165 GAUSE BLVD.
SLIDELL, LA 70461

JOB No: 2511
DRAWN BY: LJP
DATE: 04-30-2025
CHECKED BY: CKD

The ideas & things and specifications, shapes and arrangements represented shown on this drawing are the property of Dammon Engineering, and no part thereof shall be copied, disclosed to others or used in connection with any work or project other than the specific project for which they have been prepared by Dammon Engineering. Any such use or reuse, or any alteration of these plans and specifications will be without liability or legal exposure to Dammon Engineering, and Client shall indemnify and hold harmless Dammon Engineering against all claims, damages, losses and expenses including attorney's fees arising out of or resulting therefrom.

SHEET TITLE:
PANEL SCHEDULE

DRAWING NUMBER:
E103

SHEET No: 12 of 12