



GENERAL NOTES:

- THIS SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH:
 - NFPA 17A
 - THE LOUISIANA STATE FIRE MARSHAL'S OFFICE
 - THE MANUFACTURER'S SPECIFICATIONS
- ALL NOZZLES PROVIDED WITH NOZZLE CAPS
- HOOD CANOPY NEW
- DRAWING NOT TO SCALE
- UTILIZING 13 OF 15 FLOW POINTS
- ALL SUPPLY LINE TO BE 3/8 " BLACK SCHEDULE 40 PIPE
- ALL BRANCH LINE TO BE 3/8 " BLACK SCHEDULE 40 PIPE

**PYRO CHEM
PCL 460
WET CHEMICAL
UL 300 LISTED**

**SYSTEM
DETAIL**

BILL OF MATERIALS

QTY.	NAME
1	ASCO GAS SHUT-OFF VALVE
1	RPS PULL STATION
2	1H PLENUM 10" HORZL
5	AUTOMATIC DETECTOR
1	1H GRIDDLE 36"X30" @ 24"-48"L
2	2L RANGE 28"X28" @ 34"-48"
1	2H FRYER 27.75"X18" @ 24"-48"
1	PYRO CHEM PCL 460
1	PYRO CHEM NMHH-3 CONTROLHEAD
2	2D DUCT LESS THAN 100" MAX

**GONZO'S SMOKEHOUSE
13899 RIVER ROAD
LULING, LA 70070**



**FIRE AND SAFETY
COMMODITIES**
245 WOODLAND DR
LAPLACE LA 70068
(504) 465-5994
MACE@FIRESAFETYINC.NET
FIRM: F58
LIC. #: E383