



PROJECT NO: 12022	REVIEWER: DKH	DATE: 01.30.2014												
PROJECT NAME: CENTURY PARK SOUTH	<table border="1"> <tr> <th colspan="2">SHOP DRAWING REVIEW</th> </tr> <tr> <td colspan="2">Review is for general compliance with contract documents. It is the contractor's responsibility to provide items that conform to the contract documents. No responsibility is assumed for correctness of dimensions, details, or quantities.</td> </tr> <tr> <td><input type="checkbox"/></td> <td>NO COMMENTS</td> </tr> <tr> <td><input checked="" type="checkbox"/></td> <td>SEE COMMENTS</td> </tr> <tr> <td><input type="checkbox"/></td> <td>RESUBMIT (ONLY AS INDICATED)</td> </tr> <tr> <td colspan="2">BY: David Howe DKH</td> </tr> </table>		SHOP DRAWING REVIEW		Review is for general compliance with contract documents. It is the contractor's responsibility to provide items that conform to the contract documents. No responsibility is assumed for correctness of dimensions, details, or quantities.		<input type="checkbox"/>	NO COMMENTS	<input checked="" type="checkbox"/>	SEE COMMENTS	<input type="checkbox"/>	RESUBMIT (ONLY AS INDICATED)	BY: David Howe DKH	
SHOP DRAWING REVIEW														
Review is for general compliance with contract documents. It is the contractor's responsibility to provide items that conform to the contract documents. No responsibility is assumed for correctness of dimensions, details, or quantities.														
<input type="checkbox"/>			NO COMMENTS											
<input checked="" type="checkbox"/>			SEE COMMENTS											
<input type="checkbox"/>	RESUBMIT (ONLY AS INDICATED)													
BY: David Howe DKH														
SECTION NO: 280100														
EQUIPMENT MATERIAL DESCRIPTION: 2801003 ACCESS CONTROL_ CAMERA SHOP DRAWINGS														
SUBMITTAL LOG NO: 280100-003 (394)														
<ul style="list-style-type: none"> ➤ This submittal review lists ALL comments made by the reviewer in regard to the equipment/material listed above. ➤ The submittals have NOT been marked. ➤ A copy of this review must remain with each copy of the submittal. 														

MARK	COMMENTS
SEC-0.1	No Comments
SEC-0.2	No Comments
SEC-0.3	No Comments
SEC-0.4	No Comments
	Building A
SEC-A1	See Comments: ✓ 1. Provide Door Access Type "D2" at door A124b in Elect. A124.
SEC-A2	No Comments
SEC-A3	No Comments
SEC-A4	No Comments
SEC-A5	No Comments
	Building B
SEC-B1	See Comments: ✓ 1. Provide exit fixture in Vestibule B115a. ✓ 2. Provide Public Address Speaker in Laundry B128. ✓ 3. Provide Public Address Speaker in Lounge B126a.
SEC-B2	See Comments: ✓ 1. Provide exterior camera on north side near HC Double B213 as shown on sheet SEC-0.1 and ES100. <i>This was shown on 1st FLOOR</i>
SEC-B3	No Comments
SEC-B4	No Comments
SEC-B5	No Comments

Phone: 662-844-7114 • Fax: 662-844-7138



THE UNIVERSITY OF SOUTHERN MISSISSIPPI

Physical Plant Division
118 College Dr. #5058
Hattiesburg, MS 39406

PROJECT: USM Century Park South	OWNER: University of Southern Mississippi	
REVIEWED BY: Stanley Wielgosz	PN: 2012020	DATE: 3/3/2014
SUBMITTAL NO: 280100-003	LOG NO: 394	
SUBMITTAL DESCRIPTION: Access Control_Camera Shop Drawings		

ELECTRONIC SUBMITTAL REVIEW	
<input type="checkbox"/>	NO COMMENTS
<input type="checkbox"/>	SEE COMMENTS
<input checked="" type="checkbox"/>	MAKE CORRECTIONS NOTED
<input type="checkbox"/>	REVISE AND RESUBMIT

Reviewed for design only, errors & omissions excepted, **CONTRACTOR** is responsible for determining quantities, dimensions, and for verifying compliance with all **CONTRACT DOCUMENTS** including coordination of this portion of the work with that of all related trades.

This submittal review lists ALL comments made by the reviewer in regard to the material listed above.

The submittals have NOT been marked unless noted otherwise below.

A copy of this review must remain with each copy of the submittal.

MARK	NOTES
SEC-A2	✓ Provide Door Access Type with motion sensor at door A200b.
SEC-A2	Provide Card Reader (CR), Future Access Device Box (Z), and Pushbutton Door Operator for room A269. <i>Now B7?</i>
SEC-A3	Provide Door Access Type with motion sensor at door A300b & A300d. <i>B3</i>
SEC-A4	Provide Door Access Type with motion sensor at door A400b & A400d. <i>B3</i>
SEC-A5	Provide Door Access Type with motion sensor at door A500b & A500d. <i>B3</i>
SEC-B1	Provide Door Access Type with position sensor at door B135a. <i>B2</i>
SEC-B1	Provide Door Access Type with motion sensor at door B100a. <i>B3</i>
SEC-B2	Position of Future Access (Z) at door B200b. <i>Fixed</i>
SEC-B2	Provide Door Access Type with motion sensor at door B200a & B200b.
SEC-B2	Provide Door Access Type at door B253. <i>Kitchen/Lounge</i>
SEC-B3	Provide Door Access Type "B2" at doors B351, B335, B354, & B315. <i>B2</i>
SEC-B4	Provide Door Access Type "B2" at doors B451, B435, B454, & B415. <i>B2</i>
SEC-C1	Provide Future Access Device Box (Z) at door C100b.
SEC-C1	Provide Card Reader (CR) at door C108b on the inside.
SEC-C1	Provide Door Access Type with motion sensor at door C100a. <i>B3</i>
SEC-C2	Provide Camera in Multi-Purpose Room adjacent from existing camera.
SEC-C2	Provide Door Access Type with motion sensor at door C200a & C213. <i>B3</i>
SEC-C2	Provide Door Type for Lucky Day and C220.

*ALL Lucky Day door type shown on B-2
C 220 is Laundry No security*

SEC-C2	Provide Future Access Device Box (Z) at door C225A.
SEC-C3	Provide Door Access Type with motion sensor at doors C300a & C213 ³¹³ B-3
SEC-C3	No Future Access Device Box (Z) at door C300a.
SEC-C4	Provide Door Access Type with motion sensor at doors C400a & C413 B-3
SEC-C4	No Future Access Device Box (Z) at door C400a.
SEC-C5	Provide Door Access Type with motion sensor at doors C500a & C513 B-3
SEC-C5	No Future Access Device Box (Z) at door C500a.
All Stair Wells	All card readers in stairwells are to be Future Access Device Boxes (Z).
Ground Floor Bedrooms	All bedrooms leading outside should have Card Readers (CR).
All Floors	Make sure all symbols are position & presented correctly.