



ELECTRICAL NOTES (#)	
1	REFER TO TYPICAL EXAM ROOM ON THIS SHEET FOR DEVICE LAYOUT.
2	COORDINATE MOUNTING OF DEVICES AND ROUTING OF CONDUIT WITH MILLWORK PROVIDER PRIOR TO INSTALLATION.
3	1" CONDUITS WITH CABLE INDICATED TO NEAREST WALL WITH ACCESSIBLE CEILING. STUB UP A MINIMUM OF 6" ABOVE CEILING.
4	DISTRESS BUTTON. VERIFY LOCATION WITH OWNER/ARCHITECT PRIOR TO INSTALLATION.
5	3/4" CONDUIT WITH CABLE TO COMMUNICATION BACKBOARD.
6	REFER TO TYPICAL OFFICE ON THIS SHEET FOR DEVICE LAYOUT.
7	REFER TO TYPICAL PRIVATE ROOM ON THIS SHEET FOR DEVICE LAYOUT.
8	REFER TO TYPICAL BAY ROOM ON THIS SHEET FOR DEVICE LAYOUT.
9	REFER TO TYPICAL CUBICLE ROOM ON THIS SHEET FOR DEVICE LAYOUT.
10	1" CONDUIT WITH NURSE CALL CABLING TO NEAREST WALL WITH ACCESSIBLE CEILING. STUB UP MINIMUM OF 6" ABOVE CEILING.
11	CONNECT DOOR HARDWARE TO FIRE ALARM SYSTEM. DOOR TO BE RELEASED UPON ACTIVATION OF FIRE ALARM SYSTEM.
12	TOUCHLESS DOOR AUTOMATIC OPERATOR. SEE DETAIL.
13	1 1/4" CONDUIT WITH CABLE PER PNEUMATIC TUBE SYSTEM MANUFACTURER'S REQUIREMENTS TO COMMUNICATIONS BACKBOARD.

1 LEVEL 5 - SPECIAL SYSTEMS PLAN
 SCALE: 1/8" = 1'-0" (REFER TO ARCHITECTURAL DRAWINGS FOR ALL DIMENSIONS)