



Bobby Jindal
GOVERNOR

STATE OF LOUISIANA
DEPARTMENT OF HEALTH AND HOSPITALS



Alan Levine
SECRETARY

July 11, 2008

Mr. Emmett G. Dammon, Jr., P.E.
1095 Florida Avenue
Slidell, LA 70458

Re: Village Lakes Subdivision Wastewater Treatment Facility
Extended Aeration Wastewater Treatment Plant Comprised of 1 Aeration Basin with an Aeration Chamber Volume of Approximately 61,261 Gallons and One 4-hopper Final Clarifier with a Total Surface Area of Approximately 400 Square Feet and Final Clarifier Weir Effective Length of 20 Feet to Accept Sewerage Generated **ONLY** from:

➤ Lots 1-147 Located in Village Lakes Subdivision (Single-family Residences)

Equalization Basin

Tablet Chlorinator

Chlorine Contact Chamber with an Effective Volume of Approximately 2,693 Gallons

Proposed Discharge Path: Outfall Piping from Chlorine Contact Chamber into 100-foot Public Drainage Servitude along Draughan Creek

6-Foot Tall Solid Board Fence with Lockable Gate Enclosing Wastewater Treatment Facility

Latitude N30.46634'; Longitude W90.98863'

South of and Fronting Magnolia Bridge Road, East of Willow Creek Drive

Central, Louisiana

East Baton Rouge Parish

Letter of "No Objection"

Dear Mr. Dammon:

Our review has indicated that the plans and specifications are substantially in accord with the requirements of the Louisiana Administrative Code (LAC). The LAC requires that plans and specifications for projects such as yours be approved by this Department prior to construction. However, it has come to our attention that construction on this project has already started or has been completed. Therefore, we cannot give an unconditional approval, but we offer "no objection" to this project.

This letter of "no objection" refers to sanitary features of the design only, and is not to be taken as an approval of structural details, except insofar as they may affect sanitation.

This letter of "no objection" is issued with the stipulation that the wastewater treatment facility will be owned, operated, and maintained by:

Titan Development Group, LLC
11637 Wintergreen Drive
Zachary, LA 70791

The plans and specifications are being sent to the East Baton Rouge Parish Health Unit.

This letter of "no objection" is automatically canceled if construction of the project has not been started within two (2) years after the date of this letter.

After construction is completed, the person or organization responsible for the design of the project shall submit a Confirmation Letter to this Office (Capitol Region II Office of Public Health, 7173-A Florida Blvd., Baton Rouge, LA 70806) certifying that the project was constructed in accordance

OFFICE OF PUBLIC HEALTH • CAPITOL REGION 2
7173-A FLORIDA BLVD. • BATON ROUGE, LOUISIANA 70806
PHONE #: 225/925-7230 • FAX #: 225/925-3832
"AN EQUAL OPPORTUNITY EMPLOYER"



with the plans and specifications approved (or to which "no objection" was issued) by this Office. As of February 1, 2007, this Confirmation Letter will be required prior to occupancy.

If construction commences before a permit is granted, a Notice of Violation will be issued for the project. A letter of "no objection" will not be issued on any pre-constructed project unless the project fully complies with the requirements of the Sanitary Code.

In the event that it is determined at some point in the future that a design error escaped our detection during our review of these plans and specifications, that oversight shall not relieve you, the applicant, of the responsibility for complete compliance with the requirements of the Louisiana Administrative Code [particularly, LAC 51 (Public Health-Sanitary Code) and LAC 48 (Public Health-General)], specifically including correcting the violations inadvertently overlooked.

This letter of "no objection" of plans and specifications takes into consideration only the health aspects of the design. It does not take into account the requirements of any other regulatory agency. Please note that the Louisiana Department of Environmental Quality (LDEQ) may require further treatment to protect water quality.


Please be advised that an effluent discharge permit from the LDEQ is required prior to operation of this wastewater treatment facility. The LDEQ permitting office can be reached at (225) 219-3181. Approval of design will in no way guarantee that the plant will meet discharge requirements of a LDEQ permit. Details of LDEQ permit discharge requirements for your receiving stream should be obtained in advance of the design from LDEQ.

Please be advised that it is the responsibility of the owner of the treatment system to obtain all necessary permits and rights-of-way for the treated effluent to reach public waters. No letter of approval or "no objection" will be issued without proof of such rights-of-way. Authorization to discharge pursuant to the conditions of this approval/letter of "no objection" does not relieve the permittee of any liability for damages to state waters or private property. For discharges to private land, this letter of approval/letter of "no objection" does not relieve the permittee from obtaining approval from the landowner(s) for appropriate easements and rights-of-way.

Please be reminded a permit from the state health officer must be obtained for any modification(s) to this system which changes the system's capacity, effluent quality, point of discharge, hydraulic or contaminant loadings, or operation of the component units of the system prior to beginning construction.

If you have any questions or require additional information, please call me at (225) 925-7230.

Respectfully,



Steven L. Davis, P.E.
Engineer 6

cc: Julie Fourrier, P.E., Engineer, DHH-OPH CEHS
Lakeisha Theriot, R.S., East Baton Rouge Parish Sanitarian Manager
Buddy Stricker, Assistant Administrator, Utilities Division, LPSC
Yanfu Zhao, Manager, Stakeholder Outreach, Office of Environmental Service, LDEQ
Aimee' Killeen, LDEQ
Blake Seguin, Titan Development Group, LLC
Doug Bozeman, Wastewater Treatment Systems & Operations

