PANEL: PNL A (EXISTING)
LOCATION: ELEC. RM. 113
FEEDER SOURCE: SERVICE PROVIDER

VOLTAGE: 208/120V, 225A 3Ø, 4W
ENCLOSURE: RECESSED W/EQUIPMENT GND BAR
BOLT-ON BRK 22000 AIC, MLO

CKT. NO.	THHN WIRE SIZE	LOAD DESCRIPTION / LOCATION	BREAKER AMP	BREAKER POLE	LOAD (kva)	AØ BØ CØ	LOAD (kva)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION / LOCATION	THHN WIRE SIZE	CKT. NO.
1	#12	LIGHTING, SOUTHWEST	20	1	1.3		-	1	20	SPARE	#12	2
3	#12	OUTLETS, SW	20	1	0.9		1.3	1	20	SW OUTLETS	#12	4
5	#12	SPARE	20	1			1.0	1	20	LIGHTING, SOUTHEAST	#12	6
7	#12	OUTLETS, SW	20	1	0.9		1.0	1	20	LIGHTING CENTER	#12	8
9	#12	WASHING MACHINE	20	1	0.7		-	1	20	SPARE	#12	10
11	#12	LIGHTING, CENTER	20	1	0.7		-	1	20	SPARE	#12	12
13	#12	OUTLETS, SE	20	1	1.3		-	1	20	SPARE	#12	14
15	#12	SPARE	20	1	-		1.1	1	20	SE OUTLETS	#12	16
17	#12	LIGHTING, NORTHWEST	20	1	0.8		-	1	20	SPARE	#12	18
19	#12	REFRIGERATOR OUTLETS	20	1	1.3		-	1	20	SPARE	#12	20
21	#12	OUTLETS, SE	20	1	1.3		-	1	20	SPARE	#12	22
23	#12	OUTLETS, CENTER	20	1	1.3		-	1	20	SPARE	#12	24
25	#12	OUTLETS, NE	20	1	1.1		-	1	20	SPARE	#12	26
27	#12	SPARE	20	1	-		-	1	20	SPARE	#12	28
29	#12	SPARE	20	1	-		1.0	1	20	LIGHTING, NORTHEAST	#12	30
31	#12	SPARE	20	1	-		1.1	1	20	N OUTLETS	#12	32
33	#12	LIGHTING, EXTERIOR	20	1	0.6		1.3	1	20	N OUTLETS	#12	34
35	#12	TIMECLOCK	20	1	0.6		1.3	1	20	NW OUTLETS	#12	36
37	#12	SPARE	20	1	-		1.3	1	20	NW OUTLETS	#12	38
39		SPACE					2.1	2	30	DUCTLESS MINI-SPLIT	#12	40
41		SPACE					2.1					42

SOLID NEUTRAL
NEUTRAL WIRE (W)

TOTAL CONNECTED LOAD (kva)= 27.4
AØ=9.3 BØ=9.3 CØ=8.8

GROUND BUS
GROUND WIRE (G)

PANEL: PNL B (EXISTING)
LOCATION: ELEC. RM. 113
FEEDER SOURCE: SERVICE PROVIDER

VOLTAGE: 208/120V, 225A 3Ø, 4W
ENCLOSURE: RECESSED W/EQUIPMENT GND BAR
BOLT-ON BRK 22000 AIC, MLO

CKT. NO.	THHN WIRE SIZE	LOAD DESCRIPTION / LOCATION	BREAKER AMP	BREAKER POLE	LOAD (VA)	AØ BØ CØ	LOAD (VA)	BREAKER POLE	BREAKER AMP	LOAD DESCRIPTION / LOCATION	THHN WIRE SIZE	CKT. NO.
1	#10	VVT #1, 5kw Heat	30	2	2.5		4.0	2	50	OVEN	#6	2
3					2.5		4.0					4
5	#10	VVT #2, 5kw Heat	30	2	2.5							6
7					2.5							8
9	#10	VVT #3, 5kw Heat	30	2	2.5		4.0	2	50	OVEN	#6	10
11					2.5		4.0					12
13	#10	VVT #4, 4kw Heat	30	2	2.0		-	-	-	BLANK	-	14
15					2.0		-	-	-	BLANK	-	16
17	#10	WATER HEATER	30	2	2.5		-	-	-	BLANK	-	18
19					2.5		-	-	-	BLANK	-	20
21	#10	VVT #5, 3.5kw Heat	30	2	1.7		-	-	-	BLANK	-	22
23					1.7		-	-	-	BLANK	-	24
25	#10	VVT #6, 5kw Heat	30	2	2.5		-	-	-	BLANK	-	26
27					2.5		-	-	-	BLANK	-	28
29	#10	VVT #7, 5kw Heat	30	2	2.5		-	-	-	BLANK	-	30
31					2.5		-	-	-	BLANK	-	32
33	-	BLANK	-	-	-		-	-	-	BLANK	-	34
35	-	BLANK	-	-	-		-	-	-	BLANK	-	36
37	#12	SPARE	20	1	-		-	-	-	BLANK	-	38
39	#10	Clothes Dryer	30	2	2.5		-	1	20	SPARE	#12	40
41					2.5		-	1	20	SPARE	#12	42

SOLID NEUTRAL
NEUTRAL WIRE (W)

TOTAL CONNECTED LOAD (kva)= 58.2
AØ=18.5 BØ=21.7 CØ=18.2

GROUND BUS
GROUND WIRE (G)



ELEC. RISER DIAGRAM

N.T.S.

ELECTRICAL ONE LINE DIAGRAM NOTES: (#)

1. EXISTING 200A FUSED DISCONNECT TO REMAIN.
2. EXISTING 200A DISCONNECT FUSED AT 150A TO REMAIN.
3. EXISTING 225A 120/208V 3Ø PANEL TO REMAIN. LOCATED IN ROOM #113
4. DEMO 120/208 1Ø 150A LOAD CENTER WITH MAIN BREAKER.
5. NOT USED.
6. EXISTING GRND ROD, GRND WIRE, AND PVC CONDUIT TO REMAIN.
7. ALL EXISTING ELECTRICAL SERVICE EQUIPMENT TO REMAIN.

DAMMON ENGINEERING, INC.
LOUISIANA & MISSISSIPPI
www.dammonengineering.com
info@dammonengineering.com
PH: 985.649.5832
Chief Engineer: Brian Mistich, PE
554 Old Spanish Trail
Slidell, LA 70458

REVISIONS

#	DESCRIPTION	DATE

SEAL:

STATE OF LOUISIANA
BRIAN A. MISTICH
License No. 30187
PROFESSIONAL ENGINEER

NEW DAYCARE
THREE PEAS IN A POD EARLY LEARNING CENTER
2165 GAUSE BLVD.
SLIDELL, LA 70461

JOB No:	2511
DATE:	09-30-2025
DRAWN BY:	LJP
CHECKED BY:	CKD

The above drawings and specifications, ideas and arrangements represented thereby are and shall remain the property of Dammon Engineering, and no part thereof shall be used in any other manner than as authorized by Dammon Engineering. Visual contact with these drawings or specifications shall constitute full acceptance of the foregoing restrictions and conditions.

SHEET TITLE:
PANEL SCHEDULE

DRAWING NUMBER:
E103

SHEET No: 12 of 12

FILE NAME: J:_Dammon\Kaufman Dry Goods\Current Drawings\11103 - PNL SCHEDULE.dwg LAYOUT: LAYOUT 1 PLOT: Monday, October 13, 2025 9:33:13 AM