

PUBLIC HEALTH—SANITARY CODE

**Table 411**  
**Minimum Plumbing Fixtures**

[The figures shown are based upon one fixture being the minimum required for the number of persons indicated or any fraction thereof, i.e., if the calculation yields any fraction (no matter how small), the next whole number greater than the fractional number is the minimum fixture requirement]

Building or Occupancy <sup>1</sup>	Occupant Content <sup>1</sup>	Water Closets (Urinals can be substituted for up to half of the required water closets)			Lavatories <sup>2</sup>	Bathubs, Showers and Miscellaneous fixtures		
		Children (total)	Fixtures					
Dwelling or Apt. House	Not Applicable	1 for each dwelling or dwelling unit	1 for each dwelling or dwelling unit				Washing machine connection per unit <sup>3</sup> . Bath tub or shower – one per dwelling or dwelling unit. Kitchen sink – one per dwelling or dwelling unit	
Schools: Licensed Pre-School, Day Care or Nursery <sup>20</sup>	Maximum Daily Attendance	Children (total) Age 0 – 4 years 1-20 21-40 41-80 For each additional 40 children over 80, add Age 5 years and above Male Female 1-40 41-80 81-120 121-160 For each additional 40 females over 160, add	Fixtures 1 2 3 1 1 2 3 4 1	To be provided in the same proportions as the number of water closets required Kitchen: 1 in each food preparation and utensil washing area located to permit convenient use by all food and utensil handlers. Caring for Infants: 1 in or adjacent to each diaper changing area but never to be located in a food preparation/storage or utensil washing area.			Kitchen: Children (total) 7-15: 3 compartment sink (or approved domestic or commercial dishwashing machine and a 2 compartment sink) <sup>12</sup> 16 – up: 3 compartment sink (dishwashing machine, if provided, must be a commercial type) <sup>12</sup> One laundry tray, service sink, or curbed cleaning facility with floor drain on premises for cleaning of mops/mop water disposal. Caring for Infants: One extra laundry tray, service sink, or similar fixture is required to clean and sanitize toilet training potties immediately after each use. Such fixture shall be dedicated solely for this purpose and shall not be in the food preparation/storage, utensil washing, or dining areas.	
Schools: Elementary & Secondary	Maximum Daily Attendance	Persons (total) 1-50 51-100 101-150 151-200 For each additional 50 persons over 200, add	Male 2 3 4 5 1	Female 2 3 4 5 1	Persons (total) 1-120 121-240 For each additional 120 persons over 240, add	Male 1 2 1	Female 1 2 1	One drinking fountain for each 3 classrooms, but not less than one each floor
Office <sup>4</sup> and Public Buildings  (Applies to educational occupancies above the 12th grade <sub>(L)</sub> )	100 sq ft per person	Persons (total) 1-15 16-35 36-55 56-100 101-150 For each additional 100 persons over 150, add	Male 1 1 2 2 3 1	Female 1 2 2 3 4 1.5	Persons (total) 1-15 16-35 36-60 61-125 For each additional 120 persons over 125, add	Male 1 1 2 2 1	Female 1 2 2 3 1.5	Drinking Fountains Persons 1-100 101-250 251-500 No less than one fixture each floor subject to access.
Common toilet	Use the sq ft per person	Persons (total)	Male	Female	Persons (total)	Male	Female	Drinking Fountains Persons Fixtures