



TYPICAL LOW PRESSURE RECTANGULAR TO ROUND DUCT TAKEOFF DETAIL
N.T.S.

NOTE: TAKE-OFF FITTINGS SHALL BE FACTORY FABRICATED SPIN-IN TYPE. NO DOVETAIL FIELD JOINTS OR FITTINGS ARE ALLOWED.



TYPICAL LOW PRESSURE RECTANGULAR TO RECTANGULAR DUCT TAKEOFF DETAIL
N.T.S.

NOTE: TAKE-OFF FITTINGS SHALL BE FACTORY FABRICATED SPIN-IN TYPE. NO DOVETAIL FIELD JOINTS OR FITTINGS ARE ALLOWED.



HORIZONTAL GAS FURNACE W/ DX COOLING DETAIL
N.T.S.

NOTES:
1. CONTRACTOR SHALL PROVIDE FLOAT SWITCH INSIDE DRAIN PAN TO DE-ENERGIZE UNIT WHEN ACTIVATED.

REVISIONS	DATE	DESCRIPTION



NEW MEDICAL OFFICE
DIANA OAK HARBOR REAL ESTATE
LLC

540 OAK HARBOR BLVD
SLIDELL, LA 70459

JOB No: 2513 | DATE: 05-16-2025
DRAWN BY: BAW | CHECKED BY: CAD

SHEET TITLE:
MECHANICAL DETAILS

DRAWING NUMBER:
M4.1