

Dress up columns.  
material?

Needs to show  
shingles  
Roof Material?  
Size? specs?

\* No character defining features  
\* Need some more elements added  
to design.

Material?

Add additional  
column.

Picture frame  
screening.

Size of  
piers?

Railing  
needed.

Reflect Height of  
Building.

Left min  
for BFE + 2'.  
Needs to be at  
12' min.

Add stairs





Add railings  
(show typical detail for measurements)

Porch needs  
to be  
8'

No screening under  
porch.

Add Fascia  
Board.  
Building looks Floating

to open of a wall  
needs to be broken up.



REVISIONS	DATE

SEAL:

NEW DENTIST OFFICE  
CHERIE DDS, LLC  
5145 NICHOLSON STREET  
MANVELLE, LA  
JOB No: 2025 DATE: 06-06-25  
DRAWN BY: BAW  
CHECKED BY: DCD

SHEET TITLE:  
BUILDING ELEVATIONS  
DRAWING NUMBER:  
**A102**  
SHEET No: 9 of 9

985-649-7381  
DAVE