SOUTHERN Non-Destructive Testing INSPECTION
Digital concrete scanning

1236 MacArthur Ave.
Harvey, LA 70058
Ph. (504) 347-1752
Fax (504) 348-3251
www.southerninspection.com

Date:	September 15, 2022
Job #	
Page	1 of 1

Ticket No.	00904322

GPR Testing

CUSTOMER	Haley Faucheaux	CUSTOMER REPRESNTATIVE	Haley Faucheaux
PROJECT	GPR		
LOCATION	305 S Central Blvd. Chauvin, LA		

Scan	Size	Result	Comments		File	
			!st Floor Bathroom, and Closet			
			Master Bath and Closet			
			Scanned for rebar was tying new slab to			
			existing slab			
			Rebar found 2" apart			
			Wire mesh in new slab 4-1/2" -5" thick			
			No footing - Brick ledge only			
			Patiop - Front			
			Scan for rebar to see if new slab and old			
			slab was tied in			
			Wire mesh found, slab 4-1/2" to 5" thick			
			All scans were marked and reviewed			
			with customer			

Dennis Branson

Southern Inspection Representative

Customer Representative