



DAMMON ENGINEERING, INC

Date: 12-22-25 Project: Gonzos Smoke House

Reviewed: X

Reviewed as noted: _____

Revise and ReSubmit: _____

Rejected: _____

Other: _____

Correction or comments made on the shop drawings during this review do not relieve the contractor from compliance with requirements of the drawings and specifications. This check is only for review of the general conformance with the design concept of the project and general compliance with the information given in the contract documents. This contractor is responsible for: confirming and correlating all quantities and dimensions, selecting fabrication processes and techniques of construction; coordinating his or her work with that of all other trades and performing all in a safe and satisfactory manner.

Submittal item: Fire Supression

Comments: _____

GENERAL NOTES:

THIS SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH:

- NFPA 17A
- THE LOUISIANA STATE FIRE MARSHAL'S OFFICE
- THE MANUFACTURER'S SPECIFICATIONS
- ALL NOZZLES PROVIDED WITH NOZZLE CAPS
- HOOD CANOPY NEW
- DRAWING NOT TO SCALE
- UTILIZING 13 OF 15 FLOW POINTS
- ALL SUPPLY LINE TO BE 3/8 " BLACK SCHEDULE 40 PIPE
- ALL BRANCH LINE TO BE 3/8 " BLACK SCHEDULE 40 PIPE

**PYRO CHEM
PCL 460
WET CHEMICAL
UL 300 LISTED**

**SYSTEM
DETAIL**

BILL OF MATERIALS

QTY. NAME

BILL OF MATERIALS

- QTY. NAME
- 1 ASCO GAS SHUT-OFF VALVE
 - 1 RPS PULL STATION
 - 2 IH PLENUM 10" HORZL
 - 5 AUTOMATIC DETECTOR
 - 1 IH GRIDDLE 36"X30" @ 24"-48"L
 - 2 2L RANGE 28"X28" @ 34"-48"
 - 1 2H FRYER 27.75"X18" @ 24"-48"
 - 1 PYRO CHEM PCL 460
 - 1 PYRO CHEM NMHH-3 CONTROLHEAD
 - 2 20 DUCT LESS THAN 100" MAX

**GONZO'S SMOKEHOUSE
13899 RIVER ROAD
LULING, LA 70070**



**FIRE AND SAFETY
COMMODITIES**
245 WOODLAND DR
LAPLACE LA 70068
(504) 465-5994
MACE@FIRESAFETYINC.NET
FIRM: F58
LIC. #: E383