



"RFI" Request For Information: 004

RFI#		Date Created:	
4		4/6/2012	
To Company	Answered by	From Company	Authorized by
Greg Carter, Synergy Electric 475 Metroplex Dr. suf. 113 NashVile, TN. 37211		Idn-Acme, Inc. P.O. Drawer 13748 New Orleans, LA 70185	W. Wayne Hilliard 504-905-8075 whilliard@idnacme.com
Subject		Discipline	Category
North Oaks Hospital Expansion Phase 1		Special Systems	Access Control
Cost Impact Comments	Schedule Impact	Dwg. Impact	
Not Sure	Not Sure	Not Sure	
Cc: Company Name	Contact Name	Copies	
Freedom Alarm	Donald Fincher	1	
Question	Importance: HIGH	Date Required: April 11, 2012	
Please see attaced sheet listing all questions regarding Access Control Prox Readers per each floor			
Answer		Date Answered:	
IDN-Acme, Inc. P.O. Drawer 13748 New Orleans, LA 70185 Fax. 504.617.6128		Page 1	

First Floor

Door ST3-1 Exterior from Stair 3

Shouldn't there be a Prox Reader on the outside?

Door 1330 Exterior from Bio-Med Workroom

Shouldn't the interior Pro Reader be next to the ADA button?

Door 1313 Pack and Prep to HK

Floor Plans do not show a Prox Reader. Door and Hardware schedule show Prox Reader.
Which is correct?

Door 1310B Corridor 1310A from Breakout 1310

Floor Plans do not show a Prox Reader. Door schedule does not show a Prox Reader. Hardware schedule does show a Prox Reader. Which one is correct?

Door 1009 Corridor 1009 to Corridor 1009A

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

Door 1011 Exterior from Mech.1011

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

Door 1070 Exterior from Mech.1070

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

Door 1333 Exterior from Electrical 1333

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

Doors 1009A and 1221A

How are these doors suppose to operate.

Door 1230A Waiting form Shell Space

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

Door 1201B Exterior from Lobby 1201

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

Doors 1331 and 1332B

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

Door 1333A

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

ST4-1 Corridor 1009A from Stair 4

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

Second Floor

Door 2012 Corridor 2020 to Corridor 2012

Hardware schedule has an electric strike and Mag Lock.
How is this door suppose to operate?

Door R2024

Shows on Hardware schedule. Not list on Door schedule or found on plans.
Is this a good number?

Door 2300 Corridor 2025 from Shell Space

Shows on Door and Hardware schedule. Can't locate door on floor plans.
Where would I find this door.

Door 2309 Restricted Corridor to Shell Space

Shows on Door and Hardware schedule. Can't locate door on floor plans.
Where would I find this door.

Door 2011B Corridor 2020 to Shell

Hardware schedule has an electric strike and Mag Lock.
How is this door suppose to operate?

Door 2500B Semi-Restricted Corridor 2518 to Sterile Core

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

Door 2520B Semi-Restricted Corridor 2510B to Semi-Restricted Corridor 2520

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

Door 2515 Semi-Restricted Corridor 2518 to Semi-Restricted Corridor 2515

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

Third Floor

Door 3401A Corridor 3600E from Bridge 3401

Floor Plans do not show a Prox Reader. Door and Hardware schedule show Prox Reader.
Which is correct?

Door 3011A Equipment Storage 3011 to P Tube 3411A

Floor Plans do not show a Prox Reader. Door and Hardware schedule show Prox Reader.
Which is correct?

Door 3401B and 3401C Exterior from Bridge 3401

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

Door 3523 Data Room

Shouldn't this door have a Prox Reader?

Fourth Floor

Door 4130 Corridor 4100D to Staff Lounge

Floor Plans do not show a Prox Reader. Door and Hardware schedule show Prox Reader.
Which is correct?

Door 4246 Dr.'s Cart 4243 to Med.'s 4246

Floor Plans do not show a Prox Reader. Door and Hardware schedule show Prox Reader.
Which is correct?

Fifth Floor

Door 5016 Corridor 5015 from Corridor 5016

Floor Plans show a Prox Reader. Door and Hardware schedule do not show a Prox Reader.
Which is correct?

Door ST3-5 Stair 3 from ANTE 5216B

Need clarification whether this door is a Read in/Read out or if one of the readers goes to door 5216B Isolation Room?

Door ST1-5 Stair 1 from Corridor 5015

Need clarification whether this door is a Read in/Read out or if one of the readers goes to door 5016 for a Read in/Read out there?