





THESE GENERAL NOTES ARE THE RESPONSIBILITY OF LANG DESIGN. THE CLIENT IS RESPONSIBLE FOR THE ACCURACY OF THE INFORMATION PROVIDED. LANG DESIGN SHALL NOT BE RESPONSIBLE FOR ANY ERRORS OR OMISSIONS. LANG DESIGN SHALL NOT BE RESPONSIBLE FOR ANY CONSTRUCTION DEFECTS OR DAMAGE TO THE PROPERTY OF THE CLIENT. LANG DESIGN SHALL NOT BE RESPONSIBLE FOR ANY DELAYS OR COST INCREASES DUE TO CHANGES OR OMISSIONS BY THE CLIENT. LANG DESIGN SHALL NOT BE RESPONSIBLE FOR ANY DELAYS OR COST INCREASES DUE TO CHANGES OR OMISSIONS BY THE CLIENT.

CLIENT: CSCC  
SALES/ENGINEER: RICHIE JOSEPHUS  
DESIGNER: NEIL TANNER



APPROVED BY: \_\_\_\_\_  
DATE: 4/1/21

FILE: ARTWORK / SALES ART  
CHICKEN SALAD CHICK SIGNELS


**COLORS:**  
 BLACK  WHITE  PMS 374  PMS 1805  PMS 602  PMS 7507   
**TYPE FACE:**



- GENERAL NOTES:**
1. CONCRETE PROVIDED SHALL OBTAIN A 3,000 PSI, 28 DAY COMPRESSIVE STRENGTH. CONCRETE SHALL BE PLACED ON UNDISTURBED SOIL. THIS DESIGN ASSUMES A LATERAL SOIL BEARING PRESSURE OF 150 PSF/FT AND A SOIL BEARING PRESSURE OF 2000 PSF. IF THESE CONDITIONS DO NOT EXIST, THE CONTRACTOR SHALL NOTIFY THE DESIGN ENGINEER.
  2. STEEL WELDS SHALL CONFORM TO AWS D1.1. ALL WELDS SHALL BE MADE USING E70XX ELECTRODES BY WELDERS QUALIFIED IN ACCORDANCE WITH AWS STANDARDS.
  3. STEEL TUBES SHALL CONFORM TO ASTM A500 B, MINIMUM YIELD STRENGTH OF 46 KSI. STEEL PIPE SHALL CONFORM TO ASTM A53 B, MINIMUM YIELD STRENGTH OF 35 KSI. STEEL ANGLE AND PLATE SHALL CONFORM TO ASTM A36, MINIMUM YIELD STRENGTH OF 36 KSI.
  4. ANCHOR RODS SHALL CONFORM TO ASTM F1554 GRADE 85 AND SHALL BE HOT DIPPED GALVANIZED, MINIMUM YIELD STRENGTH OF 55 KSI.
  5. REINFORCING BARS SHALL CONFORM TO ASTM A615 GRADE 60, DEFORMATIONS PER ASTM A305. DO NOT WELD REINFORCING BARS.
  6. STRUCTURAL BOLTS SHALL CONFORM TO ASTM A325. NUTS SHALL CONFORM TO ASTM A563. WASHERS SHALL CONFORM TO ASTM F436. ALL SHALL BE COATED TO PREVENT CORROSION. ALL BOLTS SHALL BE TIGHTENED USING THE TURN OF NUT METHOD.
  7. ANY DEVIATION FROM ANY PART OF THIS DRAWING WITHOUT PRIOR WRITTEN CONSENT FROM THE ENGINEER OF RECORD VIOLATES THIS DRAWING IN ITS ENTIRETY.
  8. THE STRUCTURE DESIGNED ON THIS DRAWING IS INTENDED TO BE INSTALLED AT THE ADDRESS SHOWN AND MAY NOT BE USED AND ANY OTHER LOCATION.
  9. SIGN CABINET AND CLADDING DESIGN BY OTHERS.
  10. ELECTRICAL DESIGN BY OTHERS.
  11. ALL STEEL TUBES, ANGLES AND PLATES SHALL BE COATED TO RESIST CORROSION. ALL STRUCTURAL BOLTS SHALL BE ZINC COATED TO PREVENT CORROSION.
  12. SIGN TO BE CONSTRUCTED TO NEC 800 STANDARD. SIGN TO BEAR UL LABEL. SIGN TO HAVE ELECTRICAL DISCONNECT ON THE EXTERIOR.



**MATCH PLATE DETAIL**  
14"x14"x3/16" PLATE (2 R6x1/4)  
NTS



**BASE PLATE DETAIL**  
NTS

SITE ADDRESS:  
 Chicken Salad Chick  
 1522 Gause Blvd.  
 Slidell, LA 70458

