

FW: St. Tammany Permit Requirement Complete

From: Richard Niemi <richard@mcmathconstruction.com>

To: David Dammon <david@dammonengineering.com>

See below

Richard Niemi

McMath Construction

1125 N. Causeway Blvd

Mandeville, La 70471

O: 985.624.9010

C: 985.237.9435

From: Richard Niemi <Richard@McmathConstruction.com>

Date: Thursday, October 2, 2025 at 10:22 AM

To: 'aultma_j@bellsouth.net' <aultma_j@bellsouth.net>

Subject: Fw: St. Tammany Permit Requirement Complete

Richard Niemi

McMath Construction

1125 N. Causeway Blvd. Mandeville, LA 70471

O: [985-624-9010](tel:985-624-9010) | C: [985-237-9435](tel:985-237-9435) | F: [985-624-6847](tel:985-624-6847)

richard@mcmathconstruction.com

www.mcmathconstruction.com

From: no-reply@mygovernmentonline.org <no-reply@mygovernmentonline.org>

Sent: Thursday, October 2, 2025 10:13:58 AM

To: Richard Niemi <Richard@McmathConstruction.com>

Subject: St. Tammany Permit Requirement Complete

Notification from MGO Connect

To see the details of this message, log on to the MGO Connect at [MGO Connect](#)



Jurisdiction
Logo

Completed Requirement

St. Tammany Parish Permitting has completed a Building Plan Review requirement for [Project 2025-5729](#) at 132 W RUELLE ST MANDEVILLE LA 70471 on .

The following comments were provided at the time the requirement was completed:

Need stamped engineered wind design showing shear walls and location, all hold downs for shear walls and strapping and hold downs at openings, Structure needs to be built to a 140 MPH wind speed, Need stamped foundation plan, Exterior load bearing walls over ten foot need to be 2x6 walls, Need joist hangers on ceiling joist, Need smoke alarm and carbon monoxide detector upstairs, Need 5/8 type X sheetrock on garage ceiling, Need two layers of 30lb underlayment on roofs, Need R-values
