

PANEL SCHEDULE													
PANEL LOCATION: #11 ELECTRICAL ROOM 3RD THIRD LEVEL, FEEDER SOURCE: MDP PANEL		VOLTAGE: ENCLOSEURE: 208/120V, 200A, 80 AMP/100 FLUSH MOUNTED IN EQUIPMENT AND 80A 80 D TYPE GO LOAD CENTER		PANEL LOCATION: #12 ELECTRICAL ROOM 3RD THIRD LEVEL, FEEDER SOURCE: MDP PANEL		VOLTAGE: ENCLOSEURE: 208/120V, 200A, 80 AMP/100 FLUSH MOUNTED IN EQUIPMENT AND 80A 80 D TYPE GO LOAD CENTER							
CKT NO	THIN WIRE SIZE	LOAD DESCRIPTION LOCATION	BREAKER AMP POLE	LOAD (VA)	AS BS GS	LOAD (VA)	BREAKER POLE AMP	LOAD DESCRIPTION LOCATION	THIN WIRE SIZE	CKT NO			
1	#12	COMMON HALL BETWEEN EXT KING SUITE # STARS H	20 1	1800		1800	1 20	EXTENDED KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	#12	2			
3	#12	EXTENDED KING SUITE FTAC 200V RECEPTACLE	20 2	2028		1800	1 20	EXTENDED KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	4			
5	#12	EXTENDED KING SUITE FTAC 200V RECEPTACLE	20 2	2028		1800	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	6			
7	#12	EXTENDED KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		2028	1 20	COMMON HALL BETWEEN EXT KING SUITE # KING SUITE	#12	8			
9	#12	EXTENDED KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	20 1	1200		1740	1 20	KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	#12	10			
11	#12	KING SUITE FTAC 200V RECEPTACLE	20 2	2028		1500	1 20	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	12			
13	#12	KING SUITE FTAC 200V RECEPTACLE	20 2	2028		1500	1 20	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	14			
15	#12	KING SUITE FTAC 200V RECEPTACLE	20 2	2028		1500	1 20	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	16			
17	#12	COMMON HALL BETWEEN EXT KING SUITE	20 1	1740		1040	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	18			
19	#12	EXTENDED KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		2028	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	20			
21	#12	EXTENDED KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		2028	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	22			
23	#12	EXTENDED KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	20 1	1200		2028	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	24			
25	#12	EXTENDED KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		2028	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	26			
27	#12	EXTENDED KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		1200	1 20	EXTENDED KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	28			
29	#12	KING SUITE FTAC 200V RECEPTACLE	20 2	2028		1740	1 20	COMMON HALL BETWEEN EXT KING SUITE	#12	30			
31	#12	EXHAUST FAN IN ELEG ROOM 338	20 1	500		400	1 20	SPARE	#12	32			
33	-	SPARE	20 1	-		840	1 20	GUEST CORRIDOR 305 # STARS 1 LIGHTS	#12	34			
35	-	SPARE	20 1	-		840	1 20	SPARE	#12	36			
37	-	SPARE	20 1	-		-	1 20	SPARE	#12	38			
39	#12	GUEST CORRIDOR 305 HALL SCONES	20 1	252		-	1 20	SPARE	#12	40			
41	-	SPARE	20 1	-		1040	1 20	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	42			
				SOLID NEUTRAL NEUTRAL WIRE (N)				GROUND BUS GROUND WIRE (G)					
				TOTAL CONNECTED LOAD (VA) =				TOTAL CONNECTED LOAD (VA) =					
				AD + 777 BS + 777 GS + 777				AD + 777 BS + 777 GS + 777					

PANEL SCHEDULE													
PANEL LOCATION: #12 ELECTRICAL ROOM 3RD THIRD LEVEL, FEEDER SOURCE: MDP PANEL		VOLTAGE: ENCLOSEURE: 208/120V, 200A, 80 AMP/100 FLUSH MOUNTED IN EQUIPMENT AND 80A 80 D TYPE GO LOAD CENTER		PANEL LOCATION: #13 ELECTRICAL ROOM 3RD THIRD LEVEL, FEEDER SOURCE: MDP PANEL		VOLTAGE: ENCLOSEURE: 208/120V, 200A, 80 AMP/100 FLUSH MOUNTED IN EQUIPMENT AND 80A 80 D TYPE GO LOAD CENTER							
CKT NO	THIN WIRE SIZE	LOAD DESCRIPTION LOCATION	BREAKER AMP POLE	LOAD (VA)	AS BS GS	LOAD (VA)	BREAKER POLE AMP	LOAD DESCRIPTION LOCATION	THIN WIRE SIZE	CKT NO			
1	#12	SINGLE QUEEN SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		1800	1 20	SINGLE QUEEN SUITE COFFEE MAKER & FRIG. RECEPTACLE	#12	2			
3	#12	SINGLE QUEEN SUITE LIGHTS RECEPTABLES & BATH EXHAUST	20 1	1200		1000	1 20	THIRD LEVEL INTERCOM SYSTEM	#12	4			
5	#12	COMMON HALL BETWEEN EXT KING SUITE	20 1	2071		374	2 18	ICE MACHINE	#12	6			
7	#12	COMMON HALL BETWEEN EXT KING SUITE	20 1	2071		374	2 18	ICE MACHINE	#12	8			
9	#12	VENDS MACHINE	20 1	1000		2028	1 20	KING SUITE FTAC 200V RECEPTACLE	#12	10			
11	#12	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	20 1	1040		2028	1 20	KING SUITE FTAC 200V RECEPTACLE	#12	12			
13	#12	KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		2028	1 20	KING SUITE FTAC 200V RECEPTACLE	#12	14			
15	#12	COMMON HALL BETWEEN KING SUITE	20 1	1500		2028	1 20	KING SUITE FTAC 200V RECEPTACLE	#12	16			
17	#12	KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		1040	1 20	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	18			
19	#12	COMMON HALL BETWEEN EXT KING SUITE	20 1	1500		1040	1 20	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	20			
21	#12	COMMON HALL BETWEEN EXT KING SUITE	20 1	1500		2028	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	22			
23	#12	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	20 1	1200		1800	1 20	KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	#12	24			
25	#12	EXTENDED KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	20 1	1200		2028	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	26			
27	#12	EXTENDED KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		2028	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	28			
29	#12	EXTENDED KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		2028	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	30			
31	#12	EXTENDED KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		2028	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	32			
33	#12	RECEPTABLES IN SUPPLY RM. 318 & ELEG ROOM 318	20 1	1050		2028	1 20	KING SUITE FTAC 200V RECEPTACLE	#12	34			
35	#12	COMMON HALL BETWEEN EXT KING SUITE	20 1	1740		2028	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	36			
37	#12	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	20 1	1040		1800	1 20	KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	#12	38			
39	#12	RECEPTABLES IN SUPPLY RM. 318 & ELEG ROOM 318	20 1	240		2028	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	40			
41	#12	EXT # EMERGENCY LIGHTS FOR SECOND LEVEL	20 1	240		840	1 20	GUEST CORRIDOR 305 # STARS 2 LIGHTS	#12	42			
43	#12	EXTENDED KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	20 1	1200		200	1 20	THIRD LEVEL SHOCK DETECTORS	#12	34			
45	-	SPARE	20 1	-		292	1 20	GUEST CORRIDOR 305 HALL SCONES	#12	38			
47	-	SPARE	20 1	-		-	1 20	SPARE	#12	40			
49	-	SPARE	20 1	-		-	1 20	SPARE	#12	42			
				SOLID NEUTRAL NEUTRAL WIRE (N)				GROUND BUS GROUND WIRE (G)					
				TOTAL CONNECTED LOAD (VA) =				TOTAL CONNECTED LOAD (VA) =					
				AD + 777 BS + 777 GS + 777				AD + 777 BS + 777 GS + 777					

PANEL SCHEDULE													
PANEL LOCATION: #13 ELECTRICAL ROOM 4TH FOURTH LEVEL, FEEDER SOURCE: MDP PANEL		VOLTAGE: ENCLOSEURE: 208/120V, 200A, 80 AMP/100 FLUSH MOUNTED IN EQUIPMENT AND 80A 80 D TYPE GO LOAD CENTER		PANEL LOCATION: #14 ELECTRICAL ROOM 4TH FOURTH LEVEL, FEEDER SOURCE: MDP PANEL		VOLTAGE: ENCLOSEURE: 208/120V, 200A, 80 AMP/100 FLUSH MOUNTED IN EQUIPMENT AND 80A 80 D TYPE GO LOAD CENTER							
CKT NO	THIN WIRE SIZE	LOAD DESCRIPTION LOCATION	BREAKER AMP POLE	LOAD (VA)	AS BS GS	LOAD (VA)	BREAKER POLE AMP	LOAD DESCRIPTION LOCATION	THIN WIRE SIZE	CKT NO			
1	#12	COMMON HALL BETWEEN EXT KING SUITE # STARS H	20 1	840		1800	1 20	EXTENDED KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	#12	2			
3	#12	EXTENDED KING SUITE FTAC 200V RECEPTACLE	20 2	2028		1200	1 20	EXTENDED KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	4			
5	#12	EXTENDED KING SUITE FTAC 200V RECEPTACLE	20 2	2028		2028	1 20	EXTENDED KING SUITE FTAC 200V RECEPTACLE	#12	6			
7	#12	EXTENDED KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		2028	1 20	COMMON HALL BETWEEN EXT KING SUITE # KING SUITE	#12	8			
9	#12	EXTENDED KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		1740	1 20	COMMON HALL BETWEEN EXT KING SUITE # KING SUITE	#12	10			
11	#12	EXTENDED KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		1000	1 20	KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	#12	12			
13	#12	KING SUITE FTAC 200V RECEPTACLE	20 2	2028		1040	1 20	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	14			
15	#12	KING SUITE FTAC 200V RECEPTACLE	20 2	2028		1000	1 20	KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	#12	16			
17	#12	KING SUITE FTAC 200V RECEPTACLE	20 2	2028		1040	1 20	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	18			
19	#12	GUEST LAUNDRY 200V DRYER RECEPTACLE	30 2	2760		840	1 20	GUEST CORRIDOR 405 # STARS LIGHTS	#12	20			
21	#12	GUEST LAUNDRY 200V DRYER RECEPTACLE	30 2	2760		480	1 20	ELEG ROOM 436 LIGHTS	#12	22			
23	#12	EXHAUST FAN IN ELEG ROOM 438	20 1	500		2760	1 30	GUEST LAUNDRY 200V DRYER RECEPTACLE	#12	24			
25	#12	GUEST CORRIDOR 405 # STARS LIGHTS	20 1	252		2760	1 30	GUEST LAUNDRY 200V DRYER RECEPTACLE	#12	26			
27	#12	GUEST LAUNDRY FAN	20 1	1800		800	1 20	GUEST LAUNDRY FAN RECEPTACLE	#12	28			
29	#12	GUEST LAUNDRY FTAC 200V RECEPTACLE	20 2	2028		1800	1 20	ELECTRIC SPACE HEATER RECEPT. IN ATTIC ABOVE FOURTH LEVEL	#12	30			
31	#12	GUEST LAUNDRY FTAC 200V RECEPTACLE	20 2	2028		1800	1 20	ELECTRIC SPACE HEATER RECEPT. IN ATTIC ABOVE FOURTH LEVEL	#12	32			
33	#12	COMMON HALL BETWEEN KING SUITE # EXT KING SUITE	20 1	1740		1040	1 20	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	34			
35	#12	ELECTRIC SPACE HEATER RECEPT. IN ATTIC ABOVE FOURTH LEVEL	20 1	1800		800	1 20	ELECTRIC SPACE HEATER RECEPT. IN ATTIC ABOVE FOURTH LEVEL	#12	36			
37	-	SPARE	20 1	-		-	1 20	SPARE	#12	38			
39	-	SPARE	20 1	-		-	1 20	SPARE	#12	40			
41	-	SPARE	20 1	-		-	1 20	SPARE	#12	42			
				SOLID NEUTRAL NEUTRAL WIRE (N)				GROUND BUS GROUND WIRE (G)					
				TOTAL CONNECTED LOAD (VA) =				TOTAL CONNECTED LOAD (VA) =					
				AD + 777 BS + 777 GS + 777				AD + 777 BS + 777 GS + 777					

PANEL SCHEDULE													
PANEL LOCATION: #14 ELECTRICAL ROOM 4TH FOURTH LEVEL, FEEDER SOURCE: MDP PANEL		VOLTAGE: ENCLOSEURE: 208/120V, 200A, 80 AMP/100 FLUSH MOUNTED IN EQUIPMENT AND 80A 80 D TYPE GO LOAD CENTER		PANEL LOCATION: #15 ELECTRICAL ROOM 4TH FOURTH LEVEL, FEEDER SOURCE: MDP PANEL		VOLTAGE: ENCLOSEURE: 208/120V, 200A, 80 AMP/100 FLUSH MOUNTED IN EQUIPMENT AND 80A 80 D TYPE GO LOAD CENTER							
CKT NO	THIN WIRE SIZE	LOAD DESCRIPTION LOCATION	BREAKER AMP POLE	LOAD (VA)	AS BS GS	LOAD (VA)	BREAKER POLE AMP	LOAD DESCRIPTION LOCATION	THIN WIRE SIZE	CKT NO			
1	#12	DOUBLE QUEEN SUITE LIGHTS RECEPTABLES & BATH EXHAUST	20 1	1040		1800	1 20	DOUBLE QUEEN SUITE COFFEE MAKER & FRIG. RECEPTACLE	#12	2			
3	#12	DOUBLE QUEEN SUITE FTAC 200V RECEPTACLE	20 2	2028		1040	1 20	DOUBLE QUEEN SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	4			
5	#12	DOUBLE QUEEN SUITE FTAC 200V RECEPTACLE	20 2	2028		2028	2 20	DOUBLE QUEEN SUITE FTAC 200V RECEPTACLE	#12	6			
7	#12	COMMON HALL BETWEEN DOUBLE QUEEN SUITES	20 1	1800		2028	1 20	DOUBLE QUEEN SUITE FTAC 200V RECEPTACLE	#12	8			
9	#12	DOUBLE QUEEN SUITE LIGHTS RECEPTABLES & BATH EXHAUST	20 1	1040		2028	2 20	SINGLE QUEEN SUITE ACC. FTAC 200V RECEPTACLE	#12	10			
11	#12	DOUBLE QUEEN SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		2028	1 20	DOUBLE QUEEN SUITE FTAC 200V RECEPTACLE	#12	12			
13	#12	SINGLE QUEEN SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		800	1 20	SINGLE QUEEN SUITE ACC. FTAC 200V RECEPTACLE	#12	14			
15	#12	SINGLE QUEEN SUITE LIGHTS RECEPTABLES & BATH EXHAUST	20 1	1000		1000	1 20	FOURTH LEVEL INTERCOM SYSTEM	#12	16			
17	#12	GORRIDOR (BATH END) FTAC 200V RECEPTACLE	20 2	2071		374	2 18	ICE MACHINE	#12	18			
19	#12	VENDS MACHINE	20 1	1000		3000	1 20	KING SUITE FTAC 200V RECEPTACLE	#12	20			
21	#12	KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		2028	1 20	KING SUITE FTAC 200V RECEPTACLE	#12	22			
23	#12	KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		2028	1 20	KING SUITE FTAC 200V RECEPTACLE	#12	24			
25	#12	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	20 1	1040		2028	1 20	KING SUITE FTAC 200V RECEPTACLE	#12	26			
27	#12	KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	20 1	1800		1500	1 20	RECEPTABLES IN SUPPLY ROOM 418 & ELEG ROOM 418	#12	28			
29	#12	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	20 1	1040		2028	1 20	KING SUITE FTAC 200V RECEPTACLE	#12	30			
31	#12	COMMON HALL BETWEEN EXT KING SUITE # KING SUITE	20 1	1740		2028	1 20	KING SUITE FTAC 200V RECEPTACLE	#12	32			
33	#12	EXT # EMERGENCY LIGHTS FOR SECOND LEVEL	20 1	240		840	1 20	GUEST CORRIDOR 405 # STARS 2 LIGHTS	#12	34			
35	-	SPARE	20 1	-		-	1 20	SPARE	#12	36			
37	-	SPARE	20 1	-		-	1 20	SPARE	#12	38			
39	-	SPARE	20 1	-		-	1 20	SPARE	#12	40			
41	-	SPARE	20 1	-		-	1 20	SPARE	#12	42			
				SOLID NEUTRAL NEUTRAL WIRE (N)				GROUND BUS GROUND WIRE (G)					
				TOTAL CONNECTED LOAD (VA) =				TOTAL CONNECTED LOAD (VA) =					
				AD + 777 BS + 777 GS + 777				AD + 777 BS + 777 GS + 777					

PANEL SCHEDULE													
PANEL LOCATION: #15 ELECTRICAL ROOM 3RD THIRD LEVEL, FEEDER SOURCE: MDP PANEL		VOLTAGE: ENCLOSEURE: 208/120V, 200A, 80 AMP/100 FLUSH MOUNTED IN EQUIPMENT AND 80A 80 D TYPE GO LOAD CENTER		PANEL LOCATION: #16 ELECTRICAL ROOM 3RD THIRD LEVEL, FEEDER SOURCE: MDP PANEL		VOLTAGE: ENCLOSEURE: 208/120V, 200A, 80 AMP/100 FLUSH MOUNTED IN EQUIPMENT AND 80A 80 D TYPE GO LOAD CENTER							
CKT NO	THIN WIRE SIZE	LOAD DESCRIPTION LOCATION	BREAKER AMP POLE	LOAD (VA)	AS BS GS	LOAD (VA)	BREAKER POLE AMP	LOAD DESCRIPTION LOCATION	THIN WIRE SIZE	CKT NO			
1	#12	KING SUITE FTAC 200V RECEPTACLE	20 2	2028		1040	1 20	KING SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	2			
3	#12	KING SUITE FTAC 200V RECEPTACLE	20 2	2028		1800	1 20	KING SUITE COFFEE MAKER & FRIG. RECEPTACLE	#12	4			
5	#12	DOUBLE QUEEN SUITE FTAC 200V RECEPTACLE	20 2	2028		1800	1 20	DOUBLE QUEEN SUITE COFFEE MAKER & FRIG. RECEPTACLE	#12	6			
7	#12	DOUBLE QUEEN SUITE FTAC 200V RECEPTACLE	20 2	2028		1040	1 20	DOUBLE QUEEN SUITE LIGHTS RECEPTABLES & BATH EXHAUST	#12	8			
9	#12	DOUBLE QUEEN											