



Shop Drawing / Submittal Review

Project:

MSMA Project No. 1236

Laurel School Refurbishment

for the Recovery School District
820 Jackson Avenue
New Orleans, Louisiana 70130

RSD Project No. 2011-0891-0001

General Contractor: Tuna Construction, LLC

Description of Submittal: Alum. Storefront / Curtainwall
Reference: Section 08 41 00.00 & 08 44 13.00
Subcontractor: Star Glass
Supplier / Manufacturer: Kawneer, Misc

Submittal dated: 19 Dec 2016

Received Date: 20 Dec 2016

Review date: 06 Feb 2017

Reviewed by: John Conkerton, Project Arch JHC

SHOP DRAWING / SUBMITTAL REVIEW

- ☐ Reviewed ☐ Rejected ☐ Revise and Resubmit
☒ Furnish as Corrected/Noted ☒ Submit/Resubmit Specific Item(s) Noted

This review of shop drawings/submittals is only for general conformance with applicable codes and requirements of authorities having jurisdiction. This review of shop drawings/submittals is not conducted for conformance with the design concept of the project or for general compliance with the information given in the Contract Documents prepared by the Architect. The review was not conducted for the purpose of determining the accuracy of details such as dimensions and quantities, or for substantiating instructions for installation or performance of equipment or systems. Corrections or comments made on the shop drawings/submittals during this review do not relieve Contractor from compliance with the requirements of the Contract Documents. Review does not authorize any change or deviation from the Contract Documents. Review of a specific item shall not include review of an assembly of which the item is a component. Contractor remains responsible for: dimensions (which shall be confirmed and correlated at the job site); quantities; accuracy of content in submitted documents; errors and/or omissions in the submitted documents; fabrication processes; means, methods, techniques, sequences, and procedures of construction; coordination of the work of the Contractor and coordination of the Work of all trades; and for performing all Work in a safe and satisfactory manner. This review shall not constitute approval of safety precautions or construction means, methods, techniques, sequences or procedures.

CONTRACTOR'S RESPONSIBILITY FOR DIMENSIONS AND QUANTITIES

Dimensions and quantities shown on the shop drawing / submittal may have been reviewed (and revised, if necessary) by the Architect, solely as a convenience to the Contractor. This in no way releases the Contractor from his responsibility for providing correct dimensions and quantities on the shop drawings and submittals, in accordance with the construction documents and field conditions, or from his responsibility to coordinate such dimensions and quantities with the work of other trades, and any field conditions that may affect the dimensions or quantities indicated on the shop drawing / submittal.

REMARKS / COMMENTS

- Resubmit or provide missing info on:
 - Info on escape casement window hardware
 - Details on mounting of escape casement windows
 - Dimensions of opening for escape casement windows to verify code compliance
 - Details for shallow depth mullions that cross structure at window types AA, BB, CC & DD
 - Details for mullions between Mapes panel & glass
 - Jamb and sill details for doors
- Provide samples for glass, spandrel & Mapes panel
- Confirm engineering docs apply to submitted products & provide Louisiana engineer's stamp
- Coordinate w/ hardware supplier.
- See additional notes / comments marked on submittal.

mahlum /
Scairono
Martinez
Architects

3642 Magazine Street
New Orleans, LA 70115
(504) 896-2000
scaironomartinez.com