

---

Design Build, Engineering, Construction Management

5/23/2024

Trailer Bar AKA Southern Comfort Lounge  
2209 Gause Blvd, Slidell, Louisiana

Attn:

Commercial Facilitator

St, Tammany Parish Government

Permits and Inspections, 21454 Koop Drive STE, 1B

Mandeville, Louisiana 70471

Ref: TRAILER BAR AKA SOUTHERN COMFORT LOUNGE "ROOF REPAIR"

TO WHOM IT MAY CONCERN

We do hereby confirm that the above reference Trailer Bar AKA Southern Comfort Lounge Structure Roof Repair is hereby noted that the structure can and will support the proposed roof repair as per your request.

The report was carried out after my walk through with Owner and climb to the roof.

Method of installation: The contractor stated to install 2"x4" stripping on flat nailed to trailer truss 3" ring shanks. 2"x4" rafters nailed to 2"x4" stripping 2' on center 3" ring shanks and 1"x4" stripping on flat nailed to 2"x4" rafters 2' on center 2" ring shanks.

If further information is needed, please feel free to contact us at (504) 442-3499 or by email: [giekechukwu@yahoo.com](mailto:giekechukwu@yahoo.com).

Thanks

Gabriel Ekechukwu Sr

Taiwo Adejare PE